




**USAID**  
FROM THE AMERICAN PEOPLE



## **Black Sea Regional Transmission Planning Project**


---

### **Regional Model Construction Report**




January 2007

This report is made possible by the support of the American people through the United States Agency for International Development (USAID). The contents are the responsibility of the United States Energy Association and do not necessarily reflect the views of USAID or the United States.




## Contents

|                                                                     |      |
|---------------------------------------------------------------------|------|
| 1. INTRODUCTION.....                                                | 1.1  |
| 2. POWER SYSTEMS DATA.....                                          | 2.1  |
| 2.1. BULGARIA .....                                                 | 2.2  |
| 2.2. GEORGIA.....                                                   | 2.5  |
| 2.3. MOLDOVA .....                                                  | 2.8  |
| 2.4. ROMANIA.....                                                   | 2.12 |
| 2.5. RUSSIA.....                                                    | 2.15 |
| 2.6. TURKEY.....                                                    | 2.20 |
| 2.7. UKRAINE.....                                                   | 2.25 |
| 2.8. ARMENIA .....                                                  | 2.29 |
| 3. REGIONAL MODEL .....                                             | 3.1  |
| 3.1. Model development.....                                         | 3.1  |
| 3.2. Model characteristics.....                                     | 3.1  |
| 3.3. Methodology for transfer capacities calculations.....          | 3.4  |
| 3.3.1. DEFINITIONS OF TRANSFER CAPACITIES .....                     | 3.4  |
| 3.3.2. CALCULATION OF TTC.....                                      | 3.8  |
| 3.3.3. HARMONIZATION OF THE VALUES .....                            | 3.14 |
| 3.3.4. SIMULTANEOUSLY FEASIBLE (COMPOSITE) TRANSFER CAPACITIES..... | 3.15 |
| 3.3.5. TRANSFER CAPACITIES BETWEEN NON-NEIGHBOURING SYSTEMS....     | 3.16 |
| 3.4. Generation shifting lists .....                                | 3.17 |
| 4. ANALISES RESULTS .....                                           | 4.1  |
| 4.1. Model summary.....                                             | 4.1  |
| 4.2. Area interchange .....                                         | 4.3  |
| 4.3. Load flow analyses.....                                        | 4.5  |
| 4.3.1. BULGARIA .....                                               | 4.6  |
| 4.3.2. GEORGIA.....                                                 | 4.9  |
| 4.3.3. MOLDOVA .....                                                | 4.12 |
| 4.3.4. ROMANIA.....                                                 | 4.15 |
| 4.3.5. RUSSIA.....                                                  | 4.18 |
| 4.3.6. TURKEY.....                                                  | 4.25 |
| 4.3.7. UKRAINE .....                                                | 4.32 |
| 4.3.8. ARMENIA .....                                                | 4.43 |
| 4.3.9. REGION.....                                                  | 4.46 |
| 4.4. Network loading analyses .....                                 | 4.49 |
| 4.5. Voltage profile analyses .....                                 | 4.52 |
| 4.6. Contingency analyses.....                                      | 4.66 |
| 4.6.1. Bulgaria .....                                               | 4.66 |
| 4.6.2. Georgia.....                                                 | 4.68 |
| 4.6.3. Moldova .....                                                | 4.69 |



|        |                                         |      |
|--------|-----------------------------------------|------|
| 4.6.4. | Romania .....                           | 4.70 |
| 4.6.5. | Russia .....                            | 4.73 |
| 4.6.6. | Turkey .....                            | 4.76 |
| 4.6.7. | Ukraine .....                           | 4.79 |
| 4.6.8. | Armenia .....                           | 4.81 |
| 4.7.   | Border capacities .....                 | 4.82 |
| 4.7.1. | BULGARIA .....                          | 4.84 |
| 4.7.2. | GEORGIA .....                           | 4.85 |
| 4.7.3. | MOLDOVA .....                           | 4.86 |
| 4.7.4. | ROMANIA .....                           | 4.87 |
| 4.7.5. | RUSSIA .....                            | 4.88 |
| 4.7.6. | TURKEY .....                            | 4.89 |
| 4.7.7. | UKRAINE .....                           | 4.91 |
| 4.7.8. | ARMENIA .....                           | 4.92 |
| 4.8.   | Import/Export Scenarios .....           | 4.93 |
| 5.     | NEW PLANNED LINES AND SUBSTATIONS ..... | 5.1  |
| 6.     | FINDINGS .....                          | 6.1  |



## 1. INTRODUCTION

The initial meeting of the Black Sea Regional Transmission Planning Project was conducted in Sofia, Bulgaria February 18-20, 2004. At the meeting representatives of the Black Sea IPS/UPS TSOs and the Southeast Europe Black Sea TSOs, together with the US Agency for International Development, the US Energy Association and the Black Sea Regional Energy Centre, developed and agreed to a set of Project organizing principles.

The project is supporting the following goals:

- Preparation of national inputs and the development of a regional transmission model
- Power transmission system analysis
- Promotion of regional cooperation on transmission planning among Black Sea region TSOs
- Analyze the regional transmission system to identify the existing potential for electric power trade in the region
- Identify potential transmission investment projects to expand electric power trade respecting reliability requirements
- Promote the results of the analysis to a wide audience of policy and regulatory authorities
- Enhancement of the trade of electric power in the Black Sea region
- Elaboration and dissemination of the project report


A Steering Committee was established in order to advise the project. The members of Steering Committee are representatives of:

- o Black Sea Regional Energy Centre
- o Georgian State Electrosystem
- o Moldelectrica
- o National Electric Company (Bulgaria)
- o National Electric Company Ukrenergo
- o System Operator-Central Dispatch Administration of the Unified Energy System of Russia
- o Transelectrica (Romania)
- o Turkish Electricity Transmission Corporation
- o Electricity coordinating Center
- o United States Agency for International Development
- o United States Energy Association

The Steering Committee reviewed work plans, assessed objectives and plans, and review reports and recommendations on investment priorities.

Also, the Regional Working Group was formed in order to analyze possibilities of increasing electricity trade level between Black Sea region and West Europe and to identify bottle-necks and make proposition of network reinforcement. For the utilities from the Black Sea countries, which are undergoing different degrees of structural and functional change in a political environment, developing a regional transmission planning organization with the necessary tools and procedures suitable for the changing market is a significant need.





The following project objectives have been agreed to:

- (1) convert existing national transmission planning data into a common regional PSS/E format
- (2) establishing of regional transmission planning model for the Black Sea region
- (3) perform certain regional transmission planning studies as defined by the BS Steering Committee

A Regional Working Group was consisted from each participating country and Electricity Coordinating Center-EKC, which act as the regional model integrator.

A work plan and schedule was developed by the Regional Working Group to frame the activities of the project.

Based on the regional transmission network model, the Regional Working Group was elaborated a set of supply/demand and load flow scenarios and performed analysis to identify the weak points in the system and test potential reinforcements to improve the safety in operation of the power systems and provide opportunities for expanded electricity trade.

National transmission network models in PSS/E format were developed by the specialists from Black Sea countries. In the process of elaboration the national models the participants agreed the expected exchange program for target year i.e. export/import balance and load & generation forecast for 2010 was approved by all members.

The regional model integrator EKC has taken the following obligations:

- Review all collected data to check that they conform to the agreed numbering systems for areas, zones and busses
- Merge all model data in order to form one model for each regime and representing the year 2010
- Test the operation and accuracy of the regional model
- EKC is responsible for the integrated model

Turkey is responsible for integrating the Turkey and Georgia systems in PSS/E program as sub-integrator.

In Scope of Work was necessary to identify winter and summer load regimes. Regional Transmission Network Model for the year 2010 winter peak and summer light data from Bulgaria, Georgia, Moldova, Romania, Russia, Turkey and Ukraine are established.

The Black Sea Regional Transmission Planning Project (BSTP) model used more detailed generation unit representation, i.e. each unit is represented separately and included lower voltage levels and the step-up transformers. Regional Model is updated with most recent information. (P, Q, new planed: branches, generator units, compensators, phase shift transformers, shunts, etc). In the model, whole 750, 500, 400, 330, 220, 150 kV network are included.

Each country gave table for total of generation, consumption, exchange program, long term contract for importing or exporting if any, for 2010. One base scenario and some exchange scenarios will be analyzed with assumptions that the region is synchronously interconnected to UCTE. That means that one of the basic prerequisite is that the UCTE zone will be connected to the main IPS/UPS Interconnection through existing interconnectivity lines. The UCTE interconnection is modeled with adequate equivalents in the border region with Black Sea Region.

The goal of this Report is to review all necessary technical data for all Black Sea countries and the region as a whole used in regional transmission planning project.





Figure 1.1 – Interconnection lines in Black Sea Region





In Figure 1.1, scheme of interconnected network of Black Sea Countries (only border lines) is presented.


A power systems data for all analyzed countries is shown in Chapter two of this Report.

Model development, model characteristics and base case scenarios are presented in Chapter three of this Report with title REGIONAL MODEL.

In Chapter four are presented Analyses results in following subchapters: MODEL SUMMARY- Summary report for each TSO in the region, AREA INTERCHANGE - Base case exchanges and border flows for each TSO in the region, LOAD FLOWS ANALISES-report on major lines and interfaces with graphical presentation of load flows for each TSO and region as whole, NETWORK LOADING ANALISES - Report on elements that are overloaded or highly loaded and may represent network constraint, VOLTAGE PROFILE ANALISES taking into account agreed maximum and minimum voltage values for normal and emergency operation condition, CONTINGENCY ANALISES respect to (n-1) security criterion, BORDER CAPACITIES ANALISES – report on maximum transfer capabilities of the network for each country, and some market realistic scenarios.

List of NEW PLANED LINES AND SUBSTATIONS was reviewed and revised as the most probable projects for consideration, and shown in Chapter five of this Report. In that table, the projects that will be in operation in 2010 are indicated.

Overall FINDINGS are presented in final Chapter six of this document.



## **2. POWER SYSTEMS DATA**

## 2.1. BULGARIA

The power transmission network of Bulgaria consists of 750 kV, 400 kV, 220 kV and 110 kV lines. Figure 2.1 shows the map of Bulgarian network and Table 2.1 shows main data about Bulgarian transmission network.

The installed generation capacity comprises about 5400 MW of thermal units, 2880 MW of nuclear units, and 2600 MW of hydro units. Thermal power plants produce about 47 % of the total energy, and nuclear units produce about 42 % of the total energy. Hydro units cover 11 % of the total energy.

Table 2.1 – Bulgaria - network overview

| lines         |                                         | transformers  |                      |
|---------------|-----------------------------------------|---------------|----------------------|
| Voltage level | Length of the overhead lines and cables | Voltage level | Installed capacities |
| (kV)          | (km)                                    | (kV/kV)       | (MVA)                |
| 400           | 2356                                    | 400/x         | -                    |
| 220           | 2692                                    | 220/x         | -                    |
| 110           | 9562                                    | 110/x         | -                    |
| total         | 14610                                   |               | 16817                |




Figure 2.1 – Bulgaria - network map



## BULGARIA

NEK EAD is the owner of the high-voltage power transmission network in the country. Its total length is 14 610 km. The interconnection lines between the Bulgarian EPS and neighboring countries are shown in Table 2.2 and grid operation data for 2005 – in Table 2.3.

Table 2.2 – Bulgaria – interconnection lines

| Interconnection Lines between the Republic of Bulgaria and Neighbour Countries |                                              |               |                    |              |                                  |
|--------------------------------------------------------------------------------|----------------------------------------------|---------------|--------------------|--------------|----------------------------------|
| Country                                                                        | Substation                                   | Voltage<br>kV | Number<br>of lines | Length<br>km | Cross Section<br>mm <sup>2</sup> |
| Romania                                                                        | NPP Kozloduy (BG) - Tantarani (RO)           | 400           | 2                  | 115.7 (14)   | 2ACO 500                         |
| Romania                                                                        | NPP Kozloduy (BG) - Isalnita (RO)            | 220           | 1                  | 98.1 (18.6)  | ACO 500                          |
| Romania                                                                        | Varna (BG) - Isaccea (RO)                    | 400           | 1                  | 235.4 (85)   | 5ACO 300                         |
| Romania                                                                        | Dobrudja (BG) - Isaccea (RO)                 | 400           | 1                  | 230.6 (80.3) | 3ACO 400                         |
| Turkey                                                                         | TPP Maritsa East 3 (BG) - Babaeski (TR)      | 400           | 1                  | 136.6 (59.5) | 2ACO 500                         |
| Turkey                                                                         | TPP Maritsa East 3 (BG) - GPP Hamitabat (TR) | 400           | 1                  | 150 (59)     | 3ACO 400                         |
| Greece                                                                         | Blagoevgrad (BG) - Thessaloniki (GR)         | 400           | 1                  | 174.7 (72.7) | 2AC 500                          |
| Macedonia                                                                      | Petrich (BG) - Sushitsa (MK)                 | 110           | 1                  | 49.3 (21.5)  | ACO 400                          |
| Macedonia                                                                      | Skakavitsa (BG) - Kriva Palanka (MK)         | 110           | 1                  | 12.7 (5.3)   | ACO 400                          |
| Macedonia                                                                      | Chervena Mogila (BG) - Stip (MK)             | 400           | under construction |              |                                  |
| Serbia                                                                         | Sofia West (BG) - Nis (SER)                  | 400           | 1                  | 122.6 (37)   | 2ACO 500                         |
| Serbia                                                                         | Breznik (BG) - Vurla (SER)                   | 110           | 1                  | 64.1 (41.1)  | AC 185                           |
| Serbia                                                                         | Kula (BG) - Zajecar (SER)                    | 110           | 1                  | 21 (11.8)    | AC 185                           |

(...) - On the territory of the Republic of Bulgaria

Table 2.3 – Bulgaria - grid operation data for 2005

### GRID OPERATION DATA FOR 2005

|                                                         |     | Value   | date/day/hour           |
|---------------------------------------------------------|-----|---------|-------------------------|
| Absolute maximum load                                   | MW  | 6502    | 09/02/2005, Wed, 20 hrs |
| Absolute minimum load                                   | MW  | 2577    | 24/05/2005, Hol, 5 hrs  |
| Range of load fluctuation                               | MW  | 3925    |                         |
| Utilization of the absolute maximum load                | h   | 5551    |                         |
| Electricity demand per resident                         | kWh | 4580    |                         |
| Seasonal factor                                         |     | 0.60366 |                         |
| Maximum density factor -<br>workday in February         |     | 0.889   |                         |
| Minimum density factor -<br>average Saturday in October |     | 0.786   |                         |

## Planned network reinforcements

Table 2.4 shows planned network reinforcements in forthcoming period.

Table 2.4 – Bulgaria - Planned network reinforcements

| TYPE | SUBSTATION1 |          | SUBSTATION2 |           | VOLTAGE<br>LEVEL<br>kV/kV | Number<br>Of<br>Circuits<br>/units | CAPACITY |                     | MATERIAL<br>OR<br>TRANSFORMER<br>TYPE | CROSS<br>mm2 | LENGTH    |           |             | DATE OF<br>COMMISSIONING | STATUS            |
|------|-------------|----------|-------------|-----------|---------------------------|------------------------------------|----------|---------------------|---------------------------------------|--------------|-----------|-----------|-------------|--------------------------|-------------------|
|      |             |          |             |           |                           |                                    | A or MVA | limited<br>A or MVA |                                       |              | BR1<br>km | BR2<br>km | TOTAL<br>km |                          |                   |
| 1    | 2           | 3        | 2           | 3         | 4                         | 5                                  | 6        | 7                   | 8                                     | 9            | 10        | 11        | 12          | 13                       | 14                |
| OHL  | BG          | C.Mogila | MK          | Stip      | 400                       | 1                                  | 1890     | -                   | ACSR                                  | 2X500        | 80        | 70        | 150         | 2008                     | construction      |
| OHL  | BG          | M.East   | GR          | Nea Santa | 400                       | 1                                  | 1890     | -                   | ACSR                                  | 2X500        | -         | -         | -           | -                        | Feasibility study |
| OHL  | BG          | Zlatitsa | BG          | Plovdiv   | 400                       | 1                                  | 1890     | -                   | ACSR                                  | 2X500        | -         | -         | 140         | 2007                     | Feasibility study |

- 1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)
- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)

Table 2.5 – Bulgaria - Planned new generation units

| TYPE | SUBSTATION1 |        | VOLTAGE<br>LEVEL |     | CAPACITY |        | DATE OF<br>COMMISSIONING | STATUS       |
|------|-------------|--------|------------------|-----|----------|--------|--------------------------|--------------|
|      |             |        | kV               | kV  | MW       | MVA    | year                     |              |
| 1    | 2           | 3      | 4                | 5   | 6        | 7      | 8                        | 9            |
| NPP  | BG          | Belene | ?                | 400 | 2x1000   | 2x1111 | 2012                     | construction |

- 1 Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)
- 2 Country
- 3 Substation name
- 4 Generator voltage level
- 5 Network voltage level
- 6 Installed active power
- 7 Installed apparent power
- 8 Date of commissioning (estimate)
- 9 Status of the project (Idea, Feasibility study, Construction...)



## 2.2. GEORGIA

Figure 2.2 and Figure 2.3 shows the transmission system of Georgia. As it can be seen, 500 kV East-West line represents a backbone of Georgia's high voltage network. Together with 220 kV lines in parallel, 110kV and 35 kV in radial (spurs) operation, it forms Georgian transmission system.

Figure 2.2 – Georgia - network map




Figure 2.3 – Georgia - single line diagram






Table 2.6 shows main characteristics of the Georgian network.

Table 2.6 – Georgia - network overview

| lines         |                                         | transformers  |                      |
|---------------|-----------------------------------------|---------------|----------------------|
| Voltage level | Length of the overhead lines and cables | Voltage level | Installed capacities |
| (kV)          | (km)                                    | (kV/kV)       | (MVA)                |
| 500           | 576                                     | 500/220       | 2800                 |
| 330           | 21                                      | 330/x         | 400                  |
| 220           | 1690                                    | 220/x         | -                    |
| 110           | 3911                                    | 110/x         | -                    |
| total         | 6198                                    |               | 3200                 |

### Planned network reinforcements

At present, official and documented system expansion plan does not exist, but there are general guidelines and ideas how to reinforce Georgian transmission network. The main guideline is to reinforce Georgia-Russia-Azerbaijan loop, and close 500 kV loop internally and to build new connection to Turkey in order to increase transfer capacity.



Figure 2.4 – Georgia – Network reinforcements

**Table 2.7 – Georgia - Planned network reinforcements**

| TYPE | SUBSTATION1 |            | SUBSTATION2 |                  | VOLTAGE<br>LEVEL<br>kV/kV | number<br>of<br>circuits<br>/units | CAPACITY    |                     | MATERIAL<br>OR<br>TRANSFORMER<br>TYPE | CROSSECTION<br>mm2 | LENGTH    |           |             | DATE OF<br>COMMISSION | STATUS            |
|------|-------------|------------|-------------|------------------|---------------------------|------------------------------------|-------------|---------------------|---------------------------------------|--------------------|-----------|-----------|-------------|-----------------------|-------------------|
|      |             |            |             |                  |                           |                                    | A or<br>MVA | limited<br>A or MVA |                                       |                    | BR1<br>km | BR2<br>km | TOTAL<br>km |                       |                   |
| 1    | 2           | 3          | 2           | 3                | 4                         | 5                                  | 6           | 7                   | 8                                     | 9                  | 10        | 11        | 12          | 13                    | 14                |
| SS   | GE          | Qsani      |             |                  | 500/400                   | 1                                  | 3X267       |                     | LTC                                   |                    |           |           |             | 2009                  | Feasibility study |
| OHL  | GE          | Qsani      | AM          | TPP Hrazdan      | 400                       | 1                                  | 1100        | 1400                | ACSR                                  | 2x300              | 80        | 90        | 170         | 2009                  | Feasibility study |
| OHL  | GE          | Mukharani  | AZ          | AZ TPP           | 330                       | 1                                  |             |                     |                                       |                    |           |           | 283         |                       |                   |
| SS   | GE          | Akhhaltske |             |                  | 500/400                   | 1                                  |             |                     |                                       |                    |           |           |             |                       |                   |
| BB   | GE          | Akhhaltske |             |                  | 400                       | 1                                  |             |                     |                                       |                    |           |           |             |                       |                   |
| OHL  | GE          | Akhhaltske |             | Marneuli         | 500                       | 1                                  |             |                     |                                       |                    |           |           |             |                       |                   |
| OHL  | GE          | Marneuli   |             | Gardabani        | 500                       | 1                                  |             |                     |                                       |                    |           |           |             |                       |                   |
| OHL  | GE          | Akhhaltske |             | Menji            | 500                       | 1                                  |             |                     |                                       |                    |           |           |             |                       |                   |
| OHL  | GE          | Menji      |             | Kudoni           | 500                       | 1                                  |             |                     |                                       |                    |           |           |             |                       |                   |
| OHL  | GE          | Akhhaltske |             | Zestaponi        | 500                       | 1                                  |             |                     |                                       |                    |           |           | 71          |                       |                   |
| OHL  | GE          | Akhhaltske | TR          | Borcka           | 400                       | 1                                  |             |                     |                                       |                    |           |           | 130         |                       |                   |
| OHL  | GE          | Gardabani  | AR          | Atarbeksan       | 330                       | 1                                  |             |                     |                                       |                    |           |           |             |                       |                   |
| OHL  | GE          | Enguri     | RU          | Centralna(Sochi) | 500                       | 1                                  |             |                     |                                       |                    |           |           | 450         |                       |                   |

- 1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)
- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)

### 2.3. MOLDOVA

Backbone of Moldovan network is 330 kV system that crosses whole country from north to south. Together with 110 kV system that operates in parallel with 330 kV network it forms the national grid. In Figure 2.5, transmission grid of Moldova is presented.

Figure 2.5 – Moldova - network map




Table 2.8 – Moldova – overview of tie-lines

Table 2.9 shows main characteristics of the Moldovan network.

Table 2.9 – Moldova - network overview

| lines         |                                         | transformers  |                      |
|---------------|-----------------------------------------|---------------|----------------------|
| Voltage level | Length of the overhead lines and cables | Voltage level | Installed capacities |
| (kV)          | (km)                                    | (kV/kV)       | (MVA)                |
| 400           | 214                                     | 400/330       | 500                  |
| 330           | 532.4                                   | 330/x         | 2525                 |
| 110           | 5231.1                                  | 110/x         | 3687                 |
| total         | 5977.5                                  |               | 6712                 |

At present, Moldavia operates in parallel operation with Ukrainian main grid and it is highly integrated to it, while 110 kV connections to Romania are operated only in island mode, and 400 kV line to Bulgaria is rerouted to Romania and usually out of operation. Due to configuration of the high voltage network, Ukraine has large influence on system operation of Moldavian network.

### ***Planned network reinforcements***

Moldavia has not so ambitious network development plan. The main issues are rehabilitation of present network, and building of two new interconnection lines (Table 2.10).

Table 2.10 – Moldova - Planned network reinforcements

| TYPE | SUBSTATION1 |             | SUBSTATION2 |                 | VOLTAGE<br>LEVEL | Number<br>Of<br>Circuits<br>/units | CAPACITY |     | MATERIAL<br>OR<br>TRANSFORMER<br>TYPE | CROSSECTION | LENGTH |       |       | DATE OF<br>COMMISSIONING |
|------|-------------|-------------|-------------|-----------------|------------------|------------------------------------|----------|-----|---------------------------------------|-------------|--------|-------|-------|--------------------------|
|      |             |             |             |                 |                  |                                    | limited  | BR1 |                                       |             | BR2    | TOTAL |       |                          |
|      |             |             |             |                 |                  |                                    |          |     |                                       |             |        |       | kV/kV |                          |
| 1    | 2           | 3           | 2           | 3               | 4                | 5                                  | 6        | 7   | 8                                     | 9           | 10     | 11    | 12    | 13                       |
| SS   | MD          | Balti       |             |                 | 400/330          | 1                                  |          |     |                                       |             |        |       |       |                          |
| OHL  | MD          | Balti       | RO          | Suceava         | 400              | 1                                  |          |     |                                       |             |        |       |       |                          |
| SS   | MD          | Chisinau    |             |                 | 400/330          | 1                                  |          |     |                                       |             |        |       |       |                          |
| OHL  | MD          | Chisinau    | RO          | Iasi            | 400              | 1                                  |          |     |                                       |             |        |       |       |                          |
| OHL  | MD          | Balti       | UA          | Dnestrovska HPP | 330              | 1                                  |          |     |                                       |             |        |       |       |                          |
| OHL  | MD          | Balti       | MD          | Straseni        | 330              | 1                                  |          |     |                                       |             |        |       |       |                          |
| OHL  | MD          | Straseni    | MD          | Chisinau        | 330              | 1                                  |          |     |                                       |             |        |       |       |                          |
| OHL  | MD          | Balti       | MD          | Ribnita         | 330              | 1                                  |          |     |                                       |             |        |       |       |                          |
| SS   | MD          | Balti       |             |                 | 400/330          | 1                                  |          |     | IPC                                   |             |        |       |       |                          |
| SS   | MD          | Moldovskava |             |                 | 400/330          | 1                                  |          |     | IPC                                   |             |        |       |       |                          |

- 1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)
- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)

Table 2.11 – Moldova - Planned new generation units

| TYPE | SUBSTATION1 |            | VOLTAGE LEVEL |     | CAPACITY |       | DATE OF COMMISSIONING | STATUS | COMMENT                                       |
|------|-------------|------------|---------------|-----|----------|-------|-----------------------|--------|-----------------------------------------------|
|      |             |            | kV            | kV  | MW       | MVA   | year                  |        |                                               |
| 1    | 2           | 3          | 4             | 5   | 6        | 7     | 8                     | 9      | 10                                            |
| CCHP | MD          | Balti      | 15.75         | 400 | 3x150    | 3x176 | 2010                  |        | 2x150MW gas,1x150MW steam,300MW belongs to RO |
| CCHP | MD          | Vulkanesti | 15.75         | 400 | 3x150    | 3x176 | 2010                  |        | 2x150MW gas,1x150MW steam,300MW belongs to RO |

1 Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHPP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)

2 Country

3 Substation name

4 Generator voltage level

5 Network voltage level

6 Installed active power

7 Installed apparent power

8 Date of commissioning (estimate)

9 Status of the project (Idea, Feasibility study, Construction...)




## 2.4. ROMANIA

The transmission network of Romania is quite strong with a mesh of 400, 220 and 110 kV lines. From the regional system point of view, the Romanian transmission system has a strong configuration with multiple internal loops at 400 kV. There are however few interconnections with surrounding countries. Main characteristics of Romanian network are presented in Table 2.12 below.

Table 2.12 – Romania - network overview

| lines         |                                         | transformers  |                      |
|---------------|-----------------------------------------|---------------|----------------------|
| Voltage level | Length of the overhead lines and cables | Voltage level | Installed capacities |
| (kV)          | (km)                                    | (kV/kV)       | (MVA)                |
| 750           | 154.5                                   | 750/400       | 2500                 |
| 400           | 4599                                    | 400/x         | 13000                |
| 220           | 4892.5                                  | 220/x         | 18990                |
| 110           | 6473.5                                  | 110/x         | 14580                |
| total         | 16119.5                                 |               | 49070                |

Figure 2.6 – Romania - network map





# ROMANIA

## Planned network reinforcements


The present development plan is to increase border lines capacities by diverting Dobrudja (Bulgaria)-Vulkanesti (Moldova) line to Isaccea (Romania) substation, rehabilitation of existing 750 kV line Isaccea (Romania)-Pivdenoukrainskaya (Ukraine) with installation of Back-to-Back system, building 400 kV lines Oradea (Romania) - Becescaba (Hungary) and Suceava (Romania)-Balti (Moldova) and to upgrade parts of Romanian network from 220 kV to 400 kV. These lines are already built for 400 kV but presently operated at 220 kV level. The construction of the new 400 kV lines will increase transmission and reserve capacity of the network.

Table 2.13 – Romania – Planned network reinforcements

| TYPE | SUBSTATION1 |                    | SUBSTATION2 |                   | VOLTAGE<br>LEVEL | Number<br>Of<br>Circuits<br>/units | CAPACITY    |                        | MATERIAL<br>OR<br>TRANSFORM<br>ER<br>TYPE | CROSS | LENGTH |     |           | DATE OF<br>COMMISSI<br>ON | STATUS | COMMENT              |
|------|-------------|--------------------|-------------|-------------------|------------------|------------------------------------|-------------|------------------------|-------------------------------------------|-------|--------|-----|-----------|---------------------------|--------|----------------------|
|      |             |                    |             |                   |                  |                                    | A or<br>MVA | limited<br>A or<br>MVA |                                           |       | BR1    | BR2 | TOT<br>AL |                           |        |                      |
| 1    | 2           | 3                  | 2           | 3                 | 4                | 5                                  | 6           | 7                      | 8                                         | 9     | 10     | 11  | 12        | 13                        | 14     | 15                   |
| SS   | RO          | Portile de Fier II |             |                   | 220/110          | 2                                  | 2*200       |                        | 2 windings                                |       |        |     |           | 2008                      |        |                      |
| OHL  | RO          | Portile de Fier II | RO          | Cetate            | 220              | 1                                  | 875         |                        | Ol-Al                                     | 450   |        |     | 80        | 2008                      |        |                      |
| OHL  | RO          | Portile de Fier II | RO          | Portile de Fier I | 220              | 1                                  | 875         |                        | Ol-Al                                     | 450   |        |     | 71        | 2008                      |        |                      |
| CSS  | RO          | Nadab              |             | -                 | 400              |                                    |             |                        |                                           |       |        |     |           |                           |        |                      |
| OHL  | RO          | Oradea             | RO          | Nadab             | 400              | 1                                  | 1997        |                        | Ol-Al                                     | 3*300 |        |     | 75        |                           |        |                      |
| OHL  | RO          | Arad               | RO          | Nadab             | 400              | 1                                  | 1997        |                        | Ol-Al                                     | 3*300 |        |     | 35        |                           |        |                      |
| OHL  | RO          | Nadab              | HU          | Bekescsaba Border | 400              | 1                                  | 1750        |                        | Ol-Al                                     | 3*300 |        |     | 23        | 2008                      |        |                      |
| OHL  | HU          | Bekescsaba Border  | HU          | Bekescsaba        | 400              | 1                                  | 1750        |                        | Ol-Al                                     | 2*500 |        |     | 37        | 2010                      |        |                      |
| SS   | RO          | Suceava            |             |                   | 400/110          | 2                                  | 250         |                        | 2 windings                                |       |        |     |           | 2010                      |        |                      |
| OHL  | RO          | Suceava            | MD          | Balti             | 400              | 1                                  | 1750        |                        | Ol-Al                                     | 3*300 |        |     | 95        | 2014                      |        |                      |
| SS   | RO          | Bacau              |             |                   | 400/220          | 1                                  | 400         |                        | 2 windings                                |       |        |     |           | 2014                      |        |                      |
| SS   | RO          | Roman              |             |                   | 400/220          | 1                                  | 400         |                        | 2 windings                                |       |        |     |           | 2014                      |        |                      |
| OHL  | RO          | Suceava            | RO          | Roman             | 400              | 1                                  | 1700        |                        | Ol-Al                                     | 3*300 |        |     | 100       | 2014                      |        | upgrade from 220 kV  |
| OHL  | RO          | Roman              | RO          | Bacau             | 400              | 1                                  | 1700        |                        | Ol-Al                                     | 3*300 |        |     | 58.8      | 2014                      |        | upgrade from 220 kV  |
| OHL  | RO          | Bacau              | RO          | Gutinas           | 400              | 1                                  | 1700        |                        | Ol-Al                                     | 3*300 |        |     | 55.3      | 2014                      |        | upgrade from 220 kV  |
| SS   | RO          | Iasi               |             |                   | 400/220          |                                    |             |                        |                                           |       |        |     |           | 2010                      |        |                      |
| OHL  | RO          | Iasi               | MD          | Chisinau          | 400              | 1                                  |             |                        |                                           |       |        |     |           | 2010                      |        |                      |
| SS   | RO          | Resita             |             |                   | 400/220          | 1                                  | 400         |                        | 2 windings                                |       |        |     |           | 2014                      |        |                      |
| SS   | RO          | Resita             |             |                   | 400/110          | 1                                  | 250         |                        | 2 windings                                |       |        |     |           | 2014                      |        |                      |
| OHL  | RO          | Portile de Fier I  | RO          | Resita            | 400              | 1                                  | 1997        |                        | Ol-Al                                     | 3*300 |        |     | 117       | 2014                      |        | new 400kV OHL        |
| SS   | RO          | Timisoara          |             |                   | 400/220          | 1                                  | 400         |                        | 2 windings                                |       |        |     |           | 2014                      |        |                      |
| OHL  | RO          | Timisoara          | RO          | Resita            | 400              | 1                                  | 1997        |                        | Ol-Al                                     | 3*300 |        |     | 73        | 2014                      |        | upgrade from 220 kV  |
| OHL  | RO          | Timisoara          | RO          | Arad              | 400              | 1                                  | 1997        |                        | Ol-Al                                     | 3*300 |        |     | 55        | 2014                      |        | upgrade from 220 kV  |
| OHL  | RO          | Timisoara          | CS          | Vrsac             | 400              | 1                                  | 1750        |                        | Ol-Al                                     | 3*300 |        |     | 100       | 2014                      |        |                      |
| DC   | RO          | Constanta          |             |                   | 400              |                                    | 600         |                        |                                           |       |        |     |           | ?                         |        | DC Converter station |
| SK   | RO          | Constanta          | TR          | Pasakoy           | 400              | 1                                  | 600         |                        |                                           |       | 200    | 200 | 400       | ?                         |        |                      |
| OHL  | RO          | Constanta          | RO          | Medgidia          | 400              | 1                                  | 1800        |                        | Ol-Al                                     | 3*300 |        |     | 21        | 2010-2014                 |        | new 400kV OHL        |

1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)





## ROMANIA

- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)

Table 2.14 – Romania – Planned new generation units

| TYPE | SUBSTATION1 |           | VOLTAGE LEVEL |     | CAPACITY |     | DATE OF COMMISSIONING | STATUS       | COMMENT |
|------|-------------|-----------|---------------|-----|----------|-----|-----------------------|--------------|---------|
|      |             |           | kV            | kV  | MW       | MVA | year                  |              |         |
| 1    | 2           | 3         | 4             | 5   | 6        | 7   | 8                     | 9            | 10      |
| NPP  | RO          | Cernavoda | 24            | 400 | 2x700    | 740 | 2010- 2014            | construction |         |

- 1 Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHPP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)
- 2 Country
- 3 Substation name
- 4 Generator voltage level
- 5 Network voltage level
- 6 Installed active power
- 7 Installed apparent power
- 8 Date of commissioning (estimate)
- 9 Status of the project (Idea, Feasibility study, Construction...)



RUSSIA

## 2.5. RUSSIA

The power industry in Russia developed stepwise, by incorporating regional power systems, working in parallel, and forming interregional electric power pools, which merged to form a single Power Grid, operated from center in Moscow.



Figure 2.7 – Russia – network map (western part)



## RUSSIA

Table 2.15 – Russia - network overview

| lines         |                                         | transformers  |                      |
|---------------|-----------------------------------------|---------------|----------------------|
| Voltage level | Length of the overhead lines and cables | Voltage level | Installed capacities |
| (kV)          | (km)                                    | (kV/kV)       | (MVA)                |
| 750           | 3074                                    | 750/x         | 16089                |
| 500           | 38852                                   | 500/x         | 123996               |
| 330           | 10612                                   | 330/x         | 32140                |
| 220           | 99936                                   | 220/x         | 203674               |
| 110           | 298668                                  | 110/x         | 302251               |
| total         | 451142                                  |               | 678150               |




Figure 2.8 – Russia – network map (modeled part in Black Sea regional model)

Only part of Russian network is modeled, the one that has largest influence on the region. Also, central and northern part of Russia are modeled in detail to analyze eventual influence of large exports to Western Europe over Ukraine network.



RUSSIA

## Planned network reinforcements

In following Table 2.16 planned network reinforcements for Russian system are presented, but only for region of interest (Northern-Caucasus region).

Table 2.16 – Russia – Network reinforcements (Northern Caucasus region)

| TYPE | SUBSTATION1 |               | SUBSTATION2 |               | VOLTAGE<br>LEVEL | number<br>of<br>circuits<br>/units | CAPACITY    |                        | MATERIAL<br>OR<br>TRANSFORMER<br>TYPE | CROSS | LENGTH |     |       | DATE OF<br>COMMISSION | STATUS | COMMENT                       |
|------|-------------|---------------|-------------|---------------|------------------|------------------------------------|-------------|------------------------|---------------------------------------|-------|--------|-----|-------|-----------------------|--------|-------------------------------|
|      |             |               |             |               | kV/kV            |                                    | A or<br>MVA | limited<br>A or<br>MVA |                                       |       | BR1    | BR2 | TOTAL |                       |        |                               |
| 1    | 2           | 3             | 2           | 3             | 4                | 5                                  | 6           | 7                      | 8                                     | 9     | 10     | 11  | 12    | 13                    | 14     | 15                            |
| OHL  | RU          | Sotchi        | GE          | Enguri        | 500              | 1                                  |             |                        |                                       |       |        |     | 450   |                       |        |                               |
| SS   | RU          | Rostov        |             |               | 500              | 2                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Rostov        |             | Sahti 30      | 500              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Rostov        |             | Frolovskaya   | 500              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Rostov        |             | R 20          | 220              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| SS   | RU          | Krimskaya II  |             |               | 500              | 2                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Krimskaya II  |             | Tihoreck      | 500              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| SS   | RU          | Senaya        |             | Senaya        | 220              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Krimskaya II  |             | Senaya        | 220              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Krimskaya II  |             | Slavyansk     | 220              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Slavyansk     |             | Senaya        | 220              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| SS   | RU          | Nevinomysk    |             |               | 500              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Nevinomysk    |             | Volgodonskaya | 500              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| SS   | RU          | Mozdok        |             |               | 500              | 2                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Nevinomysk    |             | Mozdok        | 500              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| SS   | RU          | Alagir        |             |               | 330              | 2                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Nalcik        |             | Alagir        | 330              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | V2            |             | Alagir        | 330              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| SS   | RU          | Kizljär       |             |               | 330              | 2                                  |             |                        |                                       |       |        |     |       |                       |        | on 330 kV Budenovsk-Chirjurt  |
| SS   | RU          | Grozniy       |             |               | 330              | 2                                  |             |                        |                                       |       |        |     |       |                       |        | on 330 kV V2-Chirjurt         |
| SS   | RU          | Artem         |             |               | 330              | 2                                  |             |                        |                                       |       |        |     |       |                       |        | on 330 kV Mahachkala-Chirjurt |
| OHL  | RU          | Mozdok        |             | Artem         | 330              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | HP Irganskaya |             | Artem         | 330              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Derbent       |             | Artem         | 330              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |
| OHL  | RU          | Derbent       | AZ          | Apsheron      | 330              | 1                                  |             |                        |                                       |       |        |     |       |                       |        |                               |

1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)

2 Country (ISO code)

3 Substation name

4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)

5 number of circuits/units

6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA

7 Conventional transmission capacity limited by transformers or substations

8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)



RUSSIA

- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)

## Alternative evolution of the Power System of Northern Caucasus




Figure 2.9 – Russia – Network reinforcements (Northern Caucasus region)




## RUSSIA

Table 2.17 – Russia - New production units (Northern Caucasus region)

| TYPE | SUBSTATION1 |                | VOLTAGE LEVEL |     | CAPACITY |      | DATE OF COMMISSIONING | STATUS | COMMENT |
|------|-------------|----------------|---------------|-----|----------|------|-----------------------|--------|---------|
|      |             |                | kV            | kV  | MW       | MVA  | year                  |        |         |
| 1    | 2           | 3              | 4             | 5   | 6        | 7    | 8                     | 9      | 10      |
| HPP  | RU          | Zaramagskaya   |               | 330 |          |      | 2010                  |        |         |
| HPP  | RU          | Cherkeskaya II |               | 330 |          |      | 2010                  |        |         |
| NPP  | RU          | Volgodonskaya  | 20            | 500 | 1000     | 1111 | 2010                  |        | unit 2  |

- 1 Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)
- 2 Country
- 3 Substation name
- 4 Generator voltage level
- 5 Network voltage level
- 6 Installed active power
- 7 Installed apparent power
- 8 Date of commissioning (estimate)
- 9 Status of the project (Idea, Feasibility study, Construction...)



TURKEY

## 2.6. TURKEY

The Turkish Power Grid consists of the lines of 400, 220, 150, 66 kV, the Table 2.15 shows total length of transmission lines by voltage levels. Network of the 400 kV system is shown in Figure 2.10. Table 2.18 shows total length of transmission lines by voltage levels.

The power system of Turkey has quality of service and reliability in keeping with the west European standards. Hydro potential and lignite are important primary energy resources of the country. Large loads are concentrated in the areas of Istanbul, İzmir and Ankara. Most of the hydro resources and a large lignite field are located in Eastern Turkey, so power has to be transmitted across the country via the 400 kV lines.

Table 2.18 – Turkey – network overview

| lines         |                                         | transformers  |                      |
|---------------|-----------------------------------------|---------------|----------------------|
| Voltage level | Length of the overhead lines and cables | Voltage level | Installed capacities |
| (kV)          | (km)                                    | (kV/kV)       | (MVA)                |
| 400           | 13 958                                  | 400/x         | 24240                |
| 220           | 84.6                                    | 220/x         | 300                  |
| 150           | 31 522                                  | 154/x         | 46979                |
| 66            | 718.9                                   | 66/x          | 678                  |
| total         | 46 283.5                                |               | 72197                |







Figure 2.10 – Turkey – Map of 400 kV transmission network



TURKEY

---


### ***Planned network reinforcements***

The geographical location of primary energy resources of Turkey has brought to the construction of an important number of HPPs and of two lignite fired TPPs in the East of the country. On the other hand, large lignite fired TPPs and most of the natural gas combined cycle thermal power plants (NGCCTPPs) are located in the west of the country.

Location of generation and the long distances involved are liable to challenge the transmission grid during operation with the maximum hydroelectric dispatch, when most of the power produced by the large HPPs in the East has to be transferred to the North-West regions and also partly to the South-West regions that are the areas where the energy consumption is higher. Consequently, the planned lines connecting the Western and the Eastern areas of country has necessary power carrying capacity and stability margins.

In the eastern Black Sea region, the group of large HPPs planned for commissioning in 2005-2007, has an aggregate capacity of 2010 MW, they are Borçka HPP (300 MW), Deriner HPP (670 MW), Muratlı HPP (115 MW), Artvin HPP (332 MW) and Yusufeli HPP (540 MW). Borçka and Muratlı HPPs have been already commissioned recently.


The construction of the new HPPs allowed the extension of the 400 kV grid close to the border with Georgia and Armenia. Also a 400/154 kV, 300 MVA autotransformer bank has been installed recently at Borçka thereby reinforcing the power supply of the Eastern Black Sea Region of Turkey.



# TURKEY

Table 2.19 – Turkey – Planned network reinforcements

| TYPE | SUBSTATION1 |                    | SUBSTATION2 |                | VOLTAGE<br>LEVEL<br>kV/kV | Number<br>of<br>circuits<br>/units | CAPACITY    |                     | MATERIAL<br>OR<br>TRANSFORMER<br>TYPE | CROSS<br>mm2 | LENGTH    |           |             | DATE OF<br>COMMISSION | STATUS       | COMMENT                            |
|------|-------------|--------------------|-------------|----------------|---------------------------|------------------------------------|-------------|---------------------|---------------------------------------|--------------|-----------|-----------|-------------|-----------------------|--------------|------------------------------------|
|      |             |                    |             |                |                           |                                    | A or<br>MVA | limited<br>A or MVA |                                       |              | BR1<br>km | BR2<br>km | TOTAL<br>km |                       |              |                                    |
| 1    | 2           | 3                  | 2           | 3              | 4                         | 5                                  | 6           | 7                   | 8                                     | 9            | 10        | 11        | 12          | 13                    | 14           | 15                                 |
| SS   | TR          | Afyon              | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Agri               | -           | -              | 400/150                   |                                    | 250+150     |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| OHL  | TR          | Aliaga             |             | Manisa         | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx1272      |           |           |             | 2006                  | completed    |                                    |
| SS   | TR          | Baglum             | -           | -              | 400/150                   |                                    | 2x250       |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Beykoz GIS         | -           | -              | 400/33                    |                                    | 2x125       |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Davutpaşa GIS      | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Davutpaşa GIS      | -           | -              | 400/33                    |                                    | 125         |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Erzurum            | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2006                  | construction | capacity addition                  |
| OHL  | TR          | Erzurum            |             | Horasan        | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Germencik          | -           | -              | 400/150                   |                                    | 2x250       |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Hilvan             | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Hilvan             | -           | -              | 400/33                    |                                    | 125         |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| OHL  | TR          | Horasan            |             | Agri           | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | construction |                                    |
| OHL  | TR          | HPP Borçka-Deriner |             | HPP Yusufeli   | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | construction |                                    |
| OHL  | TR          | HPP Oymapinar      |             | Varsak         | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | construction | second line                        |
| OHL  | TR          | HPP Yusufeli       |             | Erzurum        | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | İkiteli            | -           | -              | 400/33                    |                                    | 2x125       |                     |                                       |              |           |           |             | 2005                  | completed    | capacity addition                  |
| K    | TR          | İkitelli           |             | Davutpasa      | 400                       | 1                                  |             |                     |                                       | 2000 mm2     |           |           |             | 2006                  | completed    |                                    |
| OHL  | TR          | İsıklar            |             | Manisa         | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx1272      |           |           |             | 2006                  | completed    |                                    |
| OHL  | TR          | İyidere            |             | HPP Borçka     | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx1272      |           |           |             | 2006                  | completed    |                                    |
| OHL  | TR          | Karabiga-Çan       |             | TPP Soma       | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | construction |                                    |
| OHL  | TR          | Karakya-Ataturk    |             | Hilvan         | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | completed    |                                    |
| SS   | TR          | Manisa             | -           | -              | 400/150                   |                                    | 2x250       |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| OHL  | TR          | Tirebolu           |             | İyidere        | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx1272      |           |           |             | 2006                  | completed    |                                    |
| SS   | TR          | TPP Iskenderun     | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2006                  | construction | capacity addition, autotransformer |
| OHL  | TR          | TPP Unimar         |             | Babaeski       | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | construction |                                    |
| OHL  | TR          | Yeniköy-Uzundere   |             | Aydin          | 400                       | 2                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2006                  | completed    |                                    |
| K    | TR          | Yildiztepe         |             | Davutpasa      | 400                       | 2                                  |             |                     |                                       | 2000 mm2     |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Zekeriyaakoy GIS   | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Zekeriyaakoy GIS   | -           | -              | 400/33                    |                                    | 125         |                     |                                       |              |           |           |             | 2006                  | construction |                                    |
| SS   | TR          | Hatay              | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2007                  | construction |                                    |
| SS   | TR          | Hatay              | -           | -              | 400/33                    |                                    | 125         |                     |                                       |              |           |           |             | 2007                  | construction |                                    |
| OHL  | TR          | Hatay              |             | Erzin          | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2007                  | construction |                                    |
| SS   | TR          | Mersin             | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | 2007                  | construction |                                    |
| SS   | TR          | Mersin             | -           | -              | 400/33                    |                                    | 125         |                     |                                       |              |           |           |             | 2007                  | construction |                                    |
| OHL  | TR          | Mersin             |             | TPP Iskenderun | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2007                  | construction |                                    |
| OHL  | TR          | Seydişehir         |             | HPP Oymapinar  | 400                       | 1                                  |             |                     | ACSR                                  | 3Bx954       |           |           |             | 2007                  | construction |                                    |
| SS   | TR          | Umraniye           | -           | -              | 400/150                   |                                    | 2x250       |                     |                                       |              |           |           |             | 2007                  | construction | Transformer change                 |
| SS   | TR          | Borçka             | -           | -              | 400/150                   |                                    | 250         |                     |                                       |              |           |           |             | ?                     |              |                                    |
| OHL  | TR          | Borcka             | GE          | Akhalske       | 400                       | 1                                  |             |                     |                                       |              |           |           | 130         |                       |              |                                    |



## TURKEY

|     |    |          |    |           |     |   |        |  |      |        |     |     |     |      |         |                      |
|-----|----|----------|----|-----------|-----|---|--------|--|------|--------|-----|-----|-----|------|---------|----------------------|
| OHL | TR | Babaeski | GR | N.Santa   | 400 | 1 |        |  | ACSR | 3Bx954 | 64  |     |     | 2010 | F.study |                      |
| DC  | TR | Pasakoy  |    |           | 400 |   | 600 MW |  |      |        |     |     |     |      | Idea    | DC Converter station |
| SK  | TR | Pasakoy  | RO | Constanta | 400 | 1 | 600 MW |  |      |        | 200 | 200 | 400 |      | Idea    |                      |

- 1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)
- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)

Table 2.20 – Turkey – Planned generation units

| TYPE | SUBSTATION1 |         | VOLTAGE LEVEL |     | CAPACITY |     | DATE OF COMMISSIONING | STATUS | COMMENT |
|------|-------------|---------|---------------|-----|----------|-----|-----------------------|--------|---------|
|      |             |         | kV            | kV  | MW       | MVA | year                  |        |         |
| 1    | 2           | 3       | 4             | 5   | 6        | 7   | 8                     | 9      | 10      |
| HPP  | TR          | Ermenek |               | 400 | 320      |     | -2010                 |        |         |
| HPP  | TR          | Kargı   |               | 400 | 214      |     | -2010                 |        |         |
| HPP  | TR          | Borçka  |               | 400 | 300      |     | -2010                 |        |         |
| HPP  | TR          | Deriner |               | 400 | 670      |     | -2010                 |        |         |

- 1 Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)
- 2 Country
- 3 Substation name
- 4 Generator voltage level
- 5 Network voltage level
- 6 Installed active power
- 7 Installed apparent power
- 8 Date of commissioning (estimate)
- 9 Status of the project (Idea, Feasibility study, Construction...)



## 2.7. UKRAINE

Ukraine's transmission system consists of an 800 kV DC line; a basic infrastructure of 750 kV, single circuit AC system that overlay an extensive 330 kV (single and double circuit) network, feeding into 220 kV and 110 kV systems, but also 500 kV and 400 kV AC systems in some parts of the country. Figure 2.11 shows transmission network of Ukraine and Table 2.21 shows overview of Ukrainian transmission network.




Figure 2.11 – Ukraine – network map

Table 2.21 – Ukraine – Overview of electricity transmission and distribution lines in km, year 2002

|                    | <b>Transmission</b> | <b>Distribution</b> | <b>Total</b>      |
|--------------------|---------------------|---------------------|-------------------|
|                    | <b>110-750 kV</b>   | <b>0.4-35 kV</b>    | <b>0.4-750 kV</b> |
| Overhead Lines     | 70,302              | 821,053             | 891,355           |
| Underground Cables | 51.5                | 67,275              | 67,326.5          |
| <b>Total</b>       | <b>70,353.5</b>     | <b>888,328</b>      | <b>958,681.5</b>  |

Source: Ministry of Fuel and Energy

At present, southwestern part of Ukrainian system called Burstyn island, including Burstinskaya TPP, part of 220 kV network connected to it and the Mukachevo substation, is separated from the main Ukrainian system and operates in synchronous and parallel mode with UCTE main grid. This was done in order to realize export from Ukraine to Western Europe.



## Planned network reinforcements

High voltage transmission grid needed to increase the supply of electricity to power deficient regions of the country, optimize system interflows and increase the reliability of supply and to connect to European markets.

Table 2.22 – Ukraine – Network reinforcements till 2010

| TYPE | SUBSTATION1 |                    | SUBSTATION2 |                      | VOLTAGE<br>LEVEL<br><br>kV/kV | number<br>of<br>circuits<br>/units | CAPACITY |                        | MATERIAL<br>OR<br>TRANSFOR<br>MER<br>TYPE | CROSS<br><br>mm2 | LENGTH |     |       | DATE OF<br>COMMISSI<br>ONING | STATUS            | COMMENT                                              |
|------|-------------|--------------------|-------------|----------------------|-------------------------------|------------------------------------|----------|------------------------|-------------------------------------------|------------------|--------|-----|-------|------------------------------|-------------------|------------------------------------------------------|
|      |             |                    |             |                      |                               |                                    | A or MVA | limited<br>A or<br>MVA |                                           |                  | BR1    | BR2 | TOTAL |                              |                   |                                                      |
| 1    | 2           | 3                  | 2           | 3                    | 4                             | 5                                  | 6        | 7                      | 8                                         | 9                | 10     | 11  | 12    | 13                           | 14                | 15                                                   |
| OHL  | UA          | Pivdenoukrainskaya | RO          | Isaccea              | 750                           | 1                                  | 4000 A   | -                      | ACSR                                      | 400*5            | 406    | 3   | 409   | 2015                         | Feasibility study | Restoration. Voltage level to be defined             |
| SS   | UA          | Kyivska            |             |                      | 750/330                       | 1                                  | 1000 MVA | -                      | PST                                       | -                | -      | -   | -     | 2008                         | Construction      |                                                      |
| OHL  | UA          | Rivnenska NPP      | UA          | Kyivska              | 750                           | 1                                  | 4000 A   | -                      | ACSR                                      | 400*5            | 370    | 0   | 370   | 2008                         | Construction      |                                                      |
| OHL  | UA          | Zahidnoukrainska   | UA          | Bogorodchani         | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 111    | 0   | 111   | 2010                         | Construction      |                                                      |
| OHL  | UA          | Dnistrovska PSHPP  | UA          | Bar                  | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 95     | 0   | 95    | 2007                         | Construction      |                                                      |
| OHL  | UA          | Novoodeska         | UA          | Artsyz               | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 140    | 0   | 140   | 2007                         | Feasibility study |                                                      |
| OHL  | UA          | Adgalyk            | UA          | Usatovo              | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 124    | 0   | 124   | 2007                         | Feasibility study | second line                                          |
| OHL  | UA          | Zarya              | UA          | Mirna                | 330                           | 1                                  | 1380 A   | -                      | ACSR                                      | 300*2            | 14     | 0   | 14    | 2008                         | Construction      | second line                                          |
| OHL  | UA          | Simferopol         | UA          | Sevastopol           | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 70     | 0   | 70    | 2007                         | Feasibility study | upgrade from 220kV                                   |
| OHL  | UA          | Dgankoj            | UA          | Melitopol-Simferopol | 330                           | 1                                  | 1380 A   | -                      | ACSR                                      | 400*2            | 16     | 0   | 16    | 2006                         | Construction      | Connectors of Dgankoj SS to OHL Melitopol-Simferopol |
| OHL  | UA          | Pivnichnoukrainska | UA          | Kyivska              | 750                           | 1                                  | 4000 A   | -                      | ACSR                                      | 400*5            | 292    | 0   | 292   | 2015                         | Feasibility study |                                                      |
| OHL  | UA          | Zaporizka NPP      | UA          | Kahovska             | 750                           | 1                                  | 4000 A   | -                      | ACSR                                      | 400*5            | 190    | 0   | 190   | 2015                         | Feasibility study |                                                      |
| OHL  | UA          | Lutsk Pivnichna    | UA          | Ternopil             | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 180    | 0   | 180   | 2010                         | Feasibility study |                                                      |
| OHL  | UA          | K.Podolska         | UA          | Ternopil             | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 150    | 0   | 150   | 2012                         | Feasibility study |                                                      |
| OHL  | UA          | HPP Dnistrovska    | MD          | Balti                | 330                           | 1                                  | 1670 A   | -                      | ACSR                                      | 400*2            | 120    | 0   | 120   | 2012                         | Idea              | second line                                          |

- 1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)
- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)



Figure 2.12 – Ukraine – Network reinforcements till 2010



Table 2.23 – Ukraine – New production units

| TYPE  | SUBSTATION <sup>1</sup> |             | VOLTAGE LEVEL |     | CAPACITY    |     | DATE OF COMMISSIONING | STATUS       | COMMENT                              |
|-------|-------------------------|-------------|---------------|-----|-------------|-----|-----------------------|--------------|--------------------------------------|
|       |                         |             | kV            | kV  | MW          | MVA |                       |              |                                      |
| 1     | 2                       | 3           | 4             | 5   | 6           | 7   | 8                     | 9            | 10                                   |
| PSHPP | UA                      | Dnistrovska | 15.75         | 330 | 324/416     | 360 | 2008                  | Construction |                                      |
| CCHP  | UA                      | Kyivska 6   | 20            | 330 | 250         | 353 | 2008                  | Construction |                                      |
| PSHPP | UA                      | Tashlykska  | 15.75         | 330 | 2x146/2x211 | 307 | 2006                  | Construction | units 1 and 2(211PUMP/146GENERATION) |
| PSHPP | UA                      | Tashlykska  | 15.75         | 330 | 2x146/2x211 | 307 | 2008                  | Construction | units 3 and 4(211PUMP/146GENERATION) |

<sup>1</sup> Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHPP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)

<sup>2</sup> Country

<sup>3</sup> Substation name





---

|   |                                                                  |
|---|------------------------------------------------------------------|
| 4 | Generator voltage level                                          |
| 5 | Network voltage level                                            |
| 6 | Installed active power                                           |
| 7 | Installed apparent power                                         |
| 8 | Date of commissioning (estimate)                                 |
| 9 | Status of the project (Idea, Feasibility study, Construction...) |

## 2.8. ARMENIA

The power transmission network of Armenia consists of 220 kV and 110 kV lines. Figure 2.13 shows the map of Armenian network and Table 2.24 shows main data about Armenian transmission network.

Table 2.24 – Armenia - network overview

| Lines         |                                         | Transformers  |                      |
|---------------|-----------------------------------------|---------------|----------------------|
| Voltage level | Length of the overhead lines and cables | Voltage level | Installed capacities |
| (kV)          | (km)                                    | (kV/kV)       | (MVA)                |
| 220           | 1323                                    | 220/x         | 2715                 |
| 110           | 3169                                    | 110/x         | 5400                 |
| total         | 4492                                    |               | 8115                 |

Armenia is connected through interconnection lines with all neighboring countries:

Table 2.25 – Armenia – interconnection lines

| State      | Name and Type of Interconnection | Condition            |
|------------|----------------------------------|----------------------|
| Georgia    | Alaverdi 220 kV                  | Operational          |
| Turkey     | Kars 220 kV                      | Out of operation     |
| Iran       | Megri 220 kV                     | Operational          |
| Azerbaijan | Atarbekiar 330 kV                | Out of operation     |
| Georgia    | Ashotzk 110 kV                   | Operational (radial) |
| Georgia    | Lalvar 110 kV                    | Operational (radial) |

Installed generation capacity in Armenia exceeds consumption, and Armenia is capable of exporting large quantities of energy.

|                               |             |
|-------------------------------|-------------|
| Armenian NPP                  | 815(440) MW |
| Hrazdan TPP                   | 1100 MW     |
| Yerevan TPP                   | 550 MW      |
| Sevan-Hrazdan cascade of HPPs | 550 MW      |
| Vorotan cascade of HPPs       | 400 MW      |
| Small HPPs                    | 80 MW       |

Figure 2.13 – Armenia - network map



## The scheme of the Armenian Power System



Ministry of Energy RA

- NPP
- HPP
- TPP

- 400 kV line project
- 330 kV
- 220 kV
- 110 kV



## Planned network reinforcements

Table 2.26 shows planed network reinforcements in forthcoming period.

Table 2.26 – Armenia - Planned network reinforcements


| TYPE | SUBSTATION1 |             | SUBSTATION2 |        | VOLTAGE<br>LEVEL | number<br>of<br>circuits<br>/units | CAPACITY |                     | MATERIAL<br>OR<br>TRANSFORMER<br>TYPE | CROS<br>SECTION | LENGTH |     |       | DATE OF<br>COMMISSION | STATUS            |
|------|-------------|-------------|-------------|--------|------------------|------------------------------------|----------|---------------------|---------------------------------------|-----------------|--------|-----|-------|-----------------------|-------------------|
|      |             |             |             |        |                  |                                    | A or MVA | limited<br>A or MVA |                                       |                 | BR1    | BR2 | TOTAL |                       |                   |
| 1    | 2           | 3           | 2           | 3      | 4                | 5                                  | 6        | 7                   | 8                                     | 9               | 10     | 11  | 12    | 13                    | 14                |
| SS   | AM          | Hrazdan TPP |             |        | 400/220          | 10                                 | 2x5x200  | 2x5x220             |                                       |                 |        |     |       | 2009                  | Feasibility study |
| OHL  | AM          | Hrazdan TPP | IR          | Tavriz | 400              | 2                                  | 2x1800   | 2x1900              | ACSR                                  | 2x(2x500)       | 332    | 100 | 432   | 2010                  | Feasibility study |
| OHL  | AM          | Hrazdan TPP | GE          | Ksani  | 400              | 1                                  | 1100     | 1400                | ACSR                                  | 2x300           | 90     | 80  | 170   | 2009                  | Feasibility study |

- 1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)
- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)

Table 2.27 – Armenia - Planned new generation units

| TYPE | SUBSTATION1 |                      | VOLTAGE<br>LEVEL |     | CAPACITY |     | DATE OF<br>COMMISSIONING | STATUS             |
|------|-------------|----------------------|------------------|-----|----------|-----|--------------------------|--------------------|
|      |             |                      | kV               | kV  | MW       | MVA | year                     |                    |
| 1    | 2           | 3                    | 4                | 5   | 6        | 7   | 8                        | 9                  |
| CCHP | AM          | Yerevan TPP new unit | 18               | 110 | 208      | 240 | 2009                     | Tendering          |
| TPP  | AM          | Hrazdan TPP unit 5   | 15.75            | 220 | 440      | 510 | 2009                     | Partly Constructed |

- 1 Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHPP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)
- 2 Country
- 3 Substation name
- 4 Generator voltage level
- 5 Network voltage level
- 6 Installed active power
- 7 Installed apparent power
- 8 Date of commissioning (estimate)
- 9 Status of the project (Idea, Feasibility study, Construction...)



### 3. REGIONAL MODEL

#### 3.1. Model development

Every project participant made model of his system in PSS/E. Model integrator (EKC) has connected all models into one regional model. Also, model integrator had following obligations:

- homologize data for interconnection lines
- developing of adequate external equivalent (equivalenting Western, Central and Southern Europe's network)
- checking of all models and regional one
- testing of model accuracy

#### 3.2. Model characteristics

For forecast horizon it was decided to model two regimes in 2010, with following assumptions:

- All power systems in parallel operation
- Hydrological conditions: average for whole region

It was decided to model two yearly characteristic regimes for whole region:

- ☐ minimum load regime
- ☐ peak load regime

Table 3.1 – Peak load and low load hours in Black Sea countries


|             | BG    | GE    | MD    | RO    | RU    | TR    | UA    |
|-------------|-------|-------|-------|-------|-------|-------|-------|
| time zone*  | +1:00 | +3:00 | +2:00 | +2:00 | +3:00 | +2:00 | +2:00 |
| Low hour**  | 05:00 | 04:00 | 03:00 | 03:00 | 04:00 | 03:00 | 03:00 |
| Peak hour** | 20:00 | 21:00 | 18:00 | 19:00 | 19:00 | 19:00 | 19:00 |

\*time shift to GMT time zone

\*\* local time

It was agreed to use these time for respective model regimes

- ☐ Winter peak load (16:00 GMT)
- ☐ Summer minimum load (01:00 GMT)



## Agreed base case scenarios

### Winter regime

|       |      | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10   |
|-------|------|-------|-------|-------|-------|-------|-------|-------|-------|-------|------|
|       |      | from  |       |       |       |       |       |       |       |       |      |
|       |      | BG    | GE    | MD    | RO    | RU    | TR    | UA    | AM    | EXT*  | **   |
| to    | BG   | ***** |       |       | 0     |       | 0     |       |       | 0     |      |
|       | GE   |       | ***** |       |       | 200   | 0     |       | 0     | 0     |      |
|       | MD   |       |       | ***** | -750  |       |       | 450   |       | 0     |      |
|       | RO   | 0     |       | 750   | ***** |       |       | 0     |       | -800  |      |
|       | RU   |       | -200  |       |       | ***** |       | -200  |       | -1150 | 1800 |
|       | TR   | 0     | 0     |       |       |       | ***** |       | 150   | 0     |      |
|       | UA   |       |       | -450  | 0     | 200   |       | ***** |       | -1000 | 1000 |
|       | AM   |       | 0     |       |       |       | -150  |       | ***** | -1250 |      |
|       | EXT* | 0     | 0     | 0     | 800   | 1150  | 0     | 1000  | 1250  | ***** |      |
| TOTAL |      | 0     | -200  | 300   | 50    | 1550  | -150  | 1250  | 1400  | -4200 | 2800 |

\*countries outside BSR


\*\* remaining capabilities

### Summer regime

|       |      | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10   |
|-------|------|-------|-------|-------|-------|-------|-------|-------|-------|-------|------|
|       |      | from  |       |       |       |       |       |       |       |       |      |
|       |      | BG    | GE    | MD    | RO    | RU    | TR    | UA    | AM    | EXT*  | **   |
| to    | BG   | ***** |       |       | 0     |       | 0     |       |       | 0     |      |
|       | GE   |       | ***** |       |       | 200   | -500  |       | 0     | 100   |      |
|       | MD   |       |       | ***** | -350  |       |       | 350   |       | 0     |      |
|       | RO   | 0     |       | 350   | ***** |       |       | 0     |       | -350  |      |
|       | RU   |       | -200  |       |       | ***** |       | -200  |       | -1150 | 1800 |
|       | TR   | 0     | 500   |       |       |       | ***** |       | 150   | 0     |      |
|       | UA   |       |       | -350  | 0     | 200   |       | ***** |       | -1000 | 1000 |
|       | AM   |       | 0     |       |       |       | -150  |       | ***** | -1250 |      |
|       | EXT* | 0     | -100  | 0     | 350   | 1150  | 0     | 1000  | 1250  | ***** |      |
| TOTAL |      | 0     | 200   | 0     | 0     | 1550  | -650  | 1150  | 1400  | -3650 | 2800 |

\*countries outside BSR

\*\* remaining capabilities



All systems are modeled in “parallel” operation and connected to main UCTE grid. At present they do not operate like this. Main goal of this approach is to investigate operational conditions and electric energy trade capabilities after eventual connection of the whole region to UCTE main grid.

For this purpose, high voltage network-transmission network of all countries in the region was modeled:

□ Voltage levels

750kV

500kV

400kV

330kV

220kV

150kV

110kV


Main generator units are modeled at their nominal voltage level with corresponding step-up transformers. All new substations and lines that are expected to be operational till 2010 (according to the long term development plans) are modeled too. Table 3.2 shows main model characteristics, like number of elements modeled (Buses, Plants, Machines, Loads, Lines, Transformers).

Table 3.2 – Model characteristics

| AREA         | BULGARIA |     |     | GEORGIA |    |    | MOLDOVA |     |     | ROMANIA |      |      | RUSSIA |     |     | TURKEY |      |      | UKRAINE |     |     | ARMENIA |     |     | EXT |     |     | TOTAL |      |      |
|--------------|----------|-----|-----|---------|----|----|---------|-----|-----|---------|------|------|--------|-----|-----|--------|------|------|---------|-----|-----|---------|-----|-----|-----|-----|-----|-------|------|------|
| ELEMENT TYPE | #        | W   | S   | #       | W  | S  | #       | W   | S   | #       | W    | S    | #      | W   | S   | #      | W    | S    | #       | W   | S   | #       | W   | S   | #   | W   | S   | #     | W    | S    |
| BUSES        | 651      | 608 | 596 | 59      | 54 | 49 | 469     | 476 | 476 | 1078    | 1016 | 973  | 609    | 609 | 574 | 1307   | 1102 | 1034 | 652     | 628 | 585 | 108     | 108 | 100 | 170 | 161 | 162 | 5103  | 4762 | 4549 |
| PLANTS       | 84       | 58  | 32  | 22      | 16 | 11 | 42      | 32  | 32  | 238     | 184  | 138  | 123    | 107 | 69  | 299    | 298  | 233  | 141     | 108 | 58  | 45      | 45  | 37  | 13  | 13  | 12  | 1007  | 861  | 622  |
| MACHINES     | 112      | 69  | 35  | 26      | 20 | 11 | 48      | 36  | 34  | 238     | 178  | 94   | 139    | 121 | 75  | 683    | 621  | 421  | 142     | 109 | 58  | 48      | 39  | 39  | 13  | 13  | 12  | 1449  | 1206 | 779  |
| LOADS        | 569      | 569 | 554 | 27      | 26 | 26 | 253     | 253 | 253 | 739     | 719  | 681  | 433    | 432 | 424 | 633    | 633  | 595  | 540     | 508 | 446 | 31      | 31  | 31  | 77  | 75  | 73  | 3302  | 3246 | 3083 |
| LINES        | 747      | 713 | 727 | 52      | 43 | 43 | 552     | 486 | 486 | 1315    | 1144 | 1146 | 657    | 640 | 641 | 1244   | 1300 | 1294 | 650     | 646 | 647 | 90      | 86  | 86  | 77  | 125 | 130 | 5384  | 5183 | 5200 |
| 750          |          |     |     |         |    |    |         |     |     | 1       |      |      | 6      |     |     |        |      |      | 21      |     |     |         |     |     |     |     |     |       |      | 28   |
| 500          |          |     |     | 8       |    |    |         |     |     |         |      |      | 44     |     |     |        |      |      | 4       |     |     |         |     |     | 1   |     |     |       |      | 57   |
| 400          | 40       |     |     | 2       |    |    | 5       |     |     | 58      |      |      |        |     |     | 172    |      |      | 4       |     |     | 2       |     |     | 50  |     |     |       |      | 333  |
| 330          |          |     |     | 1       |    |    | 17      |     |     |         |      |      | 76     |     |     |        |      |      | 190     |     |     |         |     |     | 20  |     |     |       |      | 304  |
| 220          | 56       |     |     | 38      |    |    |         |     |     | 117     |      |      | 207    |     |     | 2      |      |      | 75      |     |     | 42      |     |     | 6   |     |     |       |      | 543  |
| 150          |          |     |     |         |    |    |         |     |     |         |      |      |        |     |     | 1070   |      |      | 75      |     |     |         |     |     |     |     |     |       |      | 1145 |
| 110          | 651      |     |     | 3       |    |    | 530     |     |     | 1139    |      |      | 324    |     |     |        |      |      | 281     |     |     | 46      |     |     |     |     |     |       |      | 2974 |
| TRANSFORMERS | 161      | 120 | 92  | 31      | 24 | 18 | 62      | 42  | 42  | 307     | 210  | 167  | 418    | 415 | 380 | 715    | 711  | 503  | 342     | 305 | 262 | 74      | 74  | 66  | 6   | 6   | 5   | 2116  | 1907 | 1535 |
| STEP UP      | 96       |     |     | 23      |    |    | 35      |     |     | 151     |      |      | 107    |     |     | 535    |      |      | 124     |     |     | 47      |     |     | 0   |     |     |       |      | 1118 |
| NETWORK      | 65       |     |     | 8       |    |    | 27      |     |     | 156     |      |      | 311    |     |     | 180    |      |      | 218     |     |     | 27      |     |     | 6   |     |     |       |      | 998  |

# total number of elements  
W number of elements in operation in Winter maximum  
S number of elements in operation in Summer minimum





### 3.3. Methodology for transfer capacities calculations

Transfer capacities (TTC, NTC, ATC) are important indicators for market participants to anticipate and plan their cross-border transactions and for the TSOs to manage these international exchanges of electricity. But also can give indications about weak points of transmission network and can be used to evaluate influence of network development plans and new planned network reinforcements.

General definitions of transfer capacities and the procedures for their calculation/assessment are given by ETSO (European Transmission System Operators), in the following documents:

[1] ETSO, *Definitions of Transfer Capacities in liberalized Electricity Markets, Final Report April 2001*

[2] ETSO, *Procedures for cross-border transmission capacity assessments, October 2001*

[3] ETSO, *Net Transfer Capacities (NTC) and Available Transfer Capacities(ATC) in the Internal Market of Electricity in Europe (IEM)*

[4] UCTE, *Technical guidelines for Net Transfer Capacity determination*

Methodology used in performing this study is based on these prerequisites, and detailed approach will be explained in following chapters.

#### 3.3.1. DEFINITIONS OF TRANSFER CAPACITIES

According to ETSO, the definitions that refer to program values are presented below. As explained in the Introduction, these definitions are related to the classical calculation of transfer capacities – between the neighbouring systems/areas, linked with the tie-line(s).


**Also, it is important to note that the TTC, NTC, BCE, AAC, ATC are the EXCHANGE PROGRAM values; these are not the physical flows, and generally differ from the physical flows at the interconnection lines (except in particular cases of radial operation).**

The evaluation of TTC between two electrical areas requires:

- To make a choice of local power system scenario
- To define a base case, which involves the sharing of full information amongst TSOs to build up the global (merged) load flow model
- To apply an agreed procedure for carrying out the calculations

Total Transfer Capacity (TTC), is the maximum feasible exchange program between two areas compatible with operational security standards, calculated according to the pre-assumption that the future network conditions are well known.

TTC is always related to a given power system scenario, i.e.: generation schedule and pattern, consumption pattern and available network state that constitute the data allowing to build up a mathematical model of the power system (load flow equations). The solution of this model leads to the knowledge of the voltages at the network nodes and the power flows in the network elements which are the parameters being monitored by a TSO to assess system security.



The solution of this model is the so-called **base case** and is the starting point for TTC computation. This base case will already contain exchange programs between TSOs and control areas. These are the various transactions likely to exist -according to what has been observed in the past - in the forecasted situation.

For a given pair of neighbouring control areas, A and B, for which capacities are to be computed, in the base case there exists a global exchange program called **Base Case Exchange (BCE)**. Sometimes it is hard to determine the Base Case Exchanges for a given base case network model, even for the classical calculation of transfer capacities (between the neighbouring areas). It is easy to determine the load-flows at the tie-lines by running the load-flow on the base case model and recording the active power flows at the tie-lines (this value is called the Notified Transmission Flow - NTF), but since the BCEs are the program (contractual) values, related to the base case model, theoretically there can be an infinite number of sets of BCEs which give the same exchange totals of all modelled systems. That is why the BCE should be agreed by the consensus among the calculation parties. Since the final TTC values highly depend on the agreed value of BCE, it is recommended that realistic BCEs are agreed (base case load flows on interconnection lines - NTFs can give some indication of the BCEs which are resulted from).

As the result of this procedure, TTC equals the maximum exchange programme between the two areas being considered, if the generation and load pattern in these areas and in other areas strongly interconnected to these two would exactly correspond to the assumptions made in the evaluation steps, namely the ones implicit in the base case.


The maximum additional program exchange (over the BCE) that copes with the security standards is marked with  $\Delta E_{max}$ .

**The Total Transfer Capacity (TTC)** is the maximum exchange program between two areas, compatible with operational security standards\* applicable at each system\*\*, if future network conditions, generation and load patterns were perfectly known in advance\*\*\*.

$$TTC = BCE + \Delta E_{max}$$

- \* *the most important, and usually checked is n-1 security criterion*
- \*\* *in highly meshed networks, usually not only the two concerned systems are observed, but also the “third” systems, if they are significantly influenced by the transfers between the two concerned systems*
- \*\*\* *the last part of the sentence indicates that no model and/or forecasting imperfections are taken into account within TTC (they are evaluated within the TRM, see below)*

The uncertainties associated to the forecast of the power system state, for a given time period in the future, may decrease according to the selected time frame. Therefore the TTC value may vary (i.e. may increase or decrease) when approaching the time of programme execution as a result of a more accurate knowledge of generating unit schedules, load pattern, network topology and tie-lines availability.



### Transmission Reliability Margin (TRM)

is a security margin that copes with uncertainties on the computed TTC values arising from:

- Unintended deviations of physical flows during operation due to the physical functioning of load-frequency control (LFC)
- Emergency exchanges between TSOs to cope with unexpected unbalanced situations in real time
- Inaccuracies, e. g. in data collection and measurements

TRM is then associated to the real-time operation and its value is determined by each TSO, in order to guarantee the operation security of its own power system. TRM may vary seasonally or may be updated according to possible modifications occurred in the power system.

Typical values of TRM used in SEE area are 50-100 MW, which somehow corresponds to the size of the SEE systems and typical electricity transfers. However, if the calculated transfer capacities will be used in real electricity market (as a constraints for some of the transmission capacity allocation methods based on NTC), the particular TRM for each border and in each direction should be carefully assessed among the TSOs.

**Net Transfer Capacity (NTC)** is defined as:

$$\text{NTC} = \text{TTC} - \text{TRM}$$

NTC is the maximum exchange program between two areas compatible with security standards applicable in both areas and taking into account the technical uncertainties on future network conditions.

Figure 1 gives the graphical explanation of defined program values, presented on the example of calculating the transfer capacities between areas A and B, with already existing Base Case Exchange from A towards B.

Direction A→B

$$\text{TTC}^{A \rightarrow B} = \text{BCE}^{A \rightarrow B} + \Delta E_{\max}^{A \rightarrow B}$$

$$\text{NTC}^{A \rightarrow B} = \text{TTC}^{A \rightarrow B} - \text{TRM}^{A \rightarrow B}$$

Direction B→A

$$\text{TTC}^{B \rightarrow A} = \text{BCE}^{B \rightarrow A} + \Delta E_{\max}^{B \rightarrow A}$$

$$\text{NTC}^{B \rightarrow A} = \text{TTC}^{B \rightarrow A} - \text{TRM}^{A \rightarrow B}$$





Figure 3.1 - Graphical and presentation of transfer capacities and their analytical relations



NTC may be allocated in different time frames to match the need for securing longer term trading and to provide room for shorter term trading. One may distinguish, as the result of the allocation procedures in each allocation time frame, two notions:

**Already Allocated Capacity (AAC)**, that is the total amount of allocated transmission rights (at some of the possible previous allocation rounds), depending on the allocation method.

**The Available Transmission Capacity (ATC)**, is the part of NTC that remains available, after each phase of the allocation procedure, for further commercial activity. ATC is given by the following equation:

$$ATC = NTC - AAC$$

AAC and ATC are thus a result of each stage of the allocation procedure.

In ETSO definitions of transfer capacities the clear distinction is made between the program (contractual, scheduled) values, and the physical active power flows related to these program values, i.e. originated by them, and recorder in AC load flow model.





Figure 3.2 - Program and physical values

Since the definitions of the program values are related to the border between the two TSOs, the definitions of physical values are also related to the sum of the individual tie-line flows at the observed border.

**Notified Transmission Flow (NTF)** is the physical flow over the tie-lines between the considered areas observed in the base case model prior to any generation shift between the areas. It results from the Base Case Exchanges (BCE).

**The additional physical flow  $\Delta F_{max}$**  is the physical flow over the tie lines between the two concerned areas, induced by the maximum generation shift  $\Delta E_{max}$ .



**Total transfer Flow (TTF)**<sup>1</sup> is the net physical flow across the border associated with a program exchange of magnitude TTC, provided that no other exchanges have been modified from the base case (except the one between the two areas between which the TTC is calculated).

$$\text{TTF} = \text{NTF} + \Delta F_{\text{max}}$$

### 3.3.2. CALCULATION OF TTC

#### *Algorithm of TTC calculation*

The concept of TTC calculation based on ETSO documents will be explained on an example of calculating the TTCs between areas A and B, where BCE from A towards B already exist in base case.





Figure 3.3 - Process of TTC calculation

<sup>1</sup> In flow-based methods for the allocation of the transmission capacity, the TTF is usually used as a constraint, like physical maximum of the cross-border flow compatible with security standards. In most of these methods it is then called Border Capacity (BC). One of such methods is Coordinated explicit flow-based Auction, proposed by ETSO, and currently investigated among the TSO of SEE Europe.



When computing TTC from area A to area B, generation is stepwise increased in control area A and decreased in control area B giving rise to a power flow from area A to area B. The shifts of generation are named as  $\Delta E^+$  and  $\Delta E^-$  for the increase and the decrease respectively. This process is carried out up to the point, where security rules (in systems A, B, or in some of the neighbouring systems highly dependent on the transaction among A and B) are breached ( $\Delta E_{\max}^+ / \Delta E_{\max}^-$ ). The maximum exchange from A to B compatible with security rules without taking into account uncertainties and inaccuracies is actually the TTC from A to B, and it is calculated as:

$$\text{TTC} = \text{BCE} + \Delta E_{\max}^+$$

This procedure is reversed - decrease of generation in system A and increase of generation in system B - when computing TTC from area B to area A leading to a maximum increase of generation of  $\Delta E_{\max}^-$  and thus to a maximum exchange from B to A of  $\Delta E_{\max}^- - \text{BCE}$ .

For planning purposes (evaluation of development plans) and for long term transfer capabilities evaluations, after reaching the exchange in which first critical contingency occurs, calculations should be continued, to confirm this identified bottleneck, till the next identified critical contingency.





Figure 3.4

This way identified bottleneck is confirmed, or even next one identified, allowing experts to identify whole problematic parts of network (not just one critical element and contingency), giving better and wider view how this limitations can be remedied and which new investment are best in sense of transfer capabilities increase. Also, with additional analyses, influence of new elements according to the development plans can be evaluated (Figure 4).



The calculations are performed on the merged data sets, so cold “base models” and their significant maintenance (topology) scenarios, considering the approved exchange scenarios. Before starting calculations, corresponding base models have to be checked for security, respecting the N-1 criterion. If any bottlenecks are found, they have to be carefully analyzed and corresponding measures have to be taken to avoid them. Concerning that, base models overloads are to be neglected during the further transfer capacities calculations.

Except for EPS of Turkey, for all other EPSs, represented with models in the base cases, the existing long term contracts are modelled as base case exchanges. An internal exchange pattern of zero exchanges between southeast European countries and Turkey is assumed. If, from the findings of this analysis, some critically loaded lines are found, the combined influence of internal and external exchanges will be evaluated for a realistic (limited) number of cases.

### *Generation shift*

In order to determine the cross-border transmission limit between two neighbouring countries or zones, cross-border exchanges are gradually increased while maintaining the loads in the whole system unchanged until security limits are reached.

Starting from the common base case exchanges, the additional exchange is performed through an increase of generation on the exporting side and an equivalent decrease of generation on the importing side. This generation shift is to be made stepwise until a network constraint is violated. Typical step for the generation shift during the TTC assessment is 50, or 100 MW.

The generation increase/decrease has to be performed according to some predefined criteria. The main concepts of the distribution the generation increase/decrease in some area over the different generating sets are:

#### **1. Proportionally to the engagement of the production units in base case**

This is wide used generation shift concept, suitable for fast calculations, because it does not require any additional information except the base case Load flow model. Commonly used principle is that the factor which distributes the generation increase/decrease in a given area over the different generators in this area is the ratio of base case engagement of each generator to the total of internal generation scheduled and involved in the shift.


$$P_{new}^{inc} = P_i + \Delta E \cdot \frac{P_i}{\sum_n (P_i)}; \quad P_{new}^{dec} = P_i - \Delta E \cdot \frac{P_i}{\sum_n (P_i)}$$

$P_i$  - active power generation of respective production unit

$P_{new}^{inc}$  - new increased generation

$P_{new}^{dec}$  - new decreased generation

$\Delta E$  - step of the generation shift



This concept of generation shift often lead to non-feasible generation patterns, because of the principle that the generators already highly engaged in base case are favoured during the shift, often above their real possibilities. On the other hand, some generators which are not engaged in base case will not be engaged in generation shift process too.

## 2. Proportionally to the active power reserve in respective production units

This concept respects the real production possibilities of the generators, and requires additional information about the Pmin and Pmax of those generators which will participate in generation shift. Then, in each step the amount of the shift will be shared among the engaged generators according to their remaining production “reserve” (UCTE method A).

$$P_{new}^{inc} = P_i + \Delta E \cdot \frac{P_i^{max} - P_i}{\sum_n (P_i^{max} - P_i)} ; P_{new}^{dec} = P_i - \Delta E \cdot \frac{P_i^{min} - P_i}{\sum_n (P_i^{min} - P_i)}$$

$P_i$  - active power generation of respective production unit

$P_{new}^{inc}$  - new increased generation

$P_{new}^{dec}$  - new decreased generation

$\Delta E$  - step of the generation shift

$P_i^{min}$  - minimum permissible generation (for the generators participating in decreasing)

$P_i^{max}$  - maximum permissible generation (for the generators participating in increasing)

In case of using the generation shift proportionally to the reserve, the information about actual Pmin [MW] and Pmax [MW] for modelled power plants should be comprised in corresponding format for the network model. These Pmin and Pmax should be not related to the theoretical minimum and maximum generation of the respective power-plant, but to their available limits, which correspond to the observed regime.

Thus, the power reserve for some power plant can be calculated:


$$\Delta P_{increase} = P_{max} - P_{base\ case}$$

$$\Delta P_{decrease} = P_{base\ case} - P_{max}$$

## 3. According to the priority list of the production units (order& active generation shift)

Within this concept, the priority lists of the generators for the participation in generation shift are known, with an order of the engagement and the active power for the increasing/decreasing (so-called “Generation merit order” - UCTE method C). Then, generation is shifted simultaneously - increased/ decreased according to the shifting lists. This list corresponds to the common operational practice of increasing of the amount of the power exchanges, and thus corresponds to the realistic scenarios or it can be made according to the economic dispatch, or even market prices. It has to be said that this is most realistic approach, since generator units are engaged as they are in reality.





This pattern of generation shift is very frequently used in TTC calculation among the SEE countries, and requires additional information in a form of generation shift list.

In case of using the generation shift according to the priority list, an additional data should be exchanged along with each base case model, comprising the information of the shifting order (1,2,3...) and the available amount of generation shift.

#### Example

Priority list for increase within one system containing three modelled power plants can be:

Table 3.3 – Example of Generation shifting list

| Node     | Order | P <sub>basecase</sub> | ΔP+  | IF<br>STEP= | STEP 1 | STEP 2 |
|----------|-------|-----------------------|------|-------------|--------|--------|
|          |       | [MW]                  | [MW] | 100<br>MW   | [MW]   | [MW]   |
| JDJERD11 | 1     | 700                   | 120  |             | 100    | 20     |
| JBASTA21 | 2     | 70                    | 50   |             | /      | 50     |
| JBASTA22 | 3     | 90                    | 30   |             | /      | 30     |
| sum:     |       |                       |      |             | 100    | 100    |

Thus, if the generation shift step is e.g. 100 MW:


1. in first step the JDJERD11 will be shifted for 100 MW, and its engagement will be 800 MW.
2. In second step JDJERD11 will be increased for 20 MW (and thus spend its possibility for the increase) and its engagement will be 820 MW. Additionally, JBASTA21 will be increased for 50 MW, and JBASTA22 will be increased for 30 MW.

100 MW is the recommended step for increasing/decreasing the generation to calculate TTC. For all generation nodes that are to be considered for the transfer capacities determination, the minimal and maximal output power must be indicated. Generators out of operation in the base case must also be included, with their corresponding limits, so they could be switched on if necessary during TTC determination.

When calculating MTC, two methods for shift of generation are recommended:

- According merit order (method 3);
- Proportionally to the remaining available capacity (method 2).

Second method will be used in cases where Generation shifting list is not available.



### Security criteria

As it has been shown in Figure 3.3 and Figure 3.4, the calculation of the TTC is stopped if:

- 1) Maximum export possibility in exporting system is reached, or maximum import possibility in importing system is reached. In cases of reaching the  $P_{max}$  of export or import, the last  $\Delta E$  is considered as  $\Delta E_{max}$ .
- 2) Critical contingencies are discovered. If the critical contingency is reached, the calculation is stopped, and the generation shift  $\Delta E$  from the previous step is considered as an  $\Delta E_{max}$ . TTC is then calculated as:

$$TTC = BCE + \Delta E_{max}$$

The **base case model should be checked** from the point of view of respecting the security criteria. If some contingencies are determined in base case, their relevancy concerning the transfer capacity which is to be calculated should be evaluated, and the calculation of TTC should be continued depending on the conclusion (i.e. some contingencies from the base case can be irrelevant for the observed transfer, and in such case the TTC calculation can be performed).

Security assessment comprises the checking of the **n-1 security criteria** for the outages of:

- interconnection and internal lines of extra-high voltage, without radial lines
- transformers 750/x, 500/x and 400/x ...


The **n-2 security criteria** for the simultaneous outages of double circuit lines can be checked for the agreed specific cases of outages known from practice.

*Bus bar outages are not considered, because the opinion is, that the severity of possible consequences are usually loss of stability endangering overall system security and that bus bar failures and the subsequent tripping of all transformers within a substation may lead to temporary supply interruptions within complete regional high voltage network.*

*Outages of generation units should not be taken into account within the TTC assessment, since they should be covered with TRM.*

The breaching of security rules may happen internally in any of observed systems or on the tie lines between them. Under the critical contingencies, the loading of the network elements equal or greater than above values is presumed:

- 100% of  $I_{max}$  [A] for transmission lines
- 100% of  $S_{nom}$  [MVA] for the transformers



The I<sub>max</sub> (lines) and S<sub>nom</sub> (transformers) should be defined within the base case model. I<sub>max</sub> should comprise the typical operational current limit for the transmission lines known by the system operators, whether thermal limit, or the protection setting.

Due to the uncertainty of reactive power forecast, **voltage violations** are considered only for each internal network by the corresponding system operator, usually to check that corrective measures are available.

Also, some critical contingencies can be detected in TTC calculation, but can be neglected in case:

- if the reason for the detected critical contingency is not the real critical operational regime, but the **imperfection of the used network model** (like not modelled lower voltage network in one area, which actually mitigates the effect of the observed outage)
- if reasonable **preventive & fast post-event measures** can be made, under the competences of the system operator of the network affected by the considered contingency meshing of lower voltage network, maintenance rescheduling, generation restrictions and re-dispatching
- if critical contingency is caused by the outage of the element which is shown as very stable in sense of **failure probability from the practical experience** (like element operating few years without any unplanned outage)


### 3.3.3. HARMONIZATION OF THE VALUES

The same TTC and NTC value is usually calculated by the two neighbouring TSOs (and for both directions), and then it is subject of harmonization. The values of calculated transfer capacities should be compared, along with the comprehensive results of calculation (like lists of observed outages and detected critical contingencies).

Since each TSO is responsible for the operation of its network, it also has the final word in harmonization of the transfer capacities, in cases where the critical contingencies appear at the elements of its network.

Also, as described in previous chapter, the TSOs can notify each other about the practical sense of some detected contingencies (is it realistic or not, are the post-event measures possible...)

In case if the agreement between the two TSOs, the lower between the two values for the corresponding border and direction is taken as valid.



### 3.3.4. SIMULTANEOUSLY FEASIBLE (COMPOSITE) TRANSFER CAPACITIES

The TTC values are currently the basis for applied mechanisms for allocation of the transmission capacity at almost all European borders<sup>2</sup>. Nevertheless, the strong interdependence between some of the borders within the highly meshed European grid can seriously compromise the usage of classically calculated TTCs as bilaterally agreed values. The effect of parallel flows, i.e. the physical flows containing the natural flows and the loop flows originated by the scheduled transactions at some “third” borders, often endanger the operational security of the transmission grid, even if all the calculated NTCs are respected.

A simple example can show the main side of this problem:

If TTC (or NTC) is calculated for the export of system A towards system C, the generation is increased in A and decreased in C until the security limits are breached. Thus the value  $TTC\ A \rightarrow C$  is obtained. In this case the generation in system B remains as in the base case. If then the  $TTC\ (B \rightarrow C)$  is calculated, the base case model is again the starting point, and the generation is increased in B and decreased in C, while the generation in B is as in the base case.





Figure 3.5

If the two bilaterally agreed values  $TTC\ (A \rightarrow C)$  and  $TTC\ (B \rightarrow C)$  are offered to the market, the final operational regime can be dangerous from the security point of view (although both TTCs are “correctly” calculated), since the borders  $A \rightarrow C$  and  $B \rightarrow C$  are interdependent.

The values  $TTC\ (A \rightarrow C)$  and  $TTC\ (B \rightarrow C)$  are not cumulative, i.e. the value  $TTC\ (A \rightarrow C) + TTC\ (B \rightarrow C)$  cannot be offered to the market.

One of the possible ways to mitigate this problem is the calculation of so-called “composite”, or “bundled” TTC, which can be treated as simultaneously feasible. First the highly interdependent borders or regional cross-sections should be detected (can comprise two or more bilateral borders). In the above example, the composite TTC can be calculated by the simultaneous generation increase in systems A+B (according to the predefined generation shift scenario), and decrease in system C. Thus the joint  $TTC$  for the border  $(A+B) \rightarrow C$  is calculated. If necessary, it can later on be fractioned per the bilateral borders  $A \rightarrow C$  and  $B \rightarrow C$  (e.g. in proportion to the physical power flows, “TTFs” at these borders).

<sup>2</sup> Methods that use NTC: first come-first served, pro-rata rationing, explicit and implicit auctions, market splitting



The principle of simultaneous generation shift in more than one exporting (or importing) area can also be used in case of calculation the TTCs over the third, transit systems. If this system (figure 6) is typically the transit system for the electricity exchanges between A and C, the calculation of TTC by increasing the generation only in B would lead to unrealistically small capacity. Therefore the generation can be increased in (A+B) simultaneously and lead to more accurate transfer capabilities results.




Figure 3.6


### 3.3.5. TRANSFER CAPACITIES BETWEEN NON-NEIGHBOURING SYSTEMS

As already explained, ETSO definitions for the transfer capacities are always related to the neighbouring systems, i.e. to the border between the neighbouring systems, containing at least one interconnection line. However, the principles used in TTC calculation (simultaneous increase/decrease of generation in exporting/importing system) can be generalized with a goal of determination the maximum secure exchange scenarios between also non-neighbouring systems also.

The calculation procedure for TTC can be applied for this purpose, but under assumptions:

- Arbitrary assessment of BCE; It is sometimes is hard to determine BCE even for the classical TTC (for the bilateral border). Since in calculation of transfer capacities among distant systems there is no longer a bilateral border, the Base Case Exchanges among the concerned systems should be determined on the level of all TSOs involved
- Consequently to the above, the physical values typically related to the respective border (NTF,  $\Delta F_{max}$ , TTF) cannot be determined. Luckily, their assessment is not absolutely necessary in TTC assessment

The list of observed outages, as well as the list of detected contingencies should comprise the elements within all affected systems (source, sink, and systems in the middle).



### 3.4. Generation shifting lists

#### BULGARIA

Increasing the generation should start from the top of the list, and decreasing should start from the bottom of the list. Maximum and minimum generation should be set according to this list.

Table 3.4 – Bulgaria – Generation shifting list

| Price | Bus No | Name            | Pmax   | Pmin |
|-------|--------|-----------------|--------|------|
| 1     | 13310  | VHCH34G 19.000  | 428    | 0    |
| 2     | 13404  | VNKOZ_G9 24.000 | 1015.8 | 0    |
| 3     | 13602  | VTVARNG3 15.750 | 224    | 0    |
| 3     | 13603  | VTVARNG4 15.750 | 210    | 0    |
| 3     | 13604  | VTVARNG5 15.750 | 210    | 0    |
| 3     | 13605  | VTVARNG6 15.750 | 210    | 0    |

#### GEORGIA

Table 3.5 – Georgia - Generation shifting list Winter

| Price | Bus No | Name     | Pmax | Pmin |
|-------|--------|----------|------|------|
| 1     | 20104  | 6HENGUG4 | 240  | 25   |
| 1     | 20105  | 6HENGUG5 | 240  | 25   |

Table 3.6 – Georgia - Generation shifting list Summer


| Price | Bus No | Name     | Pmax | Pmin |
|-------|--------|----------|------|------|
| 1     | 20104  | 6HENGUG4 | 240  | 25   |
| 1     | 20105  | 6HENGUG5 | 240  | 25   |
| 1     | 20103  | 6HENGUG3 | 240  | 25   |

#### MOLDOVA

Increasing the generation in Moldova should start from the top of the list, and decreasing should start from the bottom of the list. Maximum and minimum generation should be set according to this list.

Table 3.7 – Moldova - Generation shifting list

| bus   | Machine name    | ID | Status | BC P | Pmax | Pmin |
|-------|-----------------|----|--------|------|------|------|
| 38016 | 5KOHPPG 10.500  | 1  | 1      | 16   | 16   | 0    |
| 38010 | 5DHPP1G 10.500  | 3  | 1      | 6    | 12   | 0    |
| 38010 | 5DHPP1G 10.500  | 4  | 1      | 6    | 12   | 0    |
| 38011 | 5DHPP2G 10.500  | 1  | 1      | 6    | 12   | 0    |
| 38011 | 5DHPP2G 10.500  | 2  | 1      | 6    | 12   | 0    |
| 38001 | 5KSPP2G1 10.500 | 2  | 1      | 70   | 80   | 0    |
| 38002 | 5KSPP2G2 10.500 | 1  | 1      | 72   | 80   | 0    |
| 38003 | 5KSPP2G3 10.500 | 3  | 1      | 68   | 80   | 0    |
| 38004 | 5KSPP2G4 10.500 | 4  | 1      | 68   | 70   | 0    |
| 30103 | 5MGRESG3 15.750 | 3  | 0      | 0    | 0    | 0    |
| 30104 | 5MGRESG4 15.750 | 4  | 0      | 0    | 150  | 0    |
| 30105 | 5MGRESG5 15.750 | 5  | 0      | 0    | 180  | 0    |
| 30106 | 5MGRESG6 15.750 | 6  | 0      | 0    | 0    | 0    |
| 30107 | 5MGRESG7 15.750 | 7  | 1      | 150  | 190  | 0    |
| 30108 | 5MGRESG8 15.750 | 8  | 0      | 0    | 170  | 0    |




|       |          |        |    |   |        |     |   |
|-------|----------|--------|----|---|--------|-----|---|
| 30109 | 5MGRESG9 | 15.750 | 9  | 1 | 150    | 200 | 0 |
| 30111 | 5MGRESGA | 15.750 | 10 | 0 | 0      | 200 | 0 |
| 30140 | 5MGRESGB | 15.750 | 11 | 1 | 195.81 | 210 | 0 |
| 30141 | 5MGRESGC | 15.750 | 12 | 0 | 0      | 210 | 0 |
| 30150 | 5MGRESG1 | 15.750 | 1  | 0 | 0      | 80  | 0 |
| 30151 | 5MGRESG2 | 15.750 | 2  | 0 | 0      | 0   | 0 |
| 30197 | 5MGRE3G2 | 10.500 | 2G | 0 | 0      | 27  | 0 |
| 30198 | 5MGRE3G1 | 10.500 | 1G | 1 | 30     | 27  | 0 |
| 38005 | 5KSPP1G5 | 6.3000 | 5  | 1 | 10     | 25  | 0 |
| 38006 | 5KSPP1G6 | 6.3000 | 1  | 1 | 9      | 12  | 0 |
| 38006 | 5KSPP1G6 | 6.3000 | 2  | 1 | 9      | 12  | 0 |
| 38006 | 5KSPP1G6 | 6.3000 | 4  | 1 | 9      | 10  | 0 |
| 38006 | 5KSPP1G6 | 6.3000 | 6  | 1 | 2      | 5   | 0 |
| 38012 | 5BSPP1G  | 10.500 | 4  | 1 | 6      | 8.4 | 0 |
| 38013 | 5BSPP2G  | 6.3000 | 3  | 1 | 9      | 12  | 0 |
| 38022 | 5BALTSG1 | 15.750 | 1  | 1 | 150    | 150 | 0 |
| 38023 | 5BALTSG2 | 15.750 | 3  | 1 | 150    | 150 | 0 |
| 38024 | 5BALTSG3 | 15.750 | 2  | 1 | 150    | 150 | 0 |
| 36056 | 5BURLAG  | 15.750 | 1  | 1 | 50     | 150 | 0 |
| 31008 | 5DONDU5  | 110.00 | 1  | 1 | 6      | 6   | 0 |
| 31009 | 5DROKI5  | 110.00 | 1  | 1 | 6      | 6   | 0 |
| 31010 | 5EDINE5  | 110.00 | 1  | 1 | 12     | 12  | 0 |
| 32018 | 5REZIN5  | 110.00 | 1  | 1 | 6      | 6   | 0 |
| 32027 | 5FALES5  | 110.00 | 1  | 1 | 6      | 6   | 0 |
| 32028 | 5FLORE5  | 110.00 | 1  | 1 | 9      | 9   | 0 |
| 33090 | 5RIBNT52 | 110.00 | 1  | 0 | 0      | 12  | 0 |
| 34017 | 5NANEN5  | 110.00 | 1  | 1 | 15     | 16  | 0 |
| 34022 | 5ORHEI5  | 110.00 | 1  | 1 | 20     | 20  | 0 |
| 34056 | 5SHTEF5  | 110.00 | 1  | 1 | 6      | 6   | 0 |
| 34057 | 5KISHI5  | 110.00 | 1  | 1 | 30     | 30  | 0 |
| 36028 | 5TARAK51 | 110.00 | 1  | 1 | 6      | 6   | 0 |
| 38018 | 5GORBOG  | 6.3000 | 1  | 1 | 4      | 6   | 0 |
| 38018 | 5GORBOG  | 6.3000 | 2  | 0 | 0      | 6   | 0 |

## ROMANIA

Machines are in ascending rank related to delivery price of energy - Regulatory Authority Decision, published in Romanian Official Journal

Table 3.8 – Romania – Generation shifting list

| Price | Bus No | Name     | Pmax | Pmin |
|-------|--------|----------|------|------|
| 1     | 49189  | RP.D.FG1 | 190  | 80   |
| 1     | 49190  | RP.D.FG2 | 190  | 80   |
| 1     | 49191  | RP.D.FG3 | 190  | 80   |
| 1     | 49192  | RP.D.FG4 | 190  | 80   |
| 1     | 49193  | RP.D.FG5 | 190  | 80   |
| 1     | 49250  | RP.D.FG6 | 190  | 80   |
| 1     | 49194  | RGRUIAG2 | 60   | 5.5  |
| 1     | 49195  | RGRUIAG4 | 60   | 5.5  |
| 1     | 49196  | RGRUIAG8 | 60   | 5.5  |
| 1     | 49199  | RGRUIAG6 | 60   | 5.5  |
| 1     | 49232  | RLOTRUG1 | 170  | 20   |
| 1     | 49233  | RLOTRUG2 | 152  | 20   |
| 1     | 49234  | RLOTRUG3 | 152  | 20   |
| 2     | 49218  | RCERNAG1 | 690  | 555  |




|   |       |          |       |       |
|---|-------|----------|-------|-------|
| 2 | 49332 | RCERNAG2 | 690   | 555   |
| 2 | 49470 | RCERNAG3 | 690   | 555   |
| 3 | 49119 | RROVING5 | 287   | 185   |
| 3 | 49120 | RROVING6 | 277   | 185   |
| 3 | 49121 | RROVING3 | 277   | 185   |
| 4 | 49110 | RTURCEG1 | 284   | 174   |
| 4 | 49112 | RTURCEG3 | 285   | 174   |
| 4 | 49113 | RTURCEG4 | 291   | 175   |
| 4 | 49114 | RTURCEG5 | 280   | 174   |
| 4 | 49116 | RTURCEG6 | 280   | 174   |
| 4 | 49117 | RTURCEG7 | 280   | 190   |
| 5 | 49198 | RCRAI G2 | 118   | 70    |
| 5 | 49200 | RCRAI G1 | 118   | 70    |
| 5 | 49184 | RISALNG7 | 277   | 130   |
| 5 | 49185 | RISALNG8 | 290   | 130   |
| 6 | 49167 | RMINTIG1 | 185   | 140   |
| 6 | 49168 | RMINTIG2 | 185   | 140   |
| 6 | 49169 | RMINTIG5 | 185   | 140   |
| 7 | 49221 | RBARBOG5 | 99.8  | 57.1  |
| 7 | 49224 | RBARBOG3 | 100   | 57.1  |
| 7 | 49225 | RSMARDG6 | 99.8  | 57.1  |
| 7 | 49310 | RSMARDG4 | 52.6  | 33.4  |
| 8 | 49136 | RBUC.SG5 | 100   | 60    |
| 8 | 49137 | RBUC.SG6 | 100   | 60    |
| 8 | 49138 | RBUC.SG3 | 100   | 50    |
| 8 | 49139 | RBUC.SG1 | 50    | 30    |
| 8 | 49317 | RBUC.SG2 | 50    | 30    |
| 8 | 49318 | RBUC.SG4 | 100   | 50    |
| 9 | 49201 | RBORZEG7 | 182.4 | 145.9 |
| 9 | 49202 | RBORZEG8 | 173.3 | 145.9 |
| 9 | 49203 | RBORZEG6 | 60    | 37    |
| 9 | 49205 | RBORZEG4 | 50    | 37    |
| 9 | 49206 | RBORZEG5 | 50    | 37    |
| 9 | 49219 | RBRAILG1 | 212   | 110   |
| 9 | 49220 | RBRAILG2 | 188   | 110   |
| 9 | 49299 | RBRAILG3 | 180   | 110   |
| 9 | 49269 | RPAROSG1 | 29    | 12    |
| 9 | 49270 | RPAROSG2 | 34.8  | 12    |
| 9 | 49271 | RPAROSG3 | 29    | 12    |
| 9 | 49263 | RPAROSG4 | 150   | 77    |
| 9 | 49301 | RDOICEG8 | 160   | 90    |
| 9 | 49302 | RDOICEG7 | 160   | 90    |

Obs. Increasing power in Romania machines has to be done from price 1 to price 9 (start from the top of the list),

Decreasing power in Romania machines, has to be done from price 9 to price 1 (start from the bottom of the list),






## RUSSIA

Increasing power in Russian machines has to be done from price 1 to price 4 (start from the top of the list).

Decreasing power in Russian machines has to be done from price 4 to price 1 (start from the bottom of the list).

Table 3.9 – Russia – Generation shifting list

| Price | Bus No | Name            | Pmax | Pmin |
|-------|--------|-----------------|------|------|
| 1     | 51420  | 4VGGESG7 13.800 | 115  | 3    |
| 1     | 51421  | 4VGGESG8 13.800 | 115  | 3    |
| 1     | 51422  | 4VGGESG9 13.800 | 115  | 3    |
| 1     | 51423  | 4VGGESG0 13.800 | 115  | 3    |
| 1     | 51424  | 4VGGESGA 13.800 | 115  | 3    |
| 1     | 51425  | 4VGGESGB 13.800 | 115  | 3    |
| 1     | 51426  | 4VGGESGG 13.800 | 115  | 3    |
| 1     | 51427  | 4VGGESGH 13.800 | 115  | 3    |
| 1     | 51428  | 4VGGESGI 13.800 | 115  | 3    |
| 1     | 51429  | 4VGGESGJ 13.800 | 115  | 3    |
| 1     | 51430  | 4VGGESGK 13.800 | 115  | 3    |
| 1     | 51431  | 4VGGESGL 13.800 | 115  | 3    |
| 1     | 51432  | 4VGG34G 13.800  | 115  | 3    |
| 1     | 51432  | 4VGG34G 13.800  | 115  | 3    |
| 1     | 51433  | 4VGG56G 13.800  | 115  | 3    |
| 1     | 51433  | 4VGG56G 13.800  | 115  | 3    |
| 1     | 51434  | 4VGG13G 13.800  | 115  | 3    |
| 1     | 51434  | 4VGG13G 13.800  | 115  | 3    |
| 1     | 51435  | 4VGG15G 13.800  | 115  | 3    |
| 1     | 51435  | 4VGG15G 13.800  | 115  | 3    |
| 1     | 58744  | 4CHGESG3        | 250  | 50   |
| 1     | 58745  | 4CHGESG1        | 250  | 50   |
| 1     | 58746  | 4CHGESG2        | 250  | 50   |
| 1     | 58747  | 4CHGESG4        | 250  | 50   |
| 2     | 58311  | 4NEVGRG1        | 150  | 80   |
| 2     | 58387  | 4NEVGRG2        | 150  | 80   |
| 2     | 58388  | 4NEVGRG3        | 150  | 80   |
| 2     | 58389  | 4NEVGRG4        | 150  | 80   |
| 2     | 58314  | 4NEVGRG5        | 100  | 70   |
| 2     | 58385  | 4NEVGRG6        | 150  | 80   |
| 2     | 58386  | 4NEVGRG7        | 150  | 80   |
| 2     | 58390  | 4NEVGRG8        | 150  | 130  |
| 2     | 51462  | 4KAES2G3 20.000 | 500  | 300  |
| 2     | 51463  | 4KAES2G4 20.000 | 500  | 300  |
| 3     | 58301  | 4STGRSG1        | 300  | 150  |
| 3     | 58380  | 4STGRSG2        | 300  | 150  |
| 3     | 58381  | 4STGRSG3        | 300  | 150  |
| 3     | 58382  | 4STGRSG4        | 300  | 150  |
| 3     | 58383  | 4STGRSG5        | 300  | 150  |
| 3     | 58384  | 4STGRSG6        | 300  | 150  |
| 3     | 58358  | 4STGRSG7        | 300  | 150  |
| 3     | 58359  | 4STGRSG8        | 300  | 150  |



|   |       |          |        |     |     |
|---|-------|----------|--------|-----|-----|
| 3 | 51400 | 4RGRESG4 | 20.000 | 300 | 150 |
| 3 | 51401 | 4RGRESG5 | 24.000 | 800 | 400 |
| 3 | 51402 | 4RGRESG6 | 24.000 | 800 | 400 |
| 3 | 51403 | 4RGRESG7 | 20.000 | 300 | 150 |
| 3 | 51404 | 4RGRESG1 | 20.000 | 300 | 150 |
| 3 | 51405 | 4RGRESG2 | 20.000 | 300 | 150 |
| 3 | 51406 | 4RGRESG3 | 20.000 | 300 | 150 |
| 4 | 58149 | 4NCHGRG1 |        | 264 | 200 |
| 4 | 58183 | 4NCHGRG2 |        | 264 | 225 |
| 4 | 58184 | 4NCHGRG3 |        | 264 | 200 |
| 4 | 58185 | 4NCHGRG4 |        | 264 | 225 |
| 4 | 58186 | 4NCHGRG5 |        | 264 | 225 |
| 4 | 58187 | 4NCHGRG6 |        | 264 | 225 |
| 4 | 58195 | 4NCHGRG7 |        | 264 | 225 |
| 4 | 58196 | 4NCHGRG8 |        | 264 | 225 |

## TURKEY

The shift list prepared for 1200 MW energy transfer in both directions according to the imp./exp.scenario of Turkey for 2010.

Table 3.10 – Turkey – Generation shifting list for RO to TR

| EXPORT        |          |               |           |
|---------------|----------|---------------|-----------|
| Summer        |          |               |           |
| Bus Number    | Bus name | Shift         | ID        |
| 60801         | G-4HAMIT | 100           | 1         |
| 60801         | G-4HAMIT | 100           | 2         |
| 60801         | G-4HAMIT | 111,5         | 3         |
| 60843         | G-4AMBR  | 138,8         | 1         |
| 60843         | G-4AMBR  | 138,8         | 2         |
| 60844         | G-4AMBR  | 172,8         | 1         |
| 60903         | G-4TUNC  | 159,8         | 1         |
| 60908         | G-TUNC B | 159,8         | 1         |
| 60909         | G-TUNC A | 65,6          | 1         |
| 60929         | G-4SOMA  | 165           | 1         |
| 60929         | G-4SOMA  | 165           | 2         |
| <b>TOTAL:</b> |          | <b>1477,1</b> | <b>MW</b> |
| Winter        |          |               |           |
| Bus Number    | Bus name | Shift         | ID        |
| 60805         | G-4HAMIT | 100           | 7         |
| 60805         | G-4HAMIT | 100           | 8         |
| 60805         | G-4HAMIT | 111,5         | 9         |
| 60848         | G-4AMBR  | 138,8         | 1         |
| 60848         | G-4AMBR  | 138,8         | 2         |
| 60849         | G-4AMBR  | 172,8         | 1         |
| 60935         | G-4SOMA  | 165           | 6         |
| 60945         | G-4YATAG | 210           | 3         |
| 60913         | G-SEYITO | 159,8         | 1         |
| 60931         | G-ALIDG  | 36            | 1         |
| 60931         | G-ALIDG  | 36            | 2         |
| 60931         | G-ALIDG  | 31            | 3         |
| <b>TOTAL:</b> |          | <b>1399,7</b> | <b>MW</b> |





Table 3.11 - Turkey – Generation shifting list for TR to RO

| <b>IMPORT</b>     |                 |                |           |
|-------------------|-----------------|----------------|-----------|
| <b>Summer</b>     |                 |                |           |
| <b>Bus Number</b> | <b>Bus name</b> | <b>Shift</b>   | <b>ID</b> |
| 60801             | G-4HAMIT        | -100,3         | 6         |
| 60801             | G-4HAMIT        | -111,5         | A         |
| 60847             | G-AMB2B         | -124,9         | 1         |
| 60848             | G-AMB2B         | -155,5         | 1         |
| 60922             | G-4ALIB         | -221,1         | 1         |
| 60922             | G-4ALIB         | -221,1         | 2         |
| 60923             | G-4ALIB         | -240,2         | 1         |
| 60852             | G-AMBFO         | -150           | 1         |
| <b>TOTAL:</b>     |                 | <b>-1324,6</b> | <b>MW</b> |
| <b>Winter</b>     |                 |                |           |
| <b>Bus Number</b> | <b>Bus name</b> | <b>Shift</b>   | <b>ID</b> |
| 60805             | G-4HAMIT        | -90            | 1         |
| 60805             | G-4HAMIT        | -90            | 2         |
| 60805             | G-4HAMIT        | -100,3         | 3         |
| 60850             | G-4HABIP        | -143           | 1         |
| 60850             | G-4HABIP        | -143           | 2         |
| 60850             | G-4HABIP        | -155           | 3         |
| 60851             | G-4AMB2A        | -124,9         | 1         |
| 60851             | G-4AMB2A        | -124,9         | 2         |
| 60852             | G-4AMB2A        | -155,5         | 1         |
| 60909             | G-4TUNC         | -143,8         | 1         |
| 60914             | G-TUNC B        | -143,8         | 1         |
| <b>TOTAL:</b>     |                 | <b>-1414,2</b> | <b>MW</b> |

The shift list prepared for 1200 MW energy transfer in both directions according to the imp./exp.scenario of Turkey for 2010.

Table 3.12 - Turkey – Generation shifting list for TR to UCTE

| <b>EXPORT</b>     |                 |               |           |
|-------------------|-----------------|---------------|-----------|
| <b>Summer</b>     |                 |               |           |
| <b>Bus Number</b> | <b>Bus name</b> | <b>Shift</b>  | <b>ID</b> |
| 60801             | G-4HAMIT        | 100           | 1         |
| 60801             | G-4HAMIT        | 100           | 2         |
| 60801             | G-4HAMIT        | 111,5         | 3         |
| 60843             | G-4AMBR         | 138,8         | 1         |
| 60843             | G-4AMBR         | 138,8         | 2         |
| 60844             | G-4AMBR         | 172,8         | 1         |
| 60903             | G-4TUNC         | 159,8         | 1         |
| 60908             | G-TUNC B        | 159,8         | 1         |
| 60909             | G-TUNC A        | 65,6          | 1         |
| 60929             | G-4SOMA         | 165           | 1         |
| 60929             | G-4SOMA         | 165           | 2         |
| <b>TOTAL:</b>     |                 | <b>1477,1</b> | <b>MW</b> |
| <b>Winter</b>     |                 |               |           |
| <b>Bus Number</b> | <b>Bus name</b> | <b>Shift</b>  | <b>ID</b> |
| 60805             | G-4HAMIT        | 100           | 7         |
| 60805             | G-4HAMIT        | 100           | 8         |
| 60805             | G-4HAMIT        | 111,5         | 9         |



|               |          |               |           |
|---------------|----------|---------------|-----------|
| 60848         | G-4AMBR  | 138,8         | 1         |
| 60848         | G-4AMBR  | 138,8         | 2         |
| 60849         | G-4AMBR  | 172,8         | 1         |
| 60935         | G-4SOMA  | 165           | 6         |
| 60945         | G-4YATAG | 210           | 3         |
| 60913         | G-SEYITO | 159,8         | 1         |
| 60931         | G-ALIDG  | 36            | 1         |
| 60931         | G-ALIDG  | 36            | 2         |
| 60931         | G-ALIDG  | 31            | 3         |
| <b>TOTAL:</b> |          | <b>1399,7</b> | <b>MW</b> |


Table 3.13 - Turkey – Generation shifting list for UCTE to TR

| <b>IMPORT</b>     |                 |                |           |
|-------------------|-----------------|----------------|-----------|
| <b>Summer</b>     |                 |                |           |
| <b>Bus Number</b> | <b>Bus name</b> | <b>Shift</b>   | <b>ID</b> |
| 60801             | G-4HAMIT        | -100,3         | 6         |
| 60801             | G-4HAMIT        | -111,5         | A         |
| 60847             | G-AMB2B         | -124,9         | 1         |
| 60848             | G-AMB2B         | -155,5         | 1         |
| 60922             | G-4ALIB         | -221,1         | 1         |
| 60922             | G-4ALIB         | -221,1         | 2         |
| 60923             | G-4ALIB         | -240,2         | 1         |
| 60852             | G-AMBFO         | -150           | 1         |
| <b>TOTAL:</b>     |                 | <b>-1324,6</b> | <b>MW</b> |
| <b>Winter</b>     |                 |                |           |
| <b>Bus Number</b> | <b>Bus name</b> | <b>Shift</b>   | <b>ID</b> |
| 60805             | G-4HAMIT        | -90            | 1         |
| 60805             | G-4HAMIT        | -90            | 2         |
| 60805             | G-4HAMIT        | -100,3         | 3         |
| 60850             | G-4HABIP        | -143           | 1         |
| 60850             | G-4HABIP        | -143           | 2         |
| 60850             | G-4HABIP        | -155           | 3         |
| 60851             | G-4AMB2A        | -124,9         | 1         |
| 60851             | G-4AMB2A        | -124,9         | 2         |
| 60852             | G-4AMB2A        | -155,5         | 1         |
| 60909             | G-4TUNC         | -143,8         | 1         |
| 60914             | G-TUNC B        | -143,8         | 1         |
| <b>TOTAL:</b>     |                 | <b>-1414,2</b> | <b>MW</b> |

The shift list prepared for 650 MW energy transfer in both directions according to the imp./exp.scenario of Turkey for 2010.

Table 3.14 - Turkey – Generation shifting list for TR to RU

| <b>EXPORT</b>     |                 |              |           |
|-------------------|-----------------|--------------|-----------|
| <b>Summer</b>     |                 |              |           |
| <b>Bus Number</b> | <b>Bus name</b> | <b>Shift</b> | <b>ID</b> |
| 61036             | G-4BORCK        | 138          | 2         |
| 61037             | G-4DERIN        | 167,4        | 2         |
| 61037             | G-4DERIN        | 167,4        | 3         |
| 61038             | G-4MURATL       | 58,8         | 1         |
| 61038             | G-4MURATL       | 58,8         | 2         |
| 61057             | G-4KEBAN        | 157,5        | 4         |
| <b>TOTAL:</b>     |                 | <b>747,9</b> | <b>MW</b> |
| <b>Winter</b>     |                 |              |           |



| Bus Number    | Bus name | Shift      | ID        |
|---------------|----------|------------|-----------|
| 61062         | G-4KARAK | 300        | 5         |
| 61062         | G-4KARAK | 300        | 6         |
| 61059         | G-4ATATU | 300        | 4         |
| <b>TOTAL:</b> |          | <b>900</b> | <b>MW</b> |


Table 3.15 - Turkey – Generation shifting list for RU to TR

| <b>IMPORT</b> |          |               |           |
|---------------|----------|---------------|-----------|
| <b>Summer</b> |          |               |           |
| Bus Number    | Bus name | Shift         | ID        |
| 61036         | G-4BORCK | -138          | 1         |
| 61062         | G-4KARAK | -270          | 3         |
| 61062         | G-4KARAK | -270          | 4         |
| 61044         | G-4ATATU | -270          | 4         |
| <b>TOTAL:</b> |          | <b>-948</b>   | <b>MW</b> |
| <b>Winter</b> |          |               |           |
| Bus Number    | Bus name | Shift         | ID        |
| 61050         | G-4BORCK | -138          | 1         |
| 61050         | G-4BORCK | -138          | 2         |
| 61062         | G-4KARAK | -270          | 3         |
| 61072         | G-4KEBAN | -162,9        | 7         |
| <b>TOTAL:</b> |          | <b>-708,9</b> | <b>MW</b> |

## UKRAINE

Table 3.16 - Ukraine – Generation shifting list for UA to CE Winter

| Node  | Order | P <sub>basecase</sub> | DP+  |
|-------|-------|-----------------------|------|
|       |       | [MW]                  | [MW] |
| 79918 | 1     | 81                    | 110  |
| 79917 | 2     | 130                   | 15   |
| 79916 | 3     | 130                   | 30   |
| 79915 | 4     | 130                   | 15   |
| 79914 | 5     | 130                   | 5    |
| 79909 | 6     | 130                   | 15   |
| 79926 | 7     | 140                   | 10   |
| 79919 | 8     | 0                     | 160  |
| 79913 | 9     | 0                     | 190  |
| 79911 | 10    | 0                     | 190  |
| 79904 | 11    | 210                   | 10   |
| 79927 | 12    | 0                     | 150  |
| 79826 | 13    | 0                     | 240  |
| 79903 | 14    | 210                   | 10   |
| 79827 | 15    | 0                     | 240  |
| 79902 | 16    | 210                   | 10   |
| 79823 | 17    | 0                     | 240  |
| 79901 | 18    | 210                   | 10   |
| 70806 | 19    | 117                   | 100  |
| 70805 | 20    | 260                   | 200  |
| 79700 | 21    | 108                   | 2    |
| 79701 | 22    | 108                   | 2    |
| 79707 | 23    | 245                   | 10   |
| 79719 | 24    | 240                   | 16   |
| 79722 | 25    | 250                   | 10   |
| 79723 | 26    | 250                   | 10   |
| 79720 | 27    | 140                   | 150  |



|       |    |     |      |
|-------|----|-----|------|
| 79724 | 28 | 140 | 150  |
| 79725 | 29 | 140 | 150  |
| 79726 | 30 | 240 | 60   |
| 79727 | 31 | 230 | 70   |
| 79728 | 32 | 230 | 70   |
| 79321 | 33 | 0   | 300  |
| 79345 | 34 | 217 | 50   |
| TOTAL |    |     | 3000 |

Table 3.17 - Ukraine – Generation shifting list for CE to UA Winter


| Node  | Order | P <sub>basecase</sub> | DP+   |
|-------|-------|-----------------------|-------|
|       |       | [MW]                  | [MW]  |
| 79908 | 1     | 200                   | -200  |
| 79909 | 2     | 130                   | -130  |
| 79914 | 3     | 130                   | -130  |
| 79915 | 4     | 130                   | -130  |
| 79916 | 5     | 130                   | -130  |
| 79917 | 6     | 130                   | -130  |
| 79900 | 7     | 116                   | -10   |
| 79927 | 8     | 140                   | -140  |
| 79900 | 9     | 1000                  | -1000 |
| 79808 | 10    | 1000                  | -1000 |
| TOTAL |       |                       | -3000 |

Table 3.18 - Ukraine – Generation shifting list for UA to CE Summer

| Node  | Order | P <sub>basecase</sub> | DP+  |
|-------|-------|-----------------------|------|
|       |       | [MW]                  | [MW] |
| 79009 | 1     | 0                     | 290  |
| 79180 | 2     | 280                   | 10   |
| 79010 | 3     | 0                     | 290  |
| 79181 | 4     | 0                     | 290  |
| 79133 | 5     | 80                    | 70   |
| 79134 | 6     | 0                     | 150  |
| 79135 | 7     | 0                     | 150  |
| 79136 | 8     | 0                     | 150  |
| 79137 | 9     | 0                     | 150  |
| 79174 | 10    | 0                     | 750  |
| 79170 | 11    | 212.5                 | 50   |
| 79171 | 12    | 212.5                 | 50   |
| 79172 | 13    | 212.5                 | 50   |
| 79173 | 14    | 212.5                 | 50   |
| 79159 | 15    | 0                     | 500  |
| TOTAL |       |                       | 3000 |

Table 3.19 - Ukraine – Generation shifting list for CE to UA Summer

| Node     | Order | P <sub>basecase</sub> | DP+    |
|----------|-------|-----------------------|--------|
|          |       | [MW]                  | [MW]   |
| 79101    | 1     | 170                   | -170   |
| 79102    | 2     | 170                   | -30    |
| 79130(4) | 3     | 150                   | -150   |
| 79130(5) | 4     | 150                   | -150   |
| 79170    | 5     | 212.5                 | -12.5  |
| 79171    | 6     | 212.5                 | -12.5  |
| 79172    | 7     | 212.5                 | -212.5 |
| 79173    | 8     | 212.5                 | -212.5 |
| 79179    | 9     | 800                   | -800   |
| 79009    | 10    | 0                     | 250    |



|       |    |     |       |
|-------|----|-----|-------|
| 79140 | 11 | 200 | -200  |
| 79143 | 12 | 200 | -200  |
| 79144 | 13 | 200 | -200  |
| 79309 | 14 | 800 | -800  |
| 79338 | 15 | 700 | -100  |
| TOTAL |    |     | -3000 |

Table 3.20 - Ukraine – Generation shifting list for UA to SEE Winter


| Node  | Order | P <sub>basecase</sub> | DP+  |
|-------|-------|-----------------------|------|
|       |       | [MW]                  | [MW] |
| 79908 | 1     | 0                     | 200  |
| 79910 | 2     | 0                     | 200  |
| 79912 | 3     | 0                     | 200  |
| 79911 | 4     | 0                     | 190  |
| 79913 | 5     | 0                     | 190  |
| 79909 | 6     | 130                   | 10   |
| 79915 | 7     | 130                   | 10   |
| 79918 | 8     | 61                    | 100  |
| 79919 | 9     | 0                     | 150  |
| 79926 | 10    | 0                     | 150  |
| 79927 | 11    | 0                     | 150  |
| 79900 | 12    | 0                     | 1000 |
| 79808 | 13    | 950                   | 50   |
| 79825 | 14    | 0                     | 250  |
| 79826 | 15    | 0                     | 150  |
| TOTAL |       |                       | 3000 |

Table 3.21 - Ukraine – Generation shifting list for SEE to UA Winter

| Node  | Order | P <sub>basecase</sub> | DP+   |
|-------|-------|-----------------------|-------|
|       |       | [MW]                  | [MW]  |
| 79914 | 1     | 130                   | -130  |
| 79915 | 2     | 130                   | -130  |
| 79916 | 3     | 130                   | -130  |
| 79917 | 4     | 130                   | -10   |
| 79985 | 5     | 1000                  | -1000 |
| 79808 | 6     | 1000                  | -1000 |
| 79719 | 7     | 200                   | -200  |
| 79599 | 8     | 1000                  | -200  |
| 79520 | 9     | 1000                  | -200  |
| TOTAL |       |                       | -3000 |

Table 3.22 - Ukraine – Generation shifting list for UA to SEE Summer

| Node  | Order | P <sub>basecase</sub> | DP+  |
|-------|-------|-----------------------|------|
|       |       | [MW]                  | [MW] |
| 79009 | 1     | 230                   | 50   |
| 79010 | 2     | 230                   | 50   |
| 79180 | 3     | 0                     | 250  |
| 79181 | 4     | 0                     | 250  |
| 79172 | 5     | 0                     | 250  |
| 79173 | 6     | 0                     | 250  |
| 79141 | 7     | 0                     | 200  |
| 79142 | 8     | 0                     | 200  |
| 79144 | 9     | 0                     | 200  |
| 79132 | 10    | 0                     | 150  |
| 79133 | 11    | 0                     | 150  |
| 79134 | 12    | 0                     | 150  |
| 79135 | 13    | 0                     | 150  |



|       |    |   |      |
|-------|----|---|------|
| 79136 | 14 | 0 | 150  |
| 79103 | 15 | 0 | 150  |
| 79104 | 16 | 0 | 150  |
| 79105 | 17 | 0 | 150  |
| 79106 | 18 | 0 | 100  |
| TOTAL |    |   | 3000 |

Table 3.23 - Ukraine – Generation shifting list for SEE to UA Summer

| Node  | Order | P <sub>basecase</sub> | DP+   |
|-------|-------|-----------------------|-------|
|       |       | [MW]                  | [MW]  |
| 79313 | 1     | 1000                  | -1000 |
| 79599 | 2     | 1000                  | -1000 |
| 79808 | 3     | 1000                  | -1000 |
| TOTAL |       |                       | -3000 |

## EQUIVALENT

For the purpose of modeling additional exchanges, following loads are added to the BSR model

Table 3.24

| BUS#  | BUS NAME | VOLT. | ID | AREA | AREA NAME |
|-------|----------|-------|----|------|-----------|
| 80001 | ZRZE421  | 400   | EQ | 12   | PL        |
| 80004 | ZZAM212  | 220   | EQ | 12   | PL        |
| 80054 | QVKAP_1  | 400   | EQ | 11   | SK        |
| 80109 | JRPMLA1  | 400   | EQ | 13   | CS        |
| 80113 | JTKOSB1  | 400   | EQ | 13   | CS        |
| 80151 | MAISA 1  | 400   | EQ | 15   | HU        |
| 80154 | MGOD 1   | 400   | EQ | 15   | HU        |
| 80255 | GAGDHM1  | 400   | EQ | 17   | GR        |
| 80256 | GKADIA1  | 400   | EQ | 17   | GR        |

Table 3.25

### FROM UCTE TO TURKEY

| BUS#  | BUS NAME | VOLT. | ID | AREA | AREA NAME | %   |
|-------|----------|-------|----|------|-----------|-----|
| 80001 | ZRZE421  | 400   | EQ | 12   | PL        | 20% |
| 80054 | QVKAP_1  | 400   | EQ | 11   | SK        | 20% |
| 80113 | JTKOSB1  | 400   | EQ | 13   | CS        | 60% |

### FROM UKRAIN AND RUSSIA TO SEE AND VS


| BUS#  | BUS NAME | VOLT. | ID | AREA | AREA NAME | %   |
|-------|----------|-------|----|------|-----------|-----|
| 80001 | ZRZE421  | 400   | EQ | 12   | PL        | 15% |
| 80151 | MAISA 1  | 400   | EQ | 15   | HU        | 10% |
| 80255 | GAGDHM1  | 400   | EQ | 17   | GR        | 40% |
| 80256 | GKADIA1  | 400   | EQ | 17   | GR        | 35% |

### FROM UKRAIN AND RUSSIA TO WEST EUROPE AND VS

| BUS#  | BUS NAME | VOLT. | ID | AREA | AREA NAME | %   |
|-------|----------|-------|----|------|-----------|-----|
| 80001 | ZRZE421  | 400   | EQ | 12   | PL        | 40% |
| 80004 | ZZAM212  | 220   | EQ | 12   | PL        | 5%  |
| 80054 | QVKAP_1  | 400   | EQ | 11   | SK        | 10% |
| 80113 | JTKOSB1  | 400   | EQ | 13   | CS        | 15% |
| 80151 | MAISA 1  | 400   | EQ | 15   | HU        | 30% |

%-percentage of total additional exchange  
to be modeled in marked bus as load






## 4. ANALISES RESULTS

### 4.1. Model summary

#### BLACK SEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

#### AREA TOTALS IN MW/MVAR


| X--    | AREA | --X | FROM<br>GENERATION | TO<br>LOAD | TO BUS<br>SHUNT | TO LINE<br>SHUNT | FROM<br>CHARGING | TO<br>NET INT | LOSSES  | DESIRED<br>NET INT |
|--------|------|-----|--------------------|------------|-----------------|------------------|------------------|---------------|---------|--------------------|
|        | 1    |     | 8023.0             | 7854.0     | 0.0             | 14.3             | 0.0              | 0.0           | 154.7   | 0.0                |
| BG     |      |     | 2800.6             | 2791.1     | 0.0             | 119.6            | 2275.2           | 89.1          | 2076.0  |                    |
|        | 2    |     | 2006.0             | 2057.0     | 0.0             | 106.6            | 0.0              | -200.0        | 42.4    | -200.0             |
| GE     |      |     | 428.8              | 1038.0     | 0.0             | -106.6           | 847.5            | -85.9         | 430.8   |                    |
|        | 3    |     | 1523.4             | 1188.1     | 0.0             | 0.0              | 0.0              | 300.0         | 35.4    | 300.0              |
| MD     |      |     | 329.7              | 503.1      | 0.0             | 0.0              | 509.7            | 77.3          | 259.0   |                    |
|        | 4    |     | 9868.9             | 9534.1     | 0.0             | 86.0             | 0.0              | 50.0          | 198.7   | 50.0               |
| RO     |      |     | 3207.4             | 3574.7     | 1259.5          | 274.9            | 4496.3           | 263.9         | 2330.7  |                    |
|        | 5    |     | 19199.3            | 16903.7    | 21.5            | 15.9             | 0.0              | 1550.0        | 708.2   | 1550.0             |
| RU     |      |     | 15961.4            | 16218.9    | 4101.2          | 122.4            | 11626.2          | 416.5         | 6728.7  |                    |
|        | 6    |     | 33598.5            | 33209.2    | 0.1             | 0.0              | 0.0              | -150.0        | 539.2   | -150.0             |
| TR     |      |     | 6329.6             | 5452.0     | 1663.7          | 0.0              | 8947.0           | -206.2        | 8367.1  |                    |
|        | 7    |     | 32610.2            | 30515.5    | 9.8             | 70.6             | 0.0              | 1250.1        | 764.2   | 1250.0             |
| UA     |      |     | 10992.8            | 10050.9    | 7876.2          | 703.3            | 16307.6          | -698.3        | 9368.3  |                    |
|        | 8    |     | 2390.8             | 930.6      | 0.0             | 0.0              | 0.0              | 1400.0        | 60.2    | 1400.0             |
| AM     |      |     | 316.4              | 309.5      | 0.0             | 0.0              | 658.7            | 182.5         | 483.1   |                    |
|        | 9    |     | 0.0                | 217.2      | 0.0             | 0.0              | 0.0              | -220.0        | 2.8     | -220.0             |
| AZ     |      |     | 0.0                | 30.0       | 0.0             | 0.0              | 36.6             | -10.1         | 16.7    |                    |
|        | 10   |     | 6009.7             | 6961.3     | 9.5             | 0.5              | 0.0              | -1000.0       | 38.4    | -1000.0            |
| BY     |      |     | 1551.6             | 1626.4     | 597.6           | 2.1              | 1099.9           | 86.5          | 338.8   |                    |
|        | 11   |     | 6.7                | 277.0      | 0.0             | 0.0              | 0.0              | -280.0        | 9.7     | -280.0             |
| SK     |      |     | 144.0              | -22.0      | 0.0             | 0.0              | 396.2            | 458.8         | 103.4   |                    |
|        | 12   |     | -187.7             | -358.3     | 0.0             | 0.0              | 0.0              | 159.9         | 10.8    | 160.0              |
| PL     |      |     | -404.7             | 251.6      | 0.0             | 2.3              | 626.4            | -174.6        | 142.4   |                    |
|        | 13   |     | 1.3                | 494.8      | 0.0             | 0.0              | 0.0              | -530.0        | 36.4    | -530.0             |
| CS     |      |     | -9.8               | 777.6      | 0.0             | 0.0              | 867.2            | -343.4        | 423.2   |                    |
|        | 15   |     | 1578.7             | 2287.6     | 0.0             | 0.0              | 0.0              | -730.0        | 21.1    | -730.0             |
| HU     |      |     | -27.4              | 801.4      | 573.2           | 2.6              | 1568.7           | -135.1        | 299.1   |                    |
|        | 16   |     | 2.5                | 100.5      | 0.0             | 0.0              | 0.0              | -100.0        | 2.0     | -100.0             |
| MK     |      |     | -51.7              | 299.3      | 0.0             | 0.0              | 302.5            | -70.7         | 22.2    |                    |
|        | 17   |     | -5.7               | 286.2      | 0.0             | 0.0              | 0.0              | -300.0        | 8.1     | -300.0             |
| GR     |      |     | 93.8               | 750.0      | 0.0             | 0.0              | 933.3            | 192.3         | 84.7    |                    |
|        | 18   |     | 12.5               | 1200.0     | 0.0             | 0.2              | 0.0              | -1200.0       | 12.3    | -1200.0            |
| IR     |      |     | -42.2              | 45.2       | 0.0             | 0.5              | 122.8            | -42.7         | 77.5    |                    |
| TOTALS |      |     | 116638.2           | 113658.5   | 41.0            | 294.1            | 0.0              | 0.0           | 2644.6  | 0.0                |
|        |      |     | 41620.2            | 44497.9    | 16071.4         | 1121.1           | 51621.8          | 0.0           | 31551.6 |                    |



**BLACKSEA REGIONAL MODEL  
SUMMER MINIMUM LOAD 2010**


**AREA TOTALS  
IN MW/MVAR**

| X--           | AREA | --X | FROM<br>GENERATION | TO<br>LOAD     | TO BUS<br>SHUNT | TO LINE<br>SHUNT | FROM<br>CHARGING | TO<br>NET INT | LOSSES         | DESIRED<br>NET INT |
|---------------|------|-----|--------------------|----------------|-----------------|------------------|------------------|---------------|----------------|--------------------|
| 1             |      |     | 3020.4             | 2958.1         | 0.0             | 12.4             | 0.0              | 0.0           | 49.9           | 0.0                |
| BG            |      |     | 507.7              | 1096.8         | 903.6           | 91.2             | 2345.0           | 62.1          | 698.9          |                    |
| 2             |      |     | 1063.9             | 713.0          | 0.0             | 127.9            | 0.0              | 200.3         | 22.7           | 200.0              |
| GE            |      |     | 139.3              | 497.0          | 529.6           | -127.9           | 865.8            | -118.5        | 224.8          |                    |
| 3             |      |     | 1203.3             | 888.0          | 0.0             | 0.0              | 0.0              | 300.0         | 15.4           | 300.0              |
| MD            |      |     | 27.7               | 375.3          | 0.0             | 0.0              | 553.2            | 75.5          | 130.1          |                    |
| 4             |      |     | 4126.2             | 3936.2         | 0.0             | 80.9             | 0.0              | 49.9          | 59.2           | 50.0               |
| RO            |      |     | 595.9              | 1944.6         | 2108.3          | 247.3            | 4526.1           | 3.3           | 818.6          |                    |
| 5             |      |     | 13430.7            | 11601.7        | 22.6            | 15.3             | 0.0              | 1550.0        | 241.1          | 1550.0             |
| RU            |      |     | 1732.6             | 5478.2         | 5443.1          | 101.7            | 12175.3          | 260.0         | 2624.8         |                    |
| 6             |      |     | 18695.7            | 19114.0        | -3.2            | 0.0              | 0.0              | -649.6        | 234.6          | -650.0             |
| TR            |      |     | 1571.3             | 2725.1         | 3807.5          | 0.0              | 8881.4           | -205.4        | 4125.6         |                    |
| 7             |      |     | 16928.2            | 15366.6        | 9.1             | 68.8             | 0.0              | 1149.5        | 334.1          | 1150.0             |
| UA            |      |     | 4937.3             | 7406.6         | 8832.5          | 645.9            | 16595.4          | -345.0        | 4992.7         |                    |
| 8             |      |     | 1937.2             | 480.6          | 0.0             | 0.0              | 0.0              | 1400.1        | 56.5           | 1400.0             |
| AM            |      |     | 339.2              | 357.5          | 0.0             | 0.0              | 641.6            | 192.7         | 430.6          |                    |
| 9             |      |     | 0.0                | 65.0           | 0.0             | 0.0              | 0.0              | -65.2         | 0.2            | 0.0                |
| AZ            |      |     | 0.0                | 30.0           | 0.0             | 0.0              | 46.7             | 15.6          | 1.2            |                    |
| 10            |      |     | 6010.1             | 6961.3         | 9.5             | 0.5              | 0.0              | -1000.0       | 38.7           | -1000.0            |
| BY            |      |     | 1408.5             | 1626.4         | 598.4           | 2.1              | 1167.1           | 26.5          | 322.1          |                    |
| 11            |      |     | 2.8                | 477.0          | 0.0             | 0.0              | 0.0              | -480.2        | 6.0            | -480.0             |
| SK            |      |     | 148.0              | 238.0          | 0.0             | 0.0              | 411.7            | 257.7         | 64.0           |                    |
| 12            |      |     | -249.4             | -301.7         | 0.0             | 0.0              | 0.0              | 45.2          | 7.1            | -20.0              |
| PL            |      |     | -380.0             | 196.7          | 0.0             | 2.4              | 640.2            | -55.5         | 116.7          |                    |
| 13            |      |     | 16.7               | 71.8           | 0.0             | 0.0              | 0.0              | -70.0         | 14.9           | -70.0              |
| CS            |      |     | -242.1             | 703.1          | 0.0             | 0.0              | 940.5            | -177.6        | 173.0          |                    |
| 15            |      |     | 7.2                | 559.3          | 0.0             | 0.0              | 0.0              | -570.0        | 17.9           | -570.0             |
| HU            |      |     | 15.1               | 830.0          | 539.0           | 1.5              | 1557.0           | -86.6         | 288.1          |                    |
| 16            |      |     | -1.5               | 97.6           | 0.0             | 0.0              | 0.0              | -100.0        | 1.0            | -100.0             |
| MK            |      |     | -16.4              | 211.9          | 0.0             | 0.0              | 318.0            | 78.9          | 10.8           |                    |
| 17            |      |     | -3.1               | 548.1          | 0.0             | 0.0              | 0.0              | -560.0        | 8.8            | -560.0             |
| GR            |      |     | 160.8              | 943.2          | 0.0             | 0.0              | 947.1            | 69.2          | 95.6           |                    |
| 18            |      |     | 12.1               | 1200.0         | 0.0             | 0.2              | 0.0              | -1200.0       | 11.9           | -1200.0            |
| IR            |      |     | -51.6              | 45.2           | 0.0             | 0.5              | 120.7            | -52.8         | 76.1           |                    |
| <b>TOTALS</b> |      |     | <b>66200.5</b>     | <b>64736.6</b> | <b>38.0</b>     | <b>305.9</b>     | <b>0.0</b>       | <b>0.0</b>    | <b>1120.0</b>  | <b>0.0</b>         |
|               |      |     | <b>10893.2</b>     | <b>24705.5</b> | <b>22762.2</b>  | <b>964.7</b>     | <b>52732.7</b>   | <b>0.0</b>    | <b>15193.6</b> |                    |




## 4.2. Area interchange

| BLACK SEA REGIONAL MODEL |    |     |      |      |      |      |      |      |       | AREA        |      |      |      |     |      |     |      |      |  |
|--------------------------|----|-----|------|------|------|------|------|------|-------|-------------|------|------|------|-----|------|-----|------|------|--|
| WINTER MAXIMUM LOAD 2010 |    |     |      |      |      |      |      |      |       | INTERCHANGE |      |      |      |     |      |     |      |      |  |
| TO AREA:                 |    | 1   | 2    | 3    | 4    | 5    | 6    | 7    | 8     | 10          | 11   | 12   | 13   | 15  | 16   | 17  | 18   | 19   |  |
| FROM AREA                | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| BG                       | 1  | *   |      |      | -900 |      | 233  |      |       |             |      |      |      | 162 |      | 155 | 350  |      |  |
|                          | *  |     |      | -37  |      |      | 75   |      |       |             |      |      |      | 62  |      | -11 | 1    |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| GE                       | 2  | *   |      |      |      | 280  | -266 |      | -214  | 0           |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      | -33  | 56   |      | -109  | 0           |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| MD                       | 3  | *   |      |      | 486  |      |      | -186 |       |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      | -84  |      |      | 161  |       |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| RO                       | 4  | *   | 900  |      | -486 |      |      | -402 |       |             |      |      |      | 190 | -153 |     |      |      |  |
|                          | *  | 37  |      | 84   |      |      |      | 11   |       |             |      |      |      | 140 | -8   |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| RU                       | 5  | *   |      | -280 |      |      |      | 757  |       | 220         | 854  |      |      |     |      |     |      |      |  |
|                          | *  |     | 33   |      |      |      |      | 413  |       | 10          | -40  |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| TR                       | 6  | *   | -233 | 266  |      |      |      |      | 14    |             |      |      |      |     |      |     | -198 |      |  |
|                          | *  | -75 | -56  |      |      |      |      |      | -31   |             |      |      |      |     |      |     | -45  |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| UA                       | 7  | *   |      |      | 186  | 402  | -757 |      |       |             | 146  | -239 | 593  |     | 918  |     |      |      |  |
|                          | *  |     |      | -161 | -11  | -413 |      |      |       |             | -47  | -52  | 30   |     | -44  |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| AM                       | 8  | *   |      | 214  |      |      |      | -14  |       |             |      |      |      |     |      |     |      | 1200 |  |
|                          | *  |     | 109  |      |      |      |      | 31   |       |             |      |      |      |     |      |     |      | 43   |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| AZ                       | 9  | *   |      | 0    |      | -220 |      |      |       |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     | 0    |      |      | -10  |      |      |       |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| BY                       | 10 | *   |      |      |      | -854 |      | -146 |       |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      | 40   |      | 47   |       |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| SK                       | 11 | *   |      |      |      |      |      | 239  |       |             |      |      | -753 |     | 234  |     |      |      |  |
|                          | *  |     |      |      |      |      |      | 52   |       |             |      |      | 145  |     | 262  |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| PL                       | 12 | *   |      |      |      |      |      | -593 |       |             |      | 753  |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      | -30  |       |             |      | -145 |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| CS                       | 13 | *   | -162 |      |      | -190 |      |      |       |             |      |      |      |     | -269 | 92  |      |      |  |
|                          | *  | -62 |      |      | -140 |      |      |      |       |             |      |      |      |     | -75  | -67 |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| HU                       | 15 | *   |      |      |      | 153  |      | -918 |       |             | -234 |      |      | 269 |      |     |      |      |  |
|                          | *  |     |      |      |      | 8    |      | 44   |       |             | -262 |      |      | 75  |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| MK                       | 16 | *   | -155 |      |      |      |      |      |       |             |      |      |      | -92 |      |     | 147  |      |  |
|                          | *  | 11  |      |      |      |      |      |      |       |             |      |      |      | 67  |      |     | -148 |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| GR                       | 17 | *   | -350 |      |      |      | 198  |      |       |             |      |      |      |     |      |     | -147 |      |  |
|                          | *  | -1  |      |      |      |      | 45   |      |       |             |      |      |      |     |      |     | 148  |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |
| IR                       | 18 | *   |      |      |      |      |      |      | -1200 |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      | -43   |             |      |      |      |     |      |     |      |      |  |
|                          | *  |     |      |      |      |      |      |      |       |             |      |      |      |     |      |     |      |      |  |



**BLACKSEA REGIONAL MODEL  
SUMMER MINIMUM LOAD 2010**

| BLACKSEA REGIONAL MODEL  |          |   |      |      |      |      |       |      |       | AREA INTERCHANGE |     |      |      |      |      |      |      |      |  |
|--------------------------|----------|---|------|------|------|------|-------|------|-------|------------------|-----|------|------|------|------|------|------|------|--|
| SUMMER MINIMUM LOAD 2010 |          | 1 | 2    | 3    | 4    | 5    | 6     | 7    | 8     | 10               | 11  | 12   | 13   | 15   | 16   | 17   | 18   | 19   |  |
| FROM AREA                | TO AREA: | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| BG                       | 1        | * |      |      | -904 |      | 407   |      |       |                  |     |      |      | -16  |      | 144  | 369  |      |  |
|                          |          | * |      |      | -1   |      | 97    |      |       |                  |     |      |      | -17  |      | -42  | 25   |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| GE                       | 2        | * |      |      |      | 279  | 29    |      | -108  | 0                |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      | -21  | 45    |      | -142  | 0                |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| MD                       | 3        | * |      |      | 457  |      |       | -157 |       |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      | 58   |      |       | 17   |       |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| RO                       | 4        | * | 904  |      | -457 |      |       | -401 |       |                  |     |      |      | 133  | -130 |      |      |      |  |
|                          |          | * | 1    |      | -58  |      |       | -29  |       |                  |     |      |      | 135  | -46  |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| RU                       | 5        | * |      | -279 |      |      |       | 1064 |       | 65               | 700 |      |      |      |      |      |      |      |  |
|                          |          | * |      | 21   |      |      |       | 282  |       | -16              | -28 |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| TR                       | 6        | * | -407 | -29  |      |      |       |      | -92   |                  |     |      |      |      |      |      | -122 |      |  |
|                          |          | * | -97  | -45  |      |      |       |      | 2     |                  |     |      |      |      |      |      | -65  |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| UA                       | 7        | * |      |      | 157  | 401  | -1064 |      |       |                  | 300 | -181 | 542  |      | 994  |      |      |      |  |
|                          |          | * |      |      | -17  | 29   | -282  |      |       |                  | 1   | -78  | -70  |      | 73   |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| AM                       | 8        | * |      | 108  |      |      |       | 92   |       |                  |     |      |      |      |      |      |      | 1200 |  |
|                          |          | * |      | 142  |      |      |       | -2   |       |                  |     |      |      |      |      |      |      | 53   |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| AZ                       | 9        | * |      | 0    |      |      | -65   |      |       |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      | 0    |      |      | 16    |      |       |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| BY                       | 10       | * |      |      |      | -700 |       | -300 |       |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      | 28   |       | -1   |       |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| SK                       | 11       | * |      |      |      |      |       | 181  |       |                  |     |      | -588 |      | -74  |      |      |      |  |
|                          |          | * |      |      |      |      |       | 78   |       |                  |     |      | 126  |      | 54   |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| PL                       | 12       | * |      |      |      |      |       | -542 |       |                  |     | 588  |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       | 70   |       |                  |     | -126 |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| CS                       | 13       | * | 16   |      | -133 |      |       |      |       |                  |     |      |      |      | -221 | 268  |      |      |  |
|                          |          | * | 17   |      | -135 |      |       |      |       |                  |     |      |      |      | 6    | -66  |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| HU                       | 15       | * |      |      | 130  |      |       | -994 |       |                  |     | 74   |      | 221  |      |      |      |      |  |
|                          |          | * |      |      | 46   |      |       | -73  |       |                  |     | -54  |      | -6   |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| MK                       | 16       | * | -144 |      |      |      |       |      |       |                  |     |      |      | -268 |      |      | 313  |      |  |
|                          |          | * | 42   |      |      |      |       |      |       |                  |     |      |      | 66   |      |      | -29  |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| GR                       | 17       | * | -369 |      |      |      | 122   |      |       |                  |     |      |      |      |      | -313 |      |      |  |
|                          |          | * | -25  |      |      |      | 65    |      |       |                  |     |      |      |      |      | 29   |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |
| IR                       | 18       | * |      |      |      |      |       |      | -1200 |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      | -53   |                  |     |      |      |      |      |      |      |      |  |
|                          |          | * |      |      |      |      |       |      |       |                  |     |      |      |      |      |      |      |      |  |



---

### **4.3. Load flow analyses**



#### 4.3.1. BULGARIA

Figure 4.1 – Bulgaria – Load flows for Winter 2010 regime





Figure 4.2 – Bulgaria – Load flows for Summer 2010 regime





#### 4.3.2. GEORGIA

Figure 4.3 – Georgia – Load flows for Winter 2010 regime





Figure 4.4 – Georgia – Load flows for Summer 2010 regime



#### 4.3.3. MOLDOVA

Figure 4.5 – Moldova – Load flows for Winter 2010 regime





Figure 4.6 – Moldova – Load flows for Summer 2010 regime





#### 4.3.4. ROMANIA



Figure 4.7 – Romania – Load flows for Winter 2010 regime








Figure 4.8 – Romania – Load flows for Summer 2010 regime





RUSSIA


---

#### 4.3.5. RUSSIA



RUSSIA


Figure 4.9 – Russia – Load flows for Winter 2010 regime part 1





RUSSIA


Figure 4.10 – Russia – Load flows for Winter 2010 regime part 2





RUSSIA


Figure 4.11 – Russia – Load flows for Winter 2010 regime part 3





RUSSIA


Figure 4.12 – Russia – Load flows for Summer 2010 regime part1





RUSSIA


Figure 4.13 – Russia – Load flows for Summer 2010 regime part2





RUSSIA

Figure 4.14 – Russia – Load flows for Summer 2010 regime part3







TURKEY


---

#### 4.3.6. TURKEY




Figure 4.11 – Turkey – Load flows for Winter 2010 regime – North West





## TURKEY

Figure 4.12 – Turkey – Load flows for Winter 2010 regime – South West





BLACK SEA REGIONAL MODEL  
WINTER MAXIMUM LOAD 2010%  
MON, MAR 19 2007 16:41

Bus - VOLTAGE (KV)  
Branch - MW/MVAR  
Equipment - MW/MVAR  
100.00 RATE  
1.100000  
KV: <=30.000 <=120.000 <=150.000 <=220.000 <=330.000 <=400.000 <=500.000 >500.000




Figure 4.13 – Turkey – Load flows for Winter 2010 regime - EAST





# TURKEY

Figure 4.14 – Turkey – Load flows for Winter 2010 regime – North West







Figure 4.15 – Turkey – Load flows for Summer 2010 regime – South West



BLACKSEA REGIONAL MODEL V4  
SUMMER MINIMUM LOAD 2010%  
MON, MAR 19 2007 16:50








Figure 4.16 – Turkey – Load flows for Summer 2010 regime - EAST






#### 4.3.7. UKRAINE






## UKRAINE


Figure 4.21 – Ukraine – Load flows for Winter 2010 regime – part1





## UKRAINE

Figure 4.22 – Ukraina – Load flows for Winter 2010 regime – part2







Figure 4.23 – Ukraine – Load flows for Winter 2010 regime – part3









Figure 4.24 – Ukraine – Load flows for Winter 2010 regime – part4






## UKRAINE


Figure 4.25 – Ukraina – Load flows for Winter 2010 regime – part5






## UKRAINE


Figure 4.26 – Ukraina – Load flows for Summer 2010 regime – part1






## UKRAINE


Figure 4.27 – Ukraina – Load flows for Summer 2010 regime – part2





## UKRAINE

Figure 4.28 – Ukraina – Load flows for Summer 2010 regime – part3











Figure 4.29 – Ukraina – Load flows for Summer 2010 regime – part4





# UKRAINE

Figure 4.30 – Ukraina – Load flows for Summer 2010 regime – part5





#### 4.3.8. ARMENIA

Figure 4.27 – Armenia – Load flows for Winter 2010 regime






Figure 4.28 – Armenia – Load flows for Summer 2010 regime





#### 4.3.9. REGION






Figure 4.29 – Region – Load flows for Winter 2010 regime









#### 4.4. Network loading analyses

##### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

BRANCH LOADINGS ABOVE 101.0 % OF RATING SET A:

| X----- FROM BUS -----X |          |      |     |         | X----- TO BUS -----X |       |          |      |         | CURRENT(MVA) |      |     |         |        |         |
|------------------------|----------|------|-----|---------|----------------------|-------|----------|------|---------|--------------|------|-----|---------|--------|---------|
| BUS#                   | X--      | NAME | --X | BASKV   | AREA                 | BUS#  | X--      | NAME | --X     | BASKV        | AREA | CKT | LOADING | RATING | PERCENT |
| 50517                  | 4NC-     | 2251 |     | 110.00  | 5                    | 50536 | 4VOSTK51 |      | 110.00* | 5            | 99   |     | 61.4    | 50.5   | 121.6   |
| 50521                  | 4SVETT51 |      |     | 110.00* | 5                    | 50525 | 4GAGAR51 |      | 110.00  | 5            | 0    |     | 76.9    | 71.4   | 107.7   |
| 50578                  | 4USHAK51 |      |     | 110.00* | 5                    | 50936 | 4TEC-353 |      | 110.00  | 5            | 99   |     | 87.7    | 71.4   | 122.8   |
| 50580                  | 4VLAD 21 |      |     | 220.00* | 5                    | 50581 | 4VLAD 51 |      | 110.00  | 5            | 1    |     | 86.7    | 63.0   | 137.7   |
| 50580                  | 4VLAD 21 |      |     | 220.00* | 5                    | 50581 | 4VLAD 51 |      | 110.00  | 5            | 2    |     | 86.1    | 63.0   | 136.6   |
| 50586                  | 4RASSV51 |      |     | 110.00* | 5                    | 50591 | 4SRP 51  |      | 110.00  | 5            | 99   |     | 112.8   | 74.3   | 151.8   |
| 50589                  | 4BARR 51 |      |     | 110.00* | 5                    | 50591 | 4SRP 51  |      | 110.00  | 5            | 99   |     | 230.5   | 148.6  | 155.1   |
| 50615                  | 4DMITR51 |      |     | 110.00* | 5                    | 50653 | 4ZELEZ51 |      | 110.00  | 5            | 0    |     | 102.8   | 38.1   | 269.8   |
| 50661                  | 4UZNAJ51 |      |     | 110.00  | 5                    | 50664 | 4SUDZA51 |      | 110.00* | 5            | 99   |     | 23.5    | 23.0   | 102.2   |
| 50661                  | 4UZNAJ51 |      |     | 110.00  | 5                    | 50665 | 4LGOV 51 |      | 110.00* | 5            | 99   |     | 112.7   | 85.7   | 131.4   |
| 50811                  | 4BELG081 |      |     | 330.00* | 5                    | 50812 | 4BELG051 |      | 110.00  | 5            | 2    |     | 140.8   | 135.0  | 104.3   |
| 50854                  | 4TAMB-21 |      |     | 220.00  | 5                    | 50857 | 4TAMB451 |      | 110.00* | 5            | 0    |     | 357.5   | 100.0  | 357.5   |
| 50922                  | 4VOLZ151 |      |     | 110.00* | 5                    | 50948 | 4VTEC151 |      | 110.00  | 5            | 99   |     | 237.7   | 228.6  | 104.0   |
| 50951                  | 4DAGIL51 |      |     | 110.00  | 5                    | 50978 | 4RIAZA51 |      | 110.00* | 5            | 0    |     | 76.7    | 72.4   | 105.9   |
| 58213                  | 4SLAVJ2  |      |     | 220.00* | 5                    | 58214 | 4SLAVJ5  |      | 110.00  | 5            | 1    |     | 136.5   | 125.0  | 109.2   |
| 58224                  | 4KTEC 2  |      |     | 220.00* | 5                    | 58226 | 4KTEC 5  |      | 110.00  | 5            | 1    |     | 129.4   | 125.0  | 103.5   |
| 70210                  | ULOSEV52 |      |     | 110.00  | 7                    | 70211 | ULOSEV81 |      | 330.00* | 7            | 0    |     | 208.2   | 200.0  | 104.1   |
| 70211                  | ULOSEV81 |      |     | 330.00* | 7                    | 70246 | ULOSEV51 |      | 110.00  | 7            | 0    |     | 208.2   | 200.0  | 104.1   |
| 70247                  | USUMIS81 |      |     | 330.00* | 7                    | 70248 | USUMIS51 |      | 110.00  | 7            | 0    |     | 220.2   | 200.0  | 110.1   |
| 70424                  | USEVAS81 |      |     | 330.00* | 7                    | 70432 | UZPKRI51 |      | 110.00  | 7            | 0    |     | 155.7   | 125.0  | 124.5   |
| 70508                  | UUSAT081 |      |     | 330.00* | 7                    | 70510 | UUSAT051 |      | 110.00  | 7            | 0    |     | 412.7   | 400.0  | 103.2   |
| 70520                  | UJUASZ81 |      |     | 330.00* | 7                    | 70521 | UJUASZ31 |      | 150.00  | 7            | 0    |     | 270.8   | 250.0  | 108.3   |

##### BLACK SEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

BRANCH LOADINGS ABOVE 101.0 % OF RATING SET A:

| X----- FROM BUS -----X |          |      |     |         | X----- TO BUS -----X |       |          |      |     | CURRENT(MVA) |      |      |         |        |         |
|------------------------|----------|------|-----|---------|----------------------|-------|----------|------|-----|--------------|------|------|---------|--------|---------|
| BUS#                   | X--      | NAME | --X | BASKV   | AREA                 | BUS#  | X--      | NAME | --X | BASKV        | AREA | CKT  | LOADING | RATING | PERCENT |
| 50615                  | 4DMITR51 |      |     | 110.00* | 5                    | 50653 | 4ZELEZ51 |      |     | 110.00       |      | 5 0  | 45.4    | 38.1   | 119.2   |
| 50951                  | 4DAGIL51 |      |     | 110.00  | 5                    | 50978 | 4RIAZA51 |      |     | 110.00*      |      | 5 0  | 135.6   | 72.4   | 187.2   |
| 50977                  | 4JAMSK52 |      |     | 110.00* | 5                    | 50978 | 4RIAZA51 |      |     | 110.00       |      | 5 99 | 93.7    | 84.8   | 110.5   |

As it can be seen, all overloaded elements are in lower voltage network (110 kV) so they can be treated as local problems. Also most of them are connected to equivalent circuits (in Russia).





Figure 4.31 – Region –Elements Loading profile histograms for Winter 2010 regime by nominal voltage levels








Figure 4.32 – Region –Elements Loading profile histograms for Summer 2010 regime by nominal voltage levels





---

#### **4.5. Voltage profile analyses**

On Figure 4.33-Figure 4.34 are diagrams that show number of buses in network in appropriate voltage ranges, and by nominal voltage levels. These diagrams show distribution of voltages in network buses and give a rough inview of voltage profile in whole regional network. Results show that in most buses voltage level is higher than nominal levels and in allowable voltage ranges. In summer regime, overall voltage level is higher than in winter regime which is consequence of low load of transmission network, but difference is very small.







Figure 4.33 – Region – Voltage profile histograms for Winter 2010 regime by nominal voltage levels




220kV network




330kV network



400kV network



500kV network



750kV network







Figure 4.34 – Region – Voltage profile histograms for Summer 2010 regime by nominal voltage levels




220 kV network




330kV network




400kV network



500kV network



750kV network



---

## BULGARIA

### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1100:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

### 110KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1100:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

### BLACK SEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1100:


| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

### 110KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1200:




---

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

## GEORGIA

### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010 500KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9500:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

### 330KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1100:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

### BLACK SEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010 500KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|


\* NONE \*

### 330KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

|                                          |                                          |
|------------------------------------------|------------------------------------------|
| BUS# X-- NAME --X BASKV AREA V(PU) V(KV) | BUS# X-- NAME --X BASKV AREA V(PU) V(KV) |
|------------------------------------------|------------------------------------------|





---

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

## MOLDOVA

#### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

##### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

##### 330KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9100:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

##### 110KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1200:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*


#### BLACK SEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

##### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#  | X-- | NAME    | --X | BASKV  | AREA | V(PU)  | V(KV)  | BUS#  | X-- | NAME    | --X | BASKV  | AREA | V(PU)  | V(KV)  |
|-------|-----|---------|-----|--------|------|--------|--------|-------|-----|---------|-----|--------|------|--------|--------|
| 36046 |     | 5VULKA1 |     | 400.00 | 3    | 1.0553 | 422.11 | 30120 |     | 5MREPP1 |     | 400.00 | 3    | 1.0541 | 421.62 |

BUSES WITH VOLTAGE LESS THAN 0.9500:




---

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

---

\* NONE \*

### 330KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9100:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

### 110KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1200:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

## ROMANIA

**BLACKSEA REGIONAL MODEL**  
**WINTER MAXIMUM LOAD 2010**

### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1100:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

### 110KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1200:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*


**BLACK SEA REGIONAL MODEL**  
**SUMMER MINIMUM LOAD 2010**

### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*




---

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

#### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1100:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

#### 110KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1200:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

## RUSSIA

#### BLACKSEA REGIONAL MODEL

#### WINTER MAXIMUM LOAD 2010

#### 750KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

#### 500KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#  | X--   | NAME | --X | BASKV  | AREA | V(PU)  | V(KV)  | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|-------|-------|------|-----|--------|------|--------|--------|------|-----|------|-----|-------|------|-------|-------|
| 50717 | 4ELEC | 91   |     | 500.00 | 5    | 1.0563 | 528.13 |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

#### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

#### 330KV NETWORK


BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

---



\* NONE \*

#### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#  | X-- | NAME     | --X | BASKV  | AREA | V(PU)  | V(KV)  | BUS#  | X-- | NAME     | --X | BASKV  | AREA | V(PU)  | V(KV)  |
|-------|-----|----------|-----|--------|------|--------|--------|-------|-----|----------|-----|--------|------|--------|--------|
| 50583 |     | 4NARAB21 |     | 220.00 | 5    | 0.8847 | 194.64 | 50585 |     | 4RASSV21 |     | 220.00 | 5    | 0.8831 | 194.29 |
| 50587 |     | 4ASTRA21 |     | 220.00 | 5    | 0.8833 | 194.33 | 50588 |     | 4BARR 21 |     | 220.00 | 5    | 0.8750 | 192.51 |
| 50592 |     | 4GAZ 21  |     | 220.00 | 5    | 0.8621 | 189.66 | 50597 |     | 4LIMAN21 |     | 220.00 | 5    | 0.8931 | 196.48 |

#### BLACK SEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

#### 750KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 500KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#  | X-- | NAME     | --X | BASKV  | AREA | V(PU)  | V(KV)  | BUS#  | X-- | NAME     | --X | BASKV  | AREA | V(PU)  | V(KV)  |
|-------|-----|----------|-----|--------|------|--------|--------|-------|-----|----------|-----|--------|------|--------|--------|
| 58374 |     | 4BUDEN95 |     | 500.00 | 5    | 1.0586 | 529.31 | 50717 |     | 4ELEC 91 |     | 500.00 | 5    | 1.0655 | 532.74 |
| 50758 |     | 4NVAES91 |     | 500.00 | 5    | 1.0603 | 530.17 | 50801 |     | 4STOSK91 |     | 500.00 | 5    | 1.0527 | 526.36 |
| 50813 |     | 4METAL91 |     | 500.00 | 5    | 1.0540 | 527.00 | 50902 |     | 4BALAS91 |     | 500.00 | 5    | 1.0616 | 530.80 |
| 50940 |     | 4OTPNV91 |     | 500.00 | 5    | 1.0557 | 527.83 | 58370 |     | 4BUDEN9  |     | 500.00 | 5    | 1.0586 | 529.28 |

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 330KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|


\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 110KV NETWORK



BUSES WITH VOLTAGE GREATER THAN 1.1500:

| BUS#  | X-- | NAME     | --X | BASKV  | AREA | V(PU)  | V(KV)  | BUS#  | X-- | NAME     | --X | BASKV  | AREA | V(PU)  | V(KV)  |
|-------|-----|----------|-----|--------|------|--------|--------|-------|-----|----------|-----|--------|------|--------|--------|
| 50586 |     | 4RASSV51 |     | 110.00 | 5    | 1.1668 | 128.35 | 50589 |     | 4BARR 51 |     | 110.00 | 5    | 1.1642 | 128.07 |
| 50591 |     | 4SRP 51  |     | 110.00 | 5    | 1.2111 | 133.23 | 50593 |     | 4GAZ1051 |     | 110.00 | 5    | 1.1642 | 128.06 |
| 50594 |     | 4BUZAN51 |     | 110.00 | 5    | 1.1600 | 127.60 | 50598 |     | 4LIMAN51 |     | 110.00 | 5    | 1.1539 | 126.93 |
| 50755 |     | 4SEMIL51 |     | 110.00 | 5    | 1.1531 | 126.84 | 50759 |     | 4NVAES51 |     | 110.00 | 5    | 1.1673 | 128.41 |
| 50762 |     | 4LISKI51 |     | 110.00 | 5    | 1.1528 | 126.81 | 50763 |     | 4BOBRO51 |     | 110.00 | 5    | 1.1687 | 128.56 |
| 50765 |     | 4EL.KO51 |     | 110.00 | 5    | 1.1522 | 126.74 | 50766 |     | 4PRIDO51 |     | 110.00 | 5    | 1.1540 | 126.94 |
| 50901 |     | 4BALAS51 |     | 110.00 | 5    | 1.1503 | 126.54 | 58316 |     | 4GEC-25  |     | 110.00 | 5    | 1.1653 | 128.19 |
| 58321 |     | 4GES-15  |     | 110.00 | 5    | 1.1684 | 128.52 | 58713 |     | 4DERBE5  |     | 110.00 | 5    | 1.2153 | 133.68 |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

## TURKEY

### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9300:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

### 150KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0800:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9700:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

### BLACK SEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9300:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

### 150KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0800:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|


\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9700:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

## UKRAINE



---

**BLACKSEA REGIONAL MODEL**  
**WINTER MAXIMUM LOAD 2010**  
**750KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9200:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

**500KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9400:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

**400KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

**330KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.8800:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

**220KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |


BUSES WITH VOLTAGE LESS THAN 0.8200:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

**BLACKSEA REGIONAL MODEL**  
**SUMMER MINIMUM LOAD 2010**  
**750KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|



---

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9200:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 500KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9400:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 330KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.8800:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

#### 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#  | X-- | NAME     | --X | BASKV  | AREA | V(PU)  | V(KV)  | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|-------|-----|----------|-----|--------|------|--------|--------|------|-----|------|-----|-------|------|-------|-------|
| 70502 |     | UTRIHA21 |     | 220.00 | 7    | 1.1165 | 245.62 |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.8200:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

## ARMENIA

**BLACKSEA REGIONAL MODEL  
WINTER MAXIMUM LOAD 2010**

#### 400KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.0500:


| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
|------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|

\* NONE \*



---

## 220KV NETWORK

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.8200:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

## 110KV NETWORK


BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |





---

**BLACKSEA REGIONAL MODEL**  
**SUMMER MINIMUM LOAD 2010**  
**400KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.0500:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

**220KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.8200:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |


**110KV NETWORK**

BUSES WITH VOLTAGE GREATER THAN 1.1000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |

BUSES WITH VOLTAGE LESS THAN 0.9000:

| BUS#     | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) | BUS# | X-- | NAME | --X | BASKV | AREA | V(PU) | V(KV) |
|----------|-----|------|-----|-------|------|-------|-------|------|-----|------|-----|-------|------|-------|-------|
| * NONE * |     |      |     |       |      |       |       |      |     |      |     |       |      |       |       |



## 4.6. Contingency analyses

Every project participant was obliged to check whether model of its systems complies according to the n-1 security criterion. In this chapter results of these analyses are shown.

### 4.6.1. Bulgaria

Here enclosed is contingency report output from PSS/E program as well as list of contingencies analyzed.

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 95.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)  
ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.01250 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: D:\bg\_2010.acc  
DISTRIBUTION FACTOR FILE: D:\bg\_2010.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\BG\_2010.sub  
MONITORED ELEMENT FILE: D:\BG\_2010.mon  
CONTINGENCY DESCRIPTION FILE: D:\BG\_2010.con

#### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010


| <----- MULTI-SECTION LINE -----> |        |             |                     | <----- MONITORED BRANCH -----> |        |       |       |
|----------------------------------|--------|-------------|---------------------|--------------------------------|--------|-------|-------|
| CONTINGENCY                      | RATING | FLOW        | %                   |                                |        |       |       |
| MONITORED VOLTAGE REPORT:        |        |             |                     |                                |        |       |       |
| SYSTEM                           |        | CONTINGENCY | <----- B U S -----> | V-CONT                         | V-INIT | V-MAX | V-MIN |

#### BLACKSEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

| <----- MULTI-SECTION LINE -----> |        |             |                     | <----- MONITORED BRANCH -----> |        |       |       |
|----------------------------------|--------|-------------|---------------------|--------------------------------|--------|-------|-------|
| CONTINGENCY                      | RATING | FLOW        | %                   |                                |        |       |       |
| MONITORED VOLTAGE REPORT:        |        |             |                     |                                |        |       |       |
| SYSTEM                           |        | CONTINGENCY | <----- B U S -----> | V-CONT                         | V-INIT | V-MAX | V-MIN |


#### CONTINGENCY LEGEND:

| LABEL     | EVENTS                                                                          |
|-----------|---------------------------------------------------------------------------------|
| INT-20    | : OPEN LINE FROM BUS 20 [XBG_TH11 400.00] TO BUS 12433 [VBLAG01 400.00] CKT 1   |
|           | : OPEN LINE FROM BUS 20 [XBG_TH11 400.00] TO BUS 80252 [GLAGAD1 400.00] CKT 1   |
| INT-21    | : OPEN LINE FROM BUS 21 [XDO_IS11 400.00] TO BUS 12461 [VDOBRU1 400.00] CKT 1   |
|           | : OPEN LINE FROM BUS 21 [XDO_IS11 400.00] TO BUS 48020 [RISACC1 400.00] CKT 1   |
| INT-22    | : OPEN LINE FROM BUS 22 [XKO_TI11 400.00] TO BUS 12440 [VAEC_41 400.00] CKT 1   |
|           | : OPEN LINE FROM BUS 22 [XKO_TI11 400.00] TO BUS 48001 [RTANTA1 400.00] CKT 1   |
| INT-23    | : OPEN LINE FROM BUS 23 [XKO_TI12 400.00] TO BUS 12440 [VAEC_41 400.00] CKT 1   |
|           | : OPEN LINE FROM BUS 23 [XKO_TI12 400.00] TO BUS 48001 [RTANTA1 400.00] CKT 2   |
| INT-24    | : OPEN LINE FROM BUS 24 [XSO_NI11 400.00] TO BUS 12431 [VSOFIW1 400.00] CKT 1   |
|           | : OPEN LINE FROM BUS 24 [XSO_NI11 400.00] TO BUS 80104 [JNIS2 1 400.00] CKT 1   |
| INT-181   | : OPEN LINE FROM BUS 181 [XVA_IS11 400.00] TO BUS 12460 [VVARNA1 400.00] CKT 1  |
|           | : OPEN LINE FROM BUS 181 [XVA_IS11 400.00] TO BUS 48020 [RISACC1 400.00] CKT 1  |
| INT-197   | : OPEN LINE FROM BUS 197 [XMI_BA11 400.00] TO BUS 12471 [VMI3 11 400.00] CKT 1  |
|           | : OPEN LINE FROM BUS 197 [XMI_BA11 400.00] TO BUS 60032 [TBABAE12 400.00] CKT 1 |
| INT-198   | : OPEN LINE FROM BUS 198 [XMI_HA11 400.00] TO BUS 12471 [VMI3 11 400.00] CKT 1  |
|           | : OPEN LINE FROM BUS 198 [XMI_HA11 400.00] TO BUS 60002 [THAMIT1 400.00] CKT 1  |
| INT-207   | : OPEN LINE FROM BUS 207 [XCM_ST11 400.00] TO BUS 12432 [VCMOGI1 400.00] CKT 1  |
|           | : OPEN LINE FROM BUS 207 [XCM_ST11 400.00] TO BUS 80204 [YSTIP11 400.00] CKT 1  |
| INT-214   | : OPEN LINE FROM BUS 214 [XMI_FI11 400.00] TO BUS 12474 [VMI 1 400.00] CKT 1    |
|           | : OPEN LINE FROM BUS 214 [XMI_FI11 400.00] TO BUS 80250 [GFILIP1 400.00] CKT 1  |
| SINGLE 1  | : OPEN LINE FROM BUS 12220 [VBELME2 220.00] TO BUS 12221 [VKAZIC2 220.00] CKT 1 |
| SINGLE 2  | : OPEN LINE FROM BUS 12220 [VBELME2 220.00] TO BUS 12221 [VKAZIC2 220.00] CKT 2 |
| SINGLE 3  | : OPEN LINE FROM BUS 12221 [VKAZIC2 220.00] TO BUS 12222 [VSOFIJ2 220.00] CKT 1 |
| SINGLE 4  | : OPEN LINE FROM BUS 12221 [VKAZIC2 220.00] TO BUS 12222 [VSOFIJ2 220.00] CKT 2 |
| SINGLE 5  | : OPEN LINE FROM BUS 12221 [VKAZIC2 220.00] TO BUS 12232 [VSTOLN2 220.00] CKT 1 |
| SINGLE 6  | : OPEN LINE FROM BUS 12221 [VKAZIC2 220.00] TO BUS 12232 [VSTOLN2 220.00] CKT 2 |
| SINGLE 7  | : OPEN LINE FROM BUS 12221 [VKAZIC2 220.00] TO BUS 12280 [VALEK02 220.00] CKT 1 |
| SINGLE 8  | : OPEN LINE FROM BUS 12221 [VKAZIC2 220.00] TO BUS 12280 [VALEK02 220.00] CKT 2 |
| SINGLE 9  | : OPEN LINE FROM BUS 12222 [VSOFIJ2 220.00] TO BUS 12231 [VB0BOV2 220.00] CKT 1 |
| SINGLE 10 | : OPEN LINE FROM BUS 12222 [VSOFIJ2 220.00] TO BUS 12231 [VB0BOV2 220.00] CKT 2 |
| SINGLE 11 | : OPEN LINE FROM BUS 12223 [VGPP_12 220.00] TO BUS 12232 [VSTOLN2 220.00] CKT 1 |



|           |   |                          |           |         |              |           |         |       |
|-----------|---|--------------------------|-----------|---------|--------------|-----------|---------|-------|
| SINGLE 12 | : | OPEN LINE FROM BUS 12224 | [VTSOFI2  | 220.00] | TO BUS 12231 | [VB0BOV2  | 220.00] | CKT 1 |
| SINGLE 13 | : | OPEN LINE FROM BUS 12224 | [VTSOFI2  | 220.00] | TO BUS 12232 | [VSTOLN2  | 220.00] | CKT 1 |
| SINGLE 14 | : | OPEN LINE FROM BUS 12230 | [VSTOMA2  | 220.00] | TO BUS 12231 | [VB0BOV2  | 220.00] | CKT 1 |
| SINGLE 15 | : | OPEN LINE FROM BUS 12230 | [VSTOMA2  | 220.00] | TO BUS 12232 | [VSTOLN2  | 220.00] | CKT 1 |
| SINGLE 16 | : | OPEN LINE FROM BUS 12232 | [VSTOLN2  | 220.00] | TO BUS 12233 | [VSESTR2  | 220.00] | CKT 1 |
| SINGLE 17 | : | OPEN LINE FROM BUS 12232 | [VSTOLN2  | 220.00] | TO BUS 12430 | [VSTOLN1  | 400.00] | CKT 1 |
| SINGLE 18 | : | OPEN LINE FROM BUS 12240 | [VBOICH2  | 220.00] | TO BUS 12241 | [VAEC_22  | 220.00] | CKT 1 |
| SINGLE 19 | : | OPEN LINE FROM BUS 12240 | [VBOICH2  | 220.00] | TO BUS 12290 | [VMIZIA2  | 220.00] | CKT 1 |
| SINGLE 20 | : | OPEN LINE FROM BUS 12241 | [VAEC_22  | 220.00] | TO BUS 12242 | [VBPC_22  | 220.00] | CKT 1 |
| SINGLE 21 | : | OPEN LINE FROM BUS 12241 | [VAEC_22  | 220.00] | TO BUS 12290 | [VMIZIA2  | 220.00] | CKT 1 |
| SINGLE 22 | : | OPEN LINE FROM BUS 12241 | [VAEC_22  | 220.00] | TO BUS 12290 | [VMIZIA2  | 220.00] | CKT 2 |
| SINGLE 23 | : | OPEN LINE FROM BUS 12241 | [VAEC_22  | 220.00] | TO BUS 12440 | [VAEC_41  | 400.00] | CKT 1 |
| SINGLE 24 | : | OPEN LINE FROM BUS 12250 | [VGORIA2  | 220.00] | TO BUS 12251 | [VBALKA2  | 220.00] | CKT 1 |
| SINGLE 25 | : | OPEN LINE FROM BUS 12250 | [VGORIA2  | 220.00] | TO BUS 12252 | [VOCHIF2  | 220.00] | CKT 1 |
| SINGLE 26 | : | OPEN LINE FROM BUS 12250 | [VGORIA2  | 220.00] | TO BUS 12261 | [VMADAR2  | 220.00] | CKT 1 |
| SINGLE 27 | : | OPEN LINE FROM BUS 12250 | [VGORIA2  | 220.00] | TO BUS 12272 | [VMI2_2   | 220.00] | CKT 1 |
| SINGLE 28 | : | OPEN LINE FROM BUS 12250 | [VGORIA2  | 220.00] | TO BUS 12278 | [VXXXXX21 | 220.00] | CKT 1 |
| SINGLE 29 | : | OPEN LINE FROM BUS 12250 | [VGORIA2  | 220.00] | TO BUS 12291 | [VPLEVE21 | 220.00] | CKT 1 |
| SINGLE 30 | : | OPEN LINE FROM BUS 12251 | [VBALKA2  | 220.00] | TO BUS 12287 | [VXXXXX23 | 220.00] | CKT 1 |
| SINGLE 31 | : | OPEN LINE FROM BUS 12260 | [VDOB RU2 | 220.00] | TO BUS 12261 | [VMADAR2  | 220.00] | CKT 2 |
| SINGLE 32 | : | OPEN LINE FROM BUS 12260 | [VDOB RU2 | 220.00] | TO BUS 12262 | [VTVARN2  | 220.00] | CKT 1 |
| SINGLE 33 | : | OPEN LINE FROM BUS 12260 | [VDOB RU2 | 220.00] | TO BUS 12262 | [VTVARN2  | 220.00] | CKT 2 |
| SINGLE 34 | : | OPEN LINE FROM BUS 12260 | [VDOB RU2 | 220.00] | TO BUS 12263 | [VVARNA2  | 220.00] | CKT 1 |
| SINGLE 35 | : | OPEN LINE FROM BUS 12260 | [VDOB RU2 | 220.00] | TO BUS 12277 | [VXXXXX21 | 220.00] | CKT 1 |
| SINGLE 36 | : | OPEN LINE FROM BUS 12261 | [VMADAR2  | 220.00] | TO BUS 12263 | [VVARNA2  | 220.00] | CKT 1 |
| SINGLE 37 | : | OPEN LINE FROM BUS 12263 | [VVARNA2  | 220.00] | TO BUS 12460 | [VVARNA1  | 400.00] | CKT 1 |
| SINGLE 38 | : | OPEN LINE FROM BUS 12270 | [VCHUD02  | 220.00] | TO BUS 12287 | [VXXXXX23 | 220.00] | CKT 1 |
| SINGLE 39 | : | OPEN LINE FROM BUS 12271 | [VTVARD2  | 220.00] | TO BUS 12278 | [VXXXXX22 | 220.00] | CKT 1 |
| SINGLE 40 | : | OPEN LINE FROM BUS 12272 | [VMI2_2   | 220.00] | TO BUS 12274 | [VMI_2    | 220.00] | CKT 1 |
| SINGLE 41 | : | OPEN LINE FROM BUS 12272 | [VMI2_2   | 220.00] | TO BUS 12274 | [VMI_2    | 220.00] | CKT 2 |
| SINGLE 42 | : | OPEN LINE FROM BUS 12272 | [VMI2_2   | 220.00] | TO BUS 12275 | [VMI3_2   | 220.00] | CKT 1 |
| SINGLE 43 | : | OPEN LINE FROM BUS 12272 | [VMI2_2   | 220.00] | TO BUS 12276 | [VSTZAG2  | 220.00] | CKT 1 |
| SINGLE 44 | : | OPEN LINE FROM BUS 12272 | [VMI2_2   | 220.00] | TO BUS 12277 | [VXXXXX21 | 220.00] | CKT 1 |
| SINGLE 45 | : | OPEN LINE FROM BUS 12272 | [VMI2_2   | 220.00] | TO BUS 12278 | [VXXXXX22 | 220.00] | CKT 1 |
| SINGLE 46 | : | OPEN LINE FROM BUS 12273 | [VKARN02  | 220.00] | TO BUS 12277 | [VXXXXX21 | 220.00] | CKT 1 |
| SINGLE 47 | : | OPEN LINE FROM BUS 12274 | [VMI_2    | 220.00] | TO BUS 12275 | [VMI3_2   | 220.00] | CKT 1 |
| SINGLE 48 | : | OPEN LINE FROM BUS 12274 | [VMI_2    | 220.00] | TO BUS 12285 | [VPL0VD2  | 220.00] | CKT 1 |
| SINGLE 49 | : | OPEN LINE FROM BUS 12274 | [VMI_2    | 220.00] | TO BUS 12285 | [VPL0VD2  | 220.00] | CKT 2 |
| SINGLE 50 | : | OPEN LINE FROM BUS 12274 | [VMI_2    | 220.00] | TO BUS 12474 | [VMI_1    | 400.00] | CKT 1 |
| SINGLE 51 | : | OPEN LINE FROM BUS 12275 | [VMI3_2   | 220.00] | TO BUS 12286 | [VUZUND2  | 220.00] | CKT 1 |
| SINGLE 52 | : | OPEN LINE FROM BUS 12275 | [VMI3_2   | 220.00] | TO BUS 12471 | [VMI3_11  | 400.00] | CKT 1 |
| SINGLE 53 | : | OPEN LINE FROM BUS 12280 | [VALEK02  | 220.00] | TO BUS 12281 | [VPESH2   | 220.00] | CKT 1 |
| SINGLE 54 | : | OPEN LINE FROM BUS 12280 | [VALEK02  | 220.00] | TO BUS 12282 | [VORFEJ2  | 220.00] | CKT 1 |
| SINGLE 55 | : | OPEN LINE FROM BUS 12280 | [VALEK02  | 220.00] | TO BUS 12285 | [VPL0VD2  | 220.00] | CKT 1 |
| SINGLE 56 | : | OPEN LINE FROM BUS 12280 | [VALEK02  | 220.00] | TO BUS 12287 | [VXXXXX23 | 220.00] | CKT 1 |
| SINGLE 57 | : | OPEN LINE FROM BUS 12282 | [VORFEJ2  | 220.00] | TO BUS 12288 | [VXXXXX24 | 220.00] | CKT 1 |
| SINGLE 58 | : | OPEN LINE FROM BUS 12283 | [VDEVIN2  | 220.00] | TO BUS 12288 | [VXXXXX24 | 220.00] | CKT 1 |
| SINGLE 59 | : | OPEN LINE FROM BUS 12284 | [VTESHE2  | 220.00] | TO BUS 12288 | [VXXXXX24 | 220.00] | CKT 1 |
| SINGLE 60 | : | OPEN LINE FROM BUS 12290 | [VMIZIA2  | 220.00] | TO BUS 12291 | [VPLEVE21 | 220.00] | CKT 1 |
| SINGLE 61 | : | OPEN LINE FROM BUS 12290 | [VMIZIA2  | 220.00] | TO BUS 12291 | [VPLEVE21 | 220.00] | CKT 2 |
| SINGLE 62 | : | OPEN LINE FROM BUS 12290 | [VMIZIA2  | 220.00] | TO BUS 12490 | [VMIZIA1  | 400.00] | CKT 1 |
| SINGLE 63 | : | OPEN LINE FROM BUS 12420 | [VMETAL1  | 400.00] | TO BUS 12430 | [VSTOLN1  | 400.00] | CKT 1 |
| SINGLE 64 | : | OPEN LINE FROM BUS 12420 | [VMETAL1  | 400.00] | TO BUS 12431 | [VSOFIW1  | 400.00] | CKT 1 |
| SINGLE 65 | : | OPEN LINE FROM BUS 12430 | [VSTOLN1  | 400.00] | TO BUS 12434 | [VZLATI1  | 400.00] | CKT 1 |
| SINGLE 66 | : | OPEN LINE FROM BUS 12430 | [VSTOLN1  | 400.00] | TO BUS 12490 | [VMIZIA1  | 400.00] | CKT 1 |
| SINGLE 67 | : | OPEN LINE FROM BUS 12431 | [VSOFIW1  | 400.00] | TO BUS 12432 | [VCMOGI1  | 400.00] | CKT 1 |
| SINGLE 68 | : | OPEN LINE FROM BUS 12431 | [VSOFIW1  | 400.00] | TO BUS 12432 | [VCMOGI1  | 400.00] | CKT 2 |
| SINGLE 69 | : | OPEN LINE FROM BUS 12431 | [VSOFIW1  | 400.00] | TO BUS 12440 | [VAEC_41  | 400.00] | CKT 1 |
| SINGLE 70 | : | OPEN LINE FROM BUS 12431 | [VSOFIW1  | 400.00] | TO BUS 12440 | [VAEC_41  | 400.00] | CKT 2 |
| SINGLE 71 | : | OPEN LINE FROM BUS 12432 | [VCMOGI1  | 400.00] | TO BUS 12433 | [VBLAG01  | 400.00] | CKT 1 |
| SINGLE 72 | : | OPEN LINE FROM BUS 12432 | [VCMOGI1  | 400.00] | TO BUS 12433 | [VBLAG01  | 400.00] | CKT 2 |
| SINGLE 73 | : | OPEN LINE FROM BUS 12432 | [VCMOGI1  | 400.00] | TO BUS 12437 | [VVETRE1  | 400.00] | CKT 1 |
| SINGLE 74 | : | OPEN LINE FROM BUS 12434 | [VZLATI1  | 400.00] | TO BUS 12480 | [VPL0VD1  | 400.00] | CKT 1 |
| SINGLE 75 | : | OPEN LINE FROM BUS 12435 | [VCHAIR11 | 400.00] | TO BUS 12437 | [VVETRE1  | 400.00] | CKT 1 |
| SINGLE 76 | : | OPEN LINE FROM BUS 12437 | [VVETRE1  | 400.00] | TO BUS 12480 | [VPL0VD1  | 400.00] | CKT 1 |
| SINGLE 77 | : | OPEN LINE FROM BUS 12440 | [VAEC_41  | 400.00] | TO BUS 12490 | [VMIZIA1  | 400.00] | CKT 2 |
| SINGLE 78 | : | OPEN LINE FROM BUS 12440 | [VAEC_41  | 400.00] | TO BUS 12490 | [VMIZIA1  | 400.00] | CKT 3 |
| SINGLE 79 | : | OPEN LINE FROM BUS 12450 | [VCAREV1  | 400.00] | TO BUS 12460 | [VVARNA1  | 400.00] | CKT 1 |
| SINGLE 80 | : | OPEN LINE FROM BUS 12450 | [VCAREV1  | 400.00] | TO BUS 12490 | [VMIZIA1  | 400.00] | CKT 1 |
| SINGLE 81 | : | OPEN LINE FROM BUS 12460 | [VVARNA1  | 400.00] | TO BUS 12461 | [VDOB RU1 | 400.00] | CKT 1 |
| SINGLE 82 | : | OPEN LINE FROM BUS 12460 | [VVARNA1  | 400.00] | TO BUS 12461 | [VDOB RU1 | 400.00] | CKT 2 |
| SINGLE 83 | : | OPEN LINE FROM BUS 12460 | [VVARNA1  | 400.00] | TO BUS 12470 | [VBURGA1  | 400.00] | CKT 1 |
| SINGLE 84 | : | OPEN LINE FROM BUS 12470 | [VBURGA1  | 400.00] | TO BUS 12472 | [VMI2_1   | 400.00] | CKT 1 |
| SINGLE 85 | : | OPEN LINE FROM BUS 12471 | [VMI3_11  | 400.00] | TO BUS 12472 | [VMI2_1   | 400.00] | CKT 1 |
| SINGLE 86 | : | OPEN LINE FROM BUS 12471 | [VMI3_11  | 400.00] | TO BUS 12474 | [VMI_1    | 400.00] | CKT 1 |
| SINGLE 87 | : | OPEN LINE FROM BUS 12474 | [VMI_1    | 400.00] | TO BUS 12475 | [VTMI_15  | 400.00] | CKT 1 |
| SINGLE 88 | : | OPEN LINE FROM BUS 12474 | [VMI_1    | 400.00] | TO BUS 12476 | [VTMI_16  | 400.00] | CKT 1 |
| SINGLE 89 | : | OPEN LINE FROM BUS 12474 | [VMI_1    | 400.00] | TO BUS 12480 | [VPL0VD1  | 400.00] | CKT 1 |

It can be concluded that in this regime, Bulgarian network fully complies with (n-1) security criterion.



## 4.6.2. Georgia

### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)

CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0  
PERCENT OF RATING SET A

ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: D:\miksa\0\BlackSea\0report\GE\GEWINTER.acc  
DISTRIBUTION FACTOR FILE: D:\miksa\0\BlackSea\0report\GE\GE.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\GE\GE.sub  
MONITORED ELEMENT FILE: D:\miksa\0\BlackSea\0report\GE\GE.mon  
CONTINGENCY DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\GE\GE.con

| <----- MONITORED BRANCH -----> |        |               |          | CONTINGENCY | RATING | FLOW  | %     |
|--------------------------------|--------|---------------|----------|-------------|--------|-------|-------|
| 20009 6VARDI2                  | 220.00 | 20032*6TKVAR2 | 220.00 1 | SINGLE 102  | 371.0  | 421.6 | 118.5 |
| 20032 6TKVAR2                  | 220.00 | 20033*6SOUKH2 | 220.00 1 | SINGLE 102  | 371.0  | 372.9 | 112.6 |
| 20002*6QSANI9                  | 500.00 | 20007 6QSANI2 | 220.00 1 | SINGLE 114  | 500.0  | 633.8 | 126.8 |

#### MONITORED VOLTAGE REPORT:

| SYSTEM  | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |         |
|---------|-----------------|---------------------|--------|---------|---------|---------|---------|
| GE220KV | RANGE SINGLE 2  | 20033 6SOUKH2       | 220.00 | 0.89503 | 0.97119 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 3  | 20030 6BZYBI21      | 220.00 | 0.87603 | 0.99323 | 1.10000 | 0.90000 |
| GE500KV | RANGE SINGLE 5  | 20001 6ZESTA9       | 500.00 | 0.94648 | 0.98827 | 1.05000 | 0.95000 |
| GE220KV | RANGE SINGLE 6  | 20032 6TKVAR2       | 220.00 | 0.89213 | 0.99683 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 6  | 20033 6SOUKH2       | 220.00 | 0.88298 | 0.97119 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 13 | 20027 6GURJA2       | 220.00 | 0.88376 | 0.97012 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 16 | 20033 6SOUKH2       | 220.00 | 0.89339 | 0.97119 | 1.10000 | 0.90000 |

### BLACKSEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)

CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0  
PERCENT OF RATING SET A

ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: D:\miksa\0\BlackSea\0report\GE\GESUMMER.acc  
DISTRIBUTION FACTOR FILE: D:\miksa\0\BlackSea\0report\GE\GE.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\GE\GE.sub  
MONITORED ELEMENT FILE: D:\miksa\0\BlackSea\0report\GE\GE.mon  
CONTINGENCY DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\GE\GE.con


| <----- MONITORED BRANCH -----> |  |  |  | CONTINGENCY | RATING | FLOW | % |
|--------------------------------|--|--|--|-------------|--------|------|---|
|--------------------------------|--|--|--|-------------|--------|------|---|

#### MONITORED VOLTAGE REPORT:

| SYSTEM  | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |         |
|---------|-----------------|---------------------|--------|---------|---------|---------|---------|
| GE220KV | RANGE BASE CASE | 20030 6BZYBI21      | 220.00 | 1.12439 | 1.12439 | 1.10000 | 0.90000 |
| GE220KV | RANGE BASE CASE | 20031 6LESEL51      | 110.00 | 1.13501 | 1.13501 | 1.10000 | 0.90000 |
| GE500KV | RANGE SINGLE 7  | 20002 6QSANI9       | 500.00 | 0.94912 | 0.97787 | 1.05000 | 0.95000 |
| GE220KV | RANGE SINGLE 32 | 20032 6TKVAR2       | 220.00 | 1.10973 | 1.07896 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 32 | 20033 6SOUKH2       | 220.00 | 1.11062 | 1.08890 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 47 | 20030 6BZYBI21      | 220.00 | 1.19101 | 1.12439 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 47 | 20031 6LESEL51      | 110.00 | 1.15710 | 1.13501 | 1.10000 | 0.90000 |
| GE220KV | RANGE SINGLE 48 | 20033 6SOUKH2       | 220.00 | 1.10941 | 1.08890 | 1.10000 | 0.90000 |

#### CONTINGENCY LEGEND:

| LABEL     | EVENTS                                                                          |
|-----------|---------------------------------------------------------------------------------|
| SINGLE 1  | : OPEN LINE FROM BUS 542 [XGE_TR21 220.00] TO BUS 20017 [6BATUM2 220.00] CKT 1  |
| SINGLE 2  | : OPEN LINE FROM BUS 543 [XGE_RU91 500.00] TO BUS 20000 [6HENGU9 500.00] CKT 1  |
| SINGLE 3  | : OPEN LINE FROM BUS 546 [XGE_RU21 220.00] TO BUS 20030 [6BZYBI21 220.00] CKT 1 |
| SINGLE 4  | : OPEN LINE FROM BUS 552 [XGE_RU51 110.00] TO BUS 20031 [6LESEL51 110.00] CKT 1 |
| SINGLE 5  | : OPEN LINE FROM BUS 20000 [6HENGU9 500.00] TO BUS 20001 [6ZESTA9 500.00] CKT 1 |
| SINGLE 6  | : OPEN LINE FROM BUS 20000 [6HENGU9 500.00] TO BUS 20005 [6HENGU2 220.00] CKT 1 |
| SINGLE 7  | : OPEN LINE FROM BUS 20001 [6ZESTA9 500.00] TO BUS 20002 [6QSANI9 500.00] CKT 1 |
| SINGLE 8  | : OPEN LINE FROM BUS 20001 [6ZESTA9 500.00] TO BUS 20006 [6ZESTA2 220.00] CKT 1 |
| SINGLE 9  | : OPEN LINE FROM BUS 20001 [6ZESTA9 500.00] TO BUS 20006 [6ZESTA2 220.00] CKT 2 |
| SINGLE 10 | : OPEN LINE FROM BUS 20001 [6ZESTA9 500.00] TO BUS 20028 [6ACHAL9 500.00] CKT 1 |
| SINGLE 11 | : OPEN LINE FROM BUS 20002 [6QSANI9 500.00] TO BUS 20003 [6TGARD9 500.00] CKT 1 |
| SINGLE 12 | : OPEN LINE FROM BUS 20002 [6QSANI9 500.00] TO BUS 20007 [6QSANI2 220.00] CKT 1 |
| SINGLE 13 | : OPEN LINE FROM BUS 20003 [6TGARD9 500.00] TO BUS 20008 [6TGARD2 220.00] CKT 1 |
| SINGLE 14 | : OPEN LINE FROM BUS 20003 [6TGARD9 500.00] TO BUS 20028 [6ACHAL9 500.00] CKT 1 |
| SINGLE 15 | : OPEN LINE FROM BUS 20004 [6TGARD8 330.00] TO BUS 20008 [6TGARD2 220.00] CKT 1 |
| SINGLE 16 | : OPEN LINE FROM BUS 20005 [6HENGU2 220.00] TO BUS 20009 [6VARDI2 220.00] CKT 1 |



|           |   |                          |           |         |              |          |         |       |
|-----------|---|--------------------------|-----------|---------|--------------|----------|---------|-------|
| SINGLE 17 | : | OPEN LINE FROM BUS 20006 | [6ZESTA2  | 220.00] | TO BUS 20013 | [6QUTAI2 | 220.00] | CKT 1 |
| SINGLE 18 | : | OPEN LINE FROM BUS 20006 | [6ZESTA2  | 220.00] | TO BUS 20013 | [6QUTAI2 | 220.00] | CKT 2 |
| SINGLE 19 | : | OPEN LINE FROM BUS 20006 | [6ZESTA2  | 220.00] | TO BUS 20015 | [6KHASH2 | 220.00] | CKT 1 |
| SINGLE 20 | : | OPEN LINE FROM BUS 20007 | [6QSANI2  | 220.00] | TO BUS 20016 | [6GORI 2 | 220.00] | CKT 1 |
| SINGLE 21 | : | OPEN LINE FROM BUS 20007 | [6QSANI2  | 220.00] | TO BUS 20019 | [6JHINV2 | 220.00] | CKT 1 |
| SINGLE 22 | : | OPEN LINE FROM BUS 20007 | [6QSANI2  | 220.00] | TO BUS 20020 | [6LISI 2 | 220.00] | CKT 1 |
| SINGLE 23 | : | OPEN LINE FROM BUS 20007 | [6QSANI2  | 220.00] | TO BUS 20020 | [6LISI 2 | 220.00] | CKT 2 |
| SINGLE 24 | : | OPEN LINE FROM BUS 20007 | [6QSANI2  | 220.00] | TO BUS 20022 | [6GLDAN2 | 220.00] | CKT 1 |
| SINGLE 25 | : | OPEN LINE FROM BUS 20008 | [6TGARD2  | 220.00] | TO BUS 20020 | [6LISI 2 | 220.00] | CKT 1 |
| SINGLE 26 | : | OPEN LINE FROM BUS 20008 | [6TGARD2  | 220.00] | TO BUS 20023 | [6NAVTL2 | 220.00] | CKT 1 |
| SINGLE 27 | : | OPEN LINE FROM BUS 20008 | [6TGARD2  | 220.00] | TO BUS 20024 | [6RUSTA2 | 220.00] | CKT 1 |
| SINGLE 28 | : | OPEN LINE FROM BUS 20008 | [6TGARD2  | 220.00] | TO BUS 20024 | [6RUSTA2 | 220.00] | CKT 2 |
| SINGLE 29 | : | OPEN LINE FROM BUS 20008 | [6TGARD2  | 220.00] | TO BUS 20026 | [6MARNE2 | 220.00] | CKT 1 |
| SINGLE 30 | : | OPEN LINE FROM BUS 20009 | [6VARDI2  | 220.00] | TO BUS 20010 | [6ZUGDI2 | 220.00] | CKT 1 |
| SINGLE 31 | : | OPEN LINE FROM BUS 20009 | [6VARDI2  | 220.00] | TO BUS 20017 | [6BATUM2 | 220.00] | CKT 1 |
| SINGLE 33 | : | OPEN LINE FROM BUS 20010 | [6ZUGDI2  | 220.00] | TO BUS 20011 | [6MENJI2 | 220.00] | CKT 1 |
| SINGLE 34 | : | OPEN LINE FROM BUS 20011 | [6MENJI2  | 220.00] | TO BUS 20012 | [6TSCHA2 | 220.00] | CKT 1 |
| SINGLE 35 | : | OPEN LINE FROM BUS 20011 | [6MENJI2  | 220.00] | TO BUS 20013 | [6QUTAI2 | 220.00] | CKT 1 |
| SINGLE 36 | : | OPEN LINE FROM BUS 20011 | [6MENJI2  | 220.00] | TO BUS 20017 | [6BATUM2 | 220.00] | CKT 1 |
| SINGLE 37 | : | OPEN LINE FROM BUS 20012 | [6TSCHA2  | 220.00] | TO BUS 20013 | [6QUTAI2 | 220.00] | CKT 1 |
| SINGLE 38 | : | OPEN LINE FROM BUS 20012 | [6TSCHA2  | 220.00] | TO BUS 20018 | [6LAJAN2 | 220.00] | CKT 1 |
| SINGLE 39 | : | OPEN LINE FROM BUS 20015 | [6KHASH2  | 220.00] | TO BUS 20016 | [6GORI 2 | 220.00] | CKT 1 |
| SINGLE 40 | : | OPEN LINE FROM BUS 20020 | [6LISI 2  | 220.00] | TO BUS 20021 | [6DIDUB2 | 220.00] | CKT 1 |
| SINGLE 41 | : | OPEN LINE FROM BUS 20020 | [6LISI 2  | 220.00] | TO BUS 20021 | [6DIDUB2 | 220.00] | CKT 2 |
| SINGLE 42 | : | OPEN LINE FROM BUS 20020 | [6LISI 2  | 220.00] | TO BUS 20026 | [6MARNE2 | 220.00] | CKT 1 |
| SINGLE 43 | : | OPEN LINE FROM BUS 20022 | [6GLDAN2  | 220.00] | TO BUS 20023 | [6NAVTL2 | 220.00] | CKT 1 |
| SINGLE 44 | : | OPEN LINE FROM BUS 20022 | [6GLDAN2  | 220.00] | TO BUS 20024 | [6RUSTA2 | 220.00] | CKT 1 |
| SINGLE 45 | : | OPEN LINE FROM BUS 20023 | [6NAVTL2  | 220.00] | TO BUS 20025 | [6KHRAM2 | 220.00] | CKT 1 |
| SINGLE 46 | : | OPEN LINE FROM BUS 20024 | [6RUSTA2  | 220.00] | TO BUS 20027 | [6GURJA2 | 220.00] | CKT 1 |
| SINGLE 47 | : | OPEN LINE FROM BUS 20030 | [6BZYBI21 | 220.00] | TO BUS 20033 | [6SOUKH2 | 220.00] | CKT 1 |

### 4.6.3. Moldova

#### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0  
PERCENT OF RATING SET A  
ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: D:\miksa\0\BlackSea\0report\MD\MD.acc  
DISTRIBUTION FACTOR FILE: D:\miksa\0\BlackSea\0report\MD\MD.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\MD\MD.sub  
MONITORED ELEMENT FILE: D:\miksa\0\BlackSea\0report\MD\MD.mon  
CONTINGENCY DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\MD\MD.con

| <----- MONITORED BRANCH -----> |        |       |         |        | CONTINGENCY | RATING | FLOW  | %     |
|--------------------------------|--------|-------|---------|--------|-------------|--------|-------|-------|
| 520*XMD_UA82                   | 330.00 | 30100 | 5MREPP8 | 330.00 | 1 BASE CASE | 120.0  | 118.8 | 100.7 |
| 520*XMD_UA82                   | 330.00 | 30100 | 5MREPP8 | 330.00 | 1 SINGLE 3  | 120.0  | 235.0 | 199.4 |
| 520*XMD_UA82                   | 330.00 | 30100 | 5MREPP8 | 330.00 | 1 SINGLE 7  | 120.0  | 137.2 | 116.6 |

MONITORED VOLTAGE REPORT:


| SYSTEM  | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |         |
|---------|-----------------|---------------------|--------|---------|---------|---------|---------|
| MD400KV | RANGE BASE CASE | 32051 5BALTS1       | 400.00 | 1.05943 | 1.05943 | 1.05000 | 0.95000 |
| MD330KV | RANGE SINGLE 5  | 33091 5RIBNI82      | 330.00 | 0.88663 | 0.97548 | 1.10000 | 0.90900 |

#### BLACKSEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0  
PERCENT OF RATING SET A  
ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: D:\miksa\0\BlackSea\0report\MD\MDSUMMER.acc  
DISTRIBUTION FACTOR FILE: D:\miksa\0\BlackSea\0report\MD\MD1.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\MD\MD.sub  
MONITORED ELEMENT FILE: D:\miksa\0\BlackSea\0report\MD\MD.mon  
CONTINGENCY DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\MD\MD.con

| <----- MONITORED BRANCH -----> |                 |                     |        |         | CONTINGENCY | RATING  | FLOW    | % |
|--------------------------------|-----------------|---------------------|--------|---------|-------------|---------|---------|---|
| MONITORED VOLTAGE REPORT:      |                 |                     |        |         |             |         |         |   |
| SYSTEM                         | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX       | V-MIN   |         |   |
| OWNER 301                      | RANGE BASE CASE | 30120 5MREPP1       | 400.00 | 1.05590 | 1.05590     | 1.05000 | 0.95000 |   |



#### CONTINGENCY LEGEND:

##### LABEL EVENTS

|           |   |                          |           |         |              |           |         |       |
|-----------|---|--------------------------|-----------|---------|--------------|-----------|---------|-------|
| SINGLE 1  | : | OPEN LINE FROM BUS 519   | [XMD_UA81 | 330.00] | TO BUS 32049 | [5BALTS8  | 330.00] | CKT 1 |
| SINGLE 2  | : | OPEN LINE FROM BUS 520   | [XMD_UA82 | 330.00] | TO BUS 30100 | [5MREPP8  | 330.00] | CKT 1 |
| SINGLE 3  | : | OPEN LINE FROM BUS 521   | [XMD_UA83 | 330.00] | TO BUS 30100 | [5MREPP8  | 330.00] | CKT 1 |
| SINGLE 4  | : | OPEN LINE FROM BUS 522   | [XMD_UA84 | 330.00] | TO BUS 33035 | [5RIBNI81 | 330.00] | CKT 1 |
| SINGLE 5  | : | OPEN LINE FROM BUS 523   | [XMD_UA85 | 330.00] | TO BUS 33091 | [5RIBNI82 | 330.00] | CKT 2 |
| SINGLE 6  | : | OPEN LINE FROM BUS 524   | [XMD_UA86 | 330.00] | TO BUS 30100 | [5MREPP8  | 330.00] | CKT 1 |
| SINGLE 7  | : | OPEN LINE FROM BUS 525   | [XMD_UA87 | 330.00] | TO BUS 30100 | [5MREPP8  | 330.00] | CKT 1 |
| SINGLE 8  | : | OPEN LINE FROM BUS 601   | [XSV_BA11 | 400.00] | TO BUS 32051 | [5BALTS1  | 400.00] | CKT 1 |
| SINGLE 9  | : | OPEN LINE FROM BUS 30100 | [5MREPP8  | 330.00] | TO BUS 37043 | [5HBK1 81 | 330.00] | CKT 1 |
| SINGLE 10 | : | OPEN LINE FROM BUS 30100 | [5MREPP8  | 330.00] | TO BUS 37044 | [5HBK2 82 | 330.00] | CKT 1 |
| SINGLE 11 | : | OPEN LINE FROM BUS 37041 | [5HBK 81  | 330.00] | TO BUS 37042 | [5HBK 82  | 330.00] | CKT 1 |
| SINGLE 12 | : | OPEN LINE FROM BUS 37041 | [5HBK 81  | 330.00] | TO BUS 37043 | [5HBK1 81 | 330.00] | CKT 1 |
| SINGLE 13 | : | OPEN LINE FROM BUS 37042 | [5HBK 82  | 330.00] | TO BUS 37044 | [5HBK2 82 | 330.00] | CKT 1 |

## 4.6.4. Romania

### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)

CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0  
PERCENT OF RATING SET A

ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE


AC CONTINGENCY RESULTS FILE: D:\miksa\0\BlackSea\0report\R0\romwin.acc  
DISTRIBUTION FACTOR FILE: D:\miksa\0\BlackSea\0report\R0\rom.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\R0\Rom.sub  
MONITORED ELEMENT FILE: D:\miksa\0\BlackSea\0report\R0\Rom.mon  
CONTINGENCY DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\R0\Rom.CON

| <-----         | MONITORED BRANCH | <----->        | CONTINGENCY         | RATING | FLOW  | %     |
|----------------|------------------|----------------|---------------------|--------|-------|-------|
| 48040*RL0TRU2  | 220.00           | 48100 RSIBIU2  | 220.00 2 SINGLE 6   | 333.4  | 518.2 | 147.2 |
| 48040*RL0TRU2  | 220.00           | 48100 RSIBIU2  | 220.00 1 SINGLE 7   | 333.4  | 518.2 | 147.2 |
| 48079 RBUC.S2B | 220.00           | 49051*RFUNDE22 | 220.00 1 SINGLE 14  | 304.8  | 340.5 | 105.0 |
| 48079 RBUC.S2B | 220.00           | 49051*RFUNDE22 | 220.00 1 SINGLE 50  | 304.8  | 401.1 | 122.9 |
| 48079 RBUC.S2B | 220.00           | 49051*RFUNDE22 | 220.00 1 SINGLE 51  | 304.8  | 333.4 | 101.8 |
| 48073*RFUNDE21 | 220.00           | 48079 RBUC.S2B | 220.00 1 SINGLE 59  | 304.8  | 330.5 | 101.1 |
| 48904*RBRAZI1  | 400.00           | 48905 RBRAZI2A | 220.00 1 SINGLE 59  | 400.0  | 404.6 | 101.1 |
| 48079 RBUC.S2B | 220.00           | 49051*RFUNDE22 | 220.00 1 SINGLE 82  | 304.8  | 328.9 | 100.8 |
| 48079 RBUC.S2B | 220.00           | 49051*RFUNDE22 | 220.00 1 SINGLE 86  | 304.8  | 329.2 | 101.0 |
| 48079 RBUC.S2B | 220.00           | 49051*RFUNDE22 | 220.00 1 SINGLE 93  | 304.8  | 350.1 | 107.5 |
| 48079 RBUC.S2B | 220.00           | 49051*RFUNDE22 | 220.00 1 SINGLE 106 | 304.8  | 366.9 | 112.5 |

#### MONITORED VOLTAGE REPORT:

| SYSTEM | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |
|--------|-----------------|---------------------|--------|---------|---------|---------|
| '4-220 | RANGE BASE CASE | 48012 RGUTIN22      | 220.00 | 1.12869 | 1.12869 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48023 RFOCSA2       | 220.00 | 1.11161 | 1.11161 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48041 RAREF 2       | 220.00 | 1.10623 | 1.10623 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48042 RRIURE2       | 220.00 | 1.10862 | 1.10862 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48043 RSTUPA2       | 220.00 | 1.10767 | 1.10767 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48074 RL.SAR2       | 220.00 | 1.11838 | 1.11838 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48075 RFILES2       | 220.00 | 1.11376 | 1.11376 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48076 RBARB02       | 220.00 | 1.11336 | 1.11336 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48077 RGUTIN21      | 220.00 | 1.12481 | 1.12481 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48078 RDUMBR2       | 220.00 | 1.10691 | 1.10691 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48080 RMUNTE2       | 220.00 | 1.12638 | 1.12638 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48081 RFAI 2        | 220.00 | 1.13089 | 1.13089 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48082 RSUCEA2       | 220.00 | 1.12670 | 1.12670 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48083 RSTEJA2       | 220.00 | 1.10119 | 1.10119 | 1.10000 |
| '4-400 | RANGE BASE CASE | 48010 RDOMNE1       | 400.00 | 1.05592 | 1.05592 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48011 RBUC.S1       | 400.00 | 1.05531 | 1.05531 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48014 RSUCEA1       | 400.00 | 1.06569 | 1.06569 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48015 RPELIC1       | 400.00 | 1.06184 | 1.06184 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48016 RG.IAL1       | 400.00 | 1.06467 | 1.06467 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48017 RCONST1       | 400.00 | 1.06214 | 1.06214 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48019 RTULCE1       | 400.00 | 1.06398 | 1.06398 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48020 RISACC1       | 400.00 | 1.06815 | 1.06815 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48021 RL.SAR1       | 400.00 | 1.06742 | 1.06742 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48022 RSMIRD1       | 400.00 | 1.06950 | 1.06950 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48024 RGUTIN1       | 400.00 | 1.07301 | 1.07301 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48025 RBACAU2       | 400.00 | 1.07234 | 1.07234 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48031 RBRAS01       | 400.00 | 1.06148 | 1.06148 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48032 RDIRST1       | 400.00 | 1.06081 | 1.06081 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48034 RSIBIU1       | 400.00 | 1.05520 | 1.05520 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48036 RIERNU1       | 400.00 | 1.06208 | 1.06208 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48037 RGADAL1       | 400.00 | 1.05922 | 1.05922 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48038 RCLUJ 1       | 400.00 | 1.05582 | 1.05582 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48904 RBRAZI1       | 400.00 | 1.05321 | 1.05321 | 1.05000 |
| '4-400 | RANGE BASE CASE | 48950 RROMAN2       | 400.00 | 1.07069 | 1.07069 | 1.05000 |





|        |                  |       |          |        |         |         |         |         |
|--------|------------------|-------|----------|--------|---------|---------|---------|---------|
| '4-400 | RANGE BASE CASE  | 48973 | RCERNA1  | 400.00 | 1.06228 | 1.06228 | 1.05000 | 0.95000 |
| '4-400 | RANGE BASE CASE  | 48974 | RMEDGI1  | 400.00 | 1.06138 | 1.06138 | 1.05000 | 0.95000 |
| '4-110 | RANGE SINGLE 14  | 48409 | RCOMAR5  | 110.00 | 0.89945 | 0.95923 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48349 | RDRAGO5  | 110.00 | 0.80751 | 1.01870 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48350 | RVLAD 5  | 110.00 | 0.76636 | 1.01544 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48351 | RDOR M5  | 110.00 | 0.72270 | 1.01488 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48352 | RLEHLI5  | 110.00 | 0.67992 | 1.01670 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48353 | RTAMAD5  | 110.00 | 0.67237 | 1.01181 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48354 | RMOSTI5  | 110.00 | 0.67125 | 1.02255 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48355 | RCIORN5  | 110.00 | 0.66474 | 1.01871 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 79  | 48356 | ROLTEN5  | 110.00 | 0.65888 | 1.01503 | 1.12000 | 0.90000 |
| '4-220 | RANGE SINGLE 79  | 48855 | RMOSTI2  | 220.00 | 0.70585 | 1.08338 | 1.10000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48309 | RPOGOA5  | 110.00 | 0.89284 | 1.01406 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48310 | RBUZAU5S | 110.00 | 0.89715 | 1.01773 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48311 | RBUZAU5E | 110.00 | 0.89739 | 1.01749 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48312 | RM.PLA51 | 110.00 | 0.89981 | 1.01868 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48313 | RM.PLA52 | 110.00 | 0.89974 | 1.01863 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48315 | RRM.SA5  | 110.00 | 0.89681 | 1.01861 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48318 | RBUZAU5C | 110.00 | 0.89941 | 1.01873 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 86  | 48926 | RCONTA5  | 110.00 | 0.89769 | 1.01740 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48463 | RLECHI5  | 110.00 | 0.83745 | 0.91071 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48464 | RSARAT5  | 110.00 | 0.83912 | 0.91221 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48465 | RVIIS051 | 110.00 | 0.84067 | 0.91355 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48466 | RBISTR5  | 110.00 | 0.83541 | 0.90862 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48467 | RNASAU5  | 110.00 | 0.84010 | 0.91254 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48468 | RDEJ 5   | 110.00 | 0.86900 | 0.93785 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48469 | RBECL5   | 110.00 | 0.85383 | 0.92619 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48470 | RCELUL5  | 110.00 | 0.86060 | 0.93253 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48471 | RCOLDA5  | 110.00 | 0.85635 | 0.92709 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48505 | RBUNES5  | 110.00 | 0.87559 | 0.95096 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48506 | RTAGA 5  | 110.00 | 0.87665 | 0.95082 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48507 | RJUCU 5  | 110.00 | 0.89812 | 0.97853 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48508 | RAPAH15  | 110.00 | 0.89737 | 0.97784 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48519 | RTURDA5  | 110.00 | 0.89824 | 0.96690 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48520 | RMIHAI52 | 110.00 | 0.89633 | 0.96546 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48521 | RC.TUR5  | 110.00 | 0.89297 | 0.96308 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48522 | RPOIAN5  | 110.00 | 0.89647 | 0.96660 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48523 | RIERNU51 | 110.00 | 0.89826 | 0.96844 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48525 | RCALAR52 | 110.00 | 0.89304 | 0.96316 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48526 | RLUDUS5  | 110.00 | 0.89465 | 0.96496 | 1.12000 | 0.90000 |
| '4-110 | RANGE SINGLE 133 | 48863 | RGHERL5  | 110.00 | 0.88451 | 0.96208 | 1.12000 | 0.90000 |
| '4-400 | RANGE SINGLE 133 | 48038 | RCLUJ 1  | 400.00 | 0.91652 | 1.05582 | 1.05000 | 0.95000 |

# BLACKSEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0

PERCENT OF RATING SET A

ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: D:\miksa\0\BlackSea\0report\R0\romsum.acc  
DISTRIBUTION FACTOR FILE: D:\miksa\0\BlackSea\0report\R0\rom.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\R0\Rom.sub  
MONITORED ELEMENT FILE: D:\miksa\0\BlackSea\0report\R0\Rom.mon  
CONTINGENCY DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\R0\Rom.CON


| <----- MONITORED BRANCH -----> | CONTINGENCY                           | RATING | FLOW   | %     |
|--------------------------------|---------------------------------------|--------|--------|-------|
| 48001*RTANTA1                  | 400.00 49113 RTURCEG4 24.000 1 GENMAX | 400.0  | 1001.7 | 250.4 |

## MONITORED VOLTAGE REPORT:

| SYSTEM | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |
|--------|-----------------|---------------------|--------|---------|---------|---------|
| '4-220 | RANGE BASE CASE | 48080 RMUNTE2       | 220.00 | 1.10185 | 1.10185 | 1.10000 |
| '4-220 | RANGE BASE CASE | 48081 RFAI 2        | 220.00 | 1.10144 | 1.10144 | 1.10000 |


## CONTINGENCY LEGEND:

| LABEL   | EVENTS                                                                                                                                                         |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|
| INT-21  | : OPEN LINE FROM BUS 21 [XDO_IS11 400.00] TO BUS 12461 [VDOBRU1 400.00] CKT 1<br>OPEN LINE FROM BUS 21 [XDO_IS11 400.00] TO BUS 48020 [RISACC1 400.00] CKT 1   |
| INT-22  | : OPEN LINE FROM BUS 22 [XKO_TI11 400.00] TO BUS 12440 [VAEC_41 400.00] CKT 1<br>OPEN LINE FROM BUS 22 [XKO_TI11 400.00] TO BUS 48001 [RTANTA1 400.00] CKT 1   |
| INT-23  | : OPEN LINE FROM BUS 23 [XKO_TI12 400.00] TO BUS 12440 [VAEC_41 400.00] CKT 1<br>OPEN LINE FROM BUS 23 [XKO_TI12 400.00] TO BUS 48001 [RTANTA1 400.00] CKT 2   |
| INT-75  | : OPEN LINE FROM BUS 75 [XSA_AR11 400.00] TO BUS 48008 [RARAD 1 400.00] CKT 1<br>OPEN LINE FROM BUS 75 [XSA_AR11 400.00] TO BUS 80160 [MSAFA 1 400.00] CKT 1   |
| INT-84  | : OPEN LINE FROM BUS 84 [XRO_MU11 400.00] TO BUS 48039 [RROSIO1 400.00] CKT 1<br>OPEN LINE FROM BUS 84 [XRO_MU11 400.00] TO BUS 70919 [UMUKAC11 400.00] CKT 1  |
| INT-85  | : OPEN LINE FROM BUS 85 [XPF_DJ11 400.00] TO BUS 48004 [RP.D.F1 400.00] CKT 1<br>OPEN LINE FROM BUS 85 [XPF_DJ11 400.00] TO BUS 80102 [JHDJE11 400.00] CKT 1   |
| INT-181 | : OPEN LINE FROM BUS 181 [XVA_IS11 400.00] TO BUS 12460 [VVARNA1 400.00] CKT 1<br>OPEN LINE FROM BUS 181 [XVA_IS11 400.00] TO BUS 48020 [RISACC1 400.00] CKT 1 |
| INT-219 | : OPEN LINE FROM BUS 219 [XBE_OR11 400.00] TO BUS 48009 [RNADAB1 400.00] CKT 1<br>OPEN LINE FROM BUS 219 [XBE_OR11 400.00] TO BUS 80152 [MBEKO 1 400.00] CKT 1 |
| INT-601 | : OPEN LINE FROM BUS 601 [XSV_BA11 400.00] TO BUS 32051 [5BALTS1 400.00] CKT 1                                                                                 |



|           |                                                                                   |
|-----------|-----------------------------------------------------------------------------------|
|           | OPEN LINE FROM BUS 601 [XSV_BA11 400.00] TO BUS 48014 [RSUCEA1 400.00] CKT 1      |
| INT-602   | : OPEN LINE FROM BUS 602 [XVK_IS11 400.00] TO BUS 36046 [5VULKA1 400.00] CKT 1    |
|           | OPEN LINE FROM BUS 602 [XVK_IS11 400.00] TO BUS 48020 [RISACC1 400.00] CKT 1      |
| GENMAX    | : OPEN LINE FROM BUS 49218 [RCERNAG1 24.000] TO BUS 48973 [RCERNA1 400.00] CKT 1  |
|           | OPEN LINE FROM BUS 49218 [RCERNAG1 24.000] TO BUS 48973 [RCERNA1 400.00] CKT 2    |
| SINGLE 1  | : OPEN LINE FROM BUS 48005 [RP.D.F22 220.00] TO BUS 48050 [RCETAT2 220.00] CKT 1  |
| SINGLE 2  | : OPEN LINE FROM BUS 48005 [RP.D.F22 220.00] TO BUS 48050 [RCETAT2 220.00] CKT 2  |
| SINGLE 3  | : OPEN LINE FROM BUS 48012 [RGUTIN22 220.00] TO BUS 48080 [RMUNTE2 220.00] CKT 1  |
| SINGLE 4  | : OPEN LINE FROM BUS 48023 [RFOCSA2 220.00] TO BUS 48076 [RBARB02 220.00] CKT 1   |
| SINGLE 5  | : OPEN LINE FROM BUS 48023 [RFOCSA2 220.00] TO BUS 48077 [RGUTIN21 220.00] CKT 1  |
| SINGLE 6  | : OPEN LINE FROM BUS 48040 [RLOTRU2 220.00] TO BUS 48100 [RSIBIU2 220.00] CKT 1   |
| SINGLE 7  | : OPEN LINE FROM BUS 48040 [RLOTRU2 220.00] TO BUS 48100 [RSIBIU2 220.00] CKT 2   |
| SINGLE 8  | : OPEN LINE FROM BUS 48041 [RAREF 2 220.00] TO BUS 48042 [RRIURE2 220.00] CKT 1   |
| SINGLE 9  | : OPEN LINE FROM BUS 48041 [RAREF 2 220.00] TO BUS 48044 [RBRADU2 220.00] CKT 1   |
| SINGLE 10 | : OPEN LINE FROM BUS 48042 [RRIURE2 220.00] TO BUS 48043 [RSTUPA2 220.00] CKT 1   |
| SINGLE 11 | : OPEN LINE FROM BUS 48043 [RSTUPA2 220.00] TO BUS 48044 [RBRADU2 220.00] CKT 1   |
| SINGLE 12 | : OPEN LINE FROM BUS 48044 [RBRADU2 220.00] TO BUS 48900 [RPIT S2 220.00] CKT 1   |
| SINGLE 13 | : OPEN LINE FROM BUS 48044 [RBRADU2 220.00] TO BUS 48910 [RTIRG022 220.00] CKT 1  |
| SINGLE 14 | : OPEN LINE FROM BUS 48044 [RBRADU2 220.00] TO BUS 48911 [RTIRG021 220.00] CKT 1  |
| SINGLE 15 | : OPEN LINE FROM BUS 48045 [RURECH2 220.00] TO BUS 48061 [RSARDA2 220.00] CKT 1   |
| SINGLE 16 | : OPEN LINE FROM BUS 48045 [RURECH2 220.00] TO BUS 48062 [RTG.JI2 220.00] CKT 1   |
| SINGLE 17 | : OPEN LINE FROM BUS 48046 [RP.D.F2B 220.00] TO BUS 48047 [RP.D.F2A 220.00] CKT 1 |
| SINGLE 18 | : OPEN LINE FROM BUS 48047 [RP.D.F2A 220.00] TO BUS 48048 [RTR.SE21 220.00] CKT 1 |
| SINGLE 19 | : OPEN LINE FROM BUS 48047 [RP.D.F2A 220.00] TO BUS 48049 [RTR.SE22 220.00] CKT 1 |
| SINGLE 20 | : OPEN LINE FROM BUS 48047 [RP.D.F2A 220.00] TO BUS 48050 [RCETAT2 220.00] CKT 1  |
| SINGLE 21 | : OPEN LINE FROM BUS 48047 [RP.D.F2A 220.00] TO BUS 48050 [RCETAT2 220.00] CKT 2  |
| SINGLE 22 | : OPEN LINE FROM BUS 48047 [RP.D.F2A 220.00] TO BUS 48052 [RRESIT2 220.00] CKT 1  |
| SINGLE 23 | : OPEN LINE FROM BUS 48047 [RP.D.F2A 220.00] TO BUS 48052 [RRESIT2 220.00] CKT 2  |
| SINGLE 24 | : OPEN LINE FROM BUS 48052 [RRESIT2 220.00] TO BUS 48053 [RIAZ 22 220.00] CKT 1   |
| SINGLE 25 | : OPEN LINE FROM BUS 48052 [RRESIT2 220.00] TO BUS 48054 [RIAZ 21 220.00] CKT 1   |
| SINGLE 26 | : OPEN LINE FROM BUS 48052 [RRESIT2 220.00] TO BUS 48071 [RTIMIS2 220.00] CKT 1   |
| SINGLE 27 | : OPEN LINE FROM BUS 48052 [RRESIT2 220.00] TO BUS 48071 [RTIMIS2 220.00] CKT 2   |
| SINGLE 28 | : OPEN LINE FROM BUS 48055 [RSLATI2 220.00] TO BUS 48056 [RGRADI2 220.00] CKT 1   |
| SINGLE 29 | : OPEN LINE FROM BUS 48055 [RSLATI2 220.00] TO BUS 48057 [RCRAI02A 220.00] CKT 1  |
| SINGLE 30 | : OPEN LINE FROM BUS 48055 [RSLATI2 220.00] TO BUS 48058 [RCRAI02B 220.00] CKT 1  |
| SINGLE 31 | : OPEN LINE FROM BUS 48055 [RSLATI2 220.00] TO BUS 48060 [RISALN2A 220.00] CKT 1  |
| SINGLE 32 | : OPEN LINE FROM BUS 48056 [RGRADI2 220.00] TO BUS 48060 [RISALN2A 220.00] CKT 1  |
| SINGLE 33 | : OPEN LINE FROM BUS 48057 [RCRAI02A 220.00] TO BUS 48060 [RISALN2A 220.00] CKT 1 |
| SINGLE 34 | : OPEN LINE FROM BUS 48057 [RCRAI02A 220.00] TO BUS 48902 [RT.MAG2 220.00] CKT 1  |
| SINGLE 35 | : OPEN LINE FROM BUS 48058 [RCRAI02B 220.00] TO BUS 48060 [RISALN2A 220.00] CKT 1 |
| SINGLE 36 | : OPEN LINE FROM BUS 48058 [RCRAI02B 220.00] TO BUS 48061 [RSARDA2 220.00] CKT 1  |
| SINGLE 37 | : OPEN LINE FROM BUS 48062 [RTG.JI2 220.00] TO BUS 48063 [RPAROS2 220.00] CKT 1   |
| SINGLE 38 | : OPEN LINE FROM BUS 48063 [RPAROS2 220.00] TO BUS 48064 [RBARU 2 220.00] CKT 1   |
| SINGLE 39 | : OPEN LINE FROM BUS 48064 [RBARU 2 220.00] TO BUS 48065 [RHAJD 2 220.00] CKT 1   |
| SINGLE 40 | : OPEN LINE FROM BUS 48065 [RHAJD 2 220.00] TO BUS 48066 [RPESTI2 220.00] CKT 1   |
| SINGLE 41 | : OPEN LINE FROM BUS 48065 [RHAJD 2 220.00] TO BUS 48068 [RMINTI2B 220.00] CKT 1  |
| SINGLE 42 | : OPEN LINE FROM BUS 48065 [RHAJD 2 220.00] TO BUS 48914 [RR.MAR2 220.00] CKT 1   |
| SINGLE 43 | : OPEN LINE FROM BUS 48066 [RPESTI2 220.00] TO BUS 48067 [RMINTI2A 220.00] CKT 1  |
| SINGLE 44 | : OPEN LINE FROM BUS 48066 [RPESTI2 220.00] TO BUS 48068 [RMINTI2B 220.00] CKT 1  |
| SINGLE 45 | : OPEN LINE FROM BUS 48067 [RMINTI2A 220.00] TO BUS 48071 [RTIMIS2 220.00] CKT 1  |
| SINGLE 46 | : OPEN LINE FROM BUS 48068 [RMINTI2B 220.00] TO BUS 48097 [RAL.JL2 220.00] CKT 1  |
| SINGLE 47 | : OPEN LINE FROM BUS 48069 [RARAD 2 220.00] TO BUS 48070 [RSACAL2 220.00] CKT 1   |
| SINGLE 48 | : OPEN LINE FROM BUS 48069 [RARAD 2 220.00] TO BUS 48071 [RTIMIS2 220.00] CKT 1   |
| SINGLE 49 | : OPEN LINE FROM BUS 48070 [RSACAL2 220.00] TO BUS 48071 [RTIMIS2 220.00] CKT 1   |
| SINGLE 50 | : OPEN LINE FROM BUS 48073 [RFUNDE21 220.00] TO BUS 48079 [RBUC.S2B 220.00] CKT 1 |
| SINGLE 51 | : OPEN LINE FROM BUS 48073 [RFUNDE21 220.00] TO BUS 48905 [RBRAZI2A 220.00] CKT 1 |
| SINGLE 52 | : OPEN LINE FROM BUS 48074 [RL.SAR2 220.00] TO BUS 48075 [RFILES2 220.00] CKT 1   |
| SINGLE 53 | : OPEN LINE FROM BUS 48075 [RFILES2 220.00] TO BUS 48076 [RBARB02 220.00] CKT 1   |
| SINGLE 54 | : OPEN LINE FROM BUS 48077 [RGUTIN21 220.00] TO BUS 48078 [RDUMBR2 220.00] CKT 1  |
| SINGLE 55 | : OPEN LINE FROM BUS 48077 [RGUTIN21 220.00] TO BUS 48081 [RFAI 2 220.00] CKT 1   |
| SINGLE 56 | : OPEN LINE FROM BUS 48078 [RDUMBR2 220.00] TO BUS 48083 [RSTEJA2 220.00] CKT 1   |
| SINGLE 57 | : OPEN LINE FROM BUS 48079 [RBUC.S2B 220.00] TO BUS 48901 [RGHIZD2 220.00] CKT 1  |
| SINGLE 58 | : OPEN LINE FROM BUS 48079 [RBUC.S2B 220.00] TO BUS 48935 [RRAC.M2 220.00] CKT 1  |
| SINGLE 59 | : OPEN LINE FROM BUS 48079 [RBUC.S2B 220.00] TO BUS 49051 [RFUNDE22 220.00] CKT 1 |
| SINGLE 60 | : OPEN LINE FROM BUS 48080 [RMUNTE2 220.00] TO BUS 48081 [RFAI 2 220.00] CKT 1    |
| SINGLE 61 | : OPEN LINE FROM BUS 48081 [RFAI 2 220.00] TO BUS 48082 [RSUCEA2 220.00] CKT 1    |
| SINGLE 62 | : OPEN LINE FROM BUS 48083 [RSTEJA2 220.00] TO BUS 48084 [RGHEOR2 220.00] CKT 1   |
| SINGLE 63 | : OPEN LINE FROM BUS 48084 [RGHEOR2 220.00] TO BUS 48085 [RFINTI2 220.00] CKT 1   |
| SINGLE 64 | : OPEN LINE FROM BUS 48085 [RFINTI2 220.00] TO BUS 48086 [RUNGHE2 220.00] CKT 1   |
| SINGLE 65 | : OPEN LINE FROM BUS 48086 [RUNGHE2 220.00] TO BUS 48087 [RIERNU2 220.00] CKT 1   |
| SINGLE 66 | : OPEN LINE FROM BUS 48086 [RUNGHE2 220.00] TO BUS 48087 [RIERNU2 220.00] CKT 2   |
| SINGLE 67 | : OPEN LINE FROM BUS 48087 [RIERNU2 220.00] TO BUS 48088 [RCUPT.2 220.00] CKT 1   |
| SINGLE 68 | : OPEN LINE FROM BUS 48087 [RIERNU2 220.00] TO BUS 48093 [RBAIA 2 220.00] CKT 1   |
| SINGLE 69 | : OPEN LINE FROM BUS 48088 [RCUPT.2 220.00] TO BUS 48089 [RCLUJ 2 220.00] CKT 1   |
| SINGLE 70 | : OPEN LINE FROM BUS 48089 [RCLUJ 2 220.00] TO BUS 48090 [RMARIS2 220.00] CKT 1   |
| SINGLE 71 | : OPEN LINE FROM BUS 48089 [RCLUJ 2 220.00] TO BUS 48091 [RTIHAU2 220.00] CKT 1   |
| SINGLE 72 | : OPEN LINE FROM BUS 48089 [RCLUJ 2 220.00] TO BUS 48097 [RAL.JL2 220.00] CKT 1   |
| SINGLE 73 | : OPEN LINE FROM BUS 48091 [RTIHAU2 220.00] TO BUS 48093 [RBAIA 2 220.00] CKT 1   |
| SINGLE 74 | : OPEN LINE FROM BUS 48093 [RBAIA 2 220.00] TO BUS 48094 [RROSIO2 220.00] CKT 1   |
| SINGLE 75 | : OPEN LINE FROM BUS 48093 [RBAIA 2 220.00] TO BUS 48094 [RROSIO2 220.00] CKT 2   |
| SINGLE 76 | : OPEN LINE FROM BUS 48094 [RROSIO2 220.00] TO BUS 48095 [RVETIS2 220.00] CKT 1   |
| SINGLE 77 | : OPEN LINE FROM BUS 48097 [RAL.JL2 220.00] TO BUS 48098 [RSUGAG2 220.00] CKT 1   |
| SINGLE 78 | : OPEN LINE FROM BUS 48097 [RAL.JL2 220.00] TO BUS 48099 [RGILCE2 220.00] CKT 1   |
| SINGLE 79 | : OPEN LINE FROM BUS 48855 [RMOSTI2 220.00] TO BUS 48935 [RRAC.M2 220.00] CKT 1   |
| SINGLE 80 | : OPEN LINE FROM BUS 48901 [RGHIZD2 220.00] TO BUS 48902 [RT.MAG2 220.00] CKT 1   |
| SINGLE 81 | : OPEN LINE FROM BUS 48901 [RGHIZD2 220.00] TO BUS 48935 [RRAC.M2 220.00] CKT 1   |
| SINGLE 82 | : OPEN LINE FROM BUS 48905 [RBRAZI2A 220.00] TO BUS 48906 [RTELEA2 220.00] CKT 1  |





|            |   |                                                                                 |
|------------|---|---------------------------------------------------------------------------------|
| SINGLE 83  | : | OPEN LINE FROM BUS 48905 [RBRAZI2A 220.00] TO BUS 48910 [RTIRG022 220.00] CKT 1 |
| SINGLE 84  | : | OPEN LINE FROM BUS 48905 [RBRAZI2A 220.00] TO BUS 48911 [RTIRG021 220.00] CKT 1 |
| SINGLE 85  | : | OPEN LINE FROM BUS 48905 [RBRAZI2A 220.00] TO BUS 49051 [RFUNDE22 220.00] CKT 1 |
| SINGLE 86  | : | OPEN LINE FROM BUS 48906 [RTELEA2 220.00] TO BUS 48907 [RSTILP2 220.00] CKT 1   |
| SINGLE 87  | : | OPEN LINE FROM BUS 75 [XSA_AR11 400.00] TO BUS 48008 [RARAD 1 400.00] CKT 1     |
| SINGLE 88  | : | OPEN LINE FROM BUS 84 [XRO_MU11 400.00] TO BUS 48039 [RROSIO1 400.00] CKT 1     |
| SINGLE 89  | : | OPEN LINE FROM BUS 85 [XPF_DJ11 400.00] TO BUS 48004 [RP.D.F1 400.00] CKT 1     |
| SINGLE 90  | : | OPEN LINE FROM BUS 219 [XBE_OR11 400.00] TO BUS 48009 [RNADAB1 400.00] CKT 1    |
| SINGLE 91  | : | OPEN LINE FROM BUS 48001 [RTANTA1 400.00] TO BUS 48002 [RURECH1 400.00] CKT 1   |
| SINGLE 92  | : | OPEN LINE FROM BUS 48001 [RTANTA1 400.00] TO BUS 48007 [RSLATI1 400.00] CKT 1   |
| SINGLE 93  | : | OPEN LINE FROM BUS 48001 [RTANTA1 400.00] TO BUS 48033 [RBRADU1 400.00] CKT 1   |
| SINGLE 94  | : | OPEN LINE FROM BUS 48001 [RTANTA1 400.00] TO BUS 48034 [RSIBIU1 400.00] CKT 1   |
| SINGLE 95  | : | OPEN LINE FROM BUS 48002 [RURECH1 400.00] TO BUS 48004 [RP.D.F1 400.00] CKT 1   |
| SINGLE 96  | : | OPEN LINE FROM BUS 48002 [RURECH1 400.00] TO BUS 48010 [RDOMNE1 400.00] CKT 1   |
| SINGLE 97  | : | OPEN LINE FROM BUS 48003 [RMINTI1 400.00] TO BUS 48008 [RARAD 1 400.00] CKT 1   |
| SINGLE 98  | : | OPEN LINE FROM BUS 48003 [RMINTI1 400.00] TO BUS 48034 [RSIBIU1 400.00] CKT 1   |
| SINGLE 99  | : | OPEN LINE FROM BUS 48004 [RP.D.F1 400.00] TO BUS 48007 [RSLATI1 400.00] CKT 1   |
| SINGLE 100 | : | OPEN LINE FROM BUS 48004 [RP.D.F1 400.00] TO BUS 48018 [RRESIT1 400.00] CKT 1   |
| SINGLE 101 | : | OPEN LINE FROM BUS 48006 [RDRAGA1 400.00] TO BUS 48007 [RSLATI1 400.00] CKT 1   |
| SINGLE 102 | : | OPEN LINE FROM BUS 48007 [RSLATI1 400.00] TO BUS 48011 [RBUC.S1 400.00] CKT 1   |
| SINGLE 103 | : | OPEN LINE FROM BUS 48008 [RARAD 1 400.00] TO BUS 48009 [RNADAB1 400.00] CKT 1   |
| SINGLE 104 | : | OPEN LINE FROM BUS 48009 [RNADAB1 400.00] TO BUS 48096 [RORADE1 400.00] CKT 1   |
| SINGLE 105 | : | OPEN LINE FROM BUS 48010 [RDOMNE1 400.00] TO BUS 48011 [RBUC.S1 400.00] CKT 1   |
| SINGLE 106 | : | OPEN LINE FROM BUS 48010 [RDOMNE1 400.00] TO BUS 48904 [RBRAZI1 400.00] CKT 1   |
| SINGLE 107 | : | OPEN LINE FROM BUS 48011 [RBUC.S1 400.00] TO BUS 48015 [RPELIC1 400.00] CKT 1   |
| SINGLE 108 | : | OPEN LINE FROM BUS 48011 [RBUC.S1 400.00] TO BUS 48016 [RG.IAL1 400.00] CKT 1   |
| SINGLE 109 | : | OPEN LINE FROM BUS 48014 [RSUCEA1 400.00] TO BUS 48037 [RGADAL1 400.00] CKT 1   |
| SINGLE 110 | : | OPEN LINE FROM BUS 48014 [RSUCEA1 400.00] TO BUS 48950 [RROMAN2 400.00] CKT 1   |
| SINGLE 111 | : | OPEN LINE FROM BUS 48015 [RPELIC1 400.00] TO BUS 48973 [RCERNA1 400.00] CKT 1   |
| SINGLE 112 | : | OPEN LINE FROM BUS 48016 [RG.IAL1 400.00] TO BUS 48021 [RL.SAR1 400.00] CKT 1   |
| SINGLE 113 | : | OPEN LINE FROM BUS 48016 [RG.IAL1 400.00] TO BUS 48973 [RCERNA1 400.00] CKT 1   |
| SINGLE 114 | : | OPEN LINE FROM BUS 48016 [RG.IAL1 400.00] TO BUS 48973 [RCERNA1 400.00] CKT 2   |
| SINGLE 115 | : | OPEN LINE FROM BUS 48017 [RCONST1 400.00] TO BUS 48019 [RTULCE1 400.00] CKT 1   |
| SINGLE 116 | : | OPEN LINE FROM BUS 48017 [RCONST1 400.00] TO BUS 48973 [RCERNA1 400.00] CKT 1   |
| SINGLE 117 | : | OPEN LINE FROM BUS 48017 [RCONST1 400.00] TO BUS 48974 [RMEDGI1 400.00] CKT 1   |
| SINGLE 118 | : | OPEN LINE FROM BUS 48019 [RTULCE1 400.00] TO BUS 48020 [RISACC1 400.00] CKT 1   |
| SINGLE 119 | : | OPEN LINE FROM BUS 48020 [RISACC1 400.00] TO BUS 48021 [RL.SAR1 400.00] CKT 1   |
| SINGLE 120 | : | OPEN LINE FROM BUS 48020 [RISACC1 400.00] TO BUS 48022 [RSMIRD1 400.00] CKT 1   |
| SINGLE 121 | : | OPEN LINE FROM BUS 48020 [RISACC1 400.00] TO BUS 48022 [RSMIRD1 400.00] CKT 2   |
| SINGLE 122 | : | OPEN LINE FROM BUS 48021 [RL.SAR1 400.00] TO BUS 48022 [RSMIRD1 400.00] CKT 1   |
| SINGLE 123 | : | OPEN LINE FROM BUS 48022 [RSMIRD1 400.00] TO BUS 48024 [RGUTIN1 400.00] CKT 1   |
| SINGLE 124 | : | OPEN LINE FROM BUS 48024 [RGUTIN1 400.00] TO BUS 48025 [RBACAU2 400.00] CKT 1   |
| SINGLE 125 | : | OPEN LINE FROM BUS 48024 [RGUTIN1 400.00] TO BUS 48031 [RBRASO1 400.00] CKT 1   |
| SINGLE 126 | : | OPEN LINE FROM BUS 48025 [RBACAU2 400.00] TO BUS 48950 [RROMAN2 400.00] CKT 1   |
| SINGLE 127 | : | OPEN LINE FROM BUS 48031 [RBRASO1 400.00] TO BUS 48032 [RDIRST1 400.00] CKT 1   |
| SINGLE 128 | : | OPEN LINE FROM BUS 48031 [RBRASO1 400.00] TO BUS 48033 [RBRADU1 400.00] CKT 1   |
| SINGLE 129 | : | OPEN LINE FROM BUS 48031 [RBRASO1 400.00] TO BUS 48034 [RSIBIU1 400.00] CKT 1   |
| SINGLE 130 | : | OPEN LINE FROM BUS 48032 [RDIRST1 400.00] TO BUS 48904 [RBRAZI1 400.00] CKT 1   |
| SINGLE 131 | : | OPEN LINE FROM BUS 48034 [RSIBIU1 400.00] TO BUS 48036 [RIERNU1 400.00] CKT 1   |
| SINGLE 132 | : | OPEN LINE FROM BUS 48036 [RIERNU1 400.00] TO BUS 48037 [RGADAL1 400.00] CKT 1   |
| SINGLE 133 | : | OPEN LINE FROM BUS 48037 [RGADAL1 400.00] TO BUS 48038 [RCLUJ 1 400.00] CKT 1   |
| SINGLE 134 | : | OPEN LINE FROM BUS 48037 [RGADAL1 400.00] TO BUS 48039 [RROSIO1 400.00] CKT 1   |
| SINGLE 135 | : | OPEN LINE FROM BUS 48039 [RROSIO1 400.00] TO BUS 48096 [RORADE1 400.00] CKT 1   |
| SINGLE 136 | : | OPEN LINE FROM BUS 48973 [RCERNA1 400.00] TO BUS 48974 [RMEDGI1 400.00] CKT 1   |

All overloadings in Romanian network can be resolved with adequate operational activities (switching on shunts or change of topology by splitting busburs or redistribution of local load) and they are not related to interconnected operation of the system but local problems, like in case of tripping 220 kV line from Lotru-Sibiu second line is overloaded because over these two lines production of HPP Lotru is placed in the network. Reduction of production in Lotru is necessary.


#### 4.6.5. Russia

##### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

| <----- MONITORED BRANCH -----> |        |               |        | CONTINGENCY  | RATING | FLOW  | %     |
|--------------------------------|--------|---------------|--------|--------------|--------|-------|-------|
| 58370*4BUDEN9                  | 500.00 | 58371 4BUDEN8 | 330.00 | 2 SINGLE 112 | 500.0  | 573.8 | 114.8 |
| 58370*4BUDEN9                  | 500.00 | 58371 4BUDEN8 | 330.00 | 1 SINGLE 113 | 500.0  | 573.8 | 114.8 |

##### MONITORED VOLTAGE REPORT:

| SYSTEM    | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |
|-----------|-----------------|---------------------|--------|---------|---------|---------|
| OWNER 509 | RANGE BASE CASE | 50717 4ELEC 91      | 500.00 | 1.05626 | 1.05626 | 0.95000 |
| OWNER 502 | RANGE BASE CASE | 50583 4NARAB21      | 220.00 | 0.88476 | 0.88476 | 0.90000 |
| OWNER 502 | RANGE BASE CASE | 50585 4RASSV21      | 220.00 | 0.88317 | 0.88317 | 0.90000 |
| OWNER 502 | RANGE BASE CASE | 50587 4ASTRA21      | 220.00 | 0.88334 | 0.88334 | 0.90000 |
| OWNER 502 | RANGE BASE CASE | 50588 4BARR 21      | 220.00 | 0.87505 | 0.87505 | 0.90000 |
| OWNER 502 | RANGE BASE CASE | 50592 4GAZ 21       | 220.00 | 0.86214 | 0.86214 | 0.90000 |
| OWNER 502 | RANGE BASE CASE | 50597 4LIMAN21      | 220.00 | 0.89312 | 0.89312 | 0.90000 |
| OWNER 502 | RANGE SINGLE 10 | 58219 4KIRIL2       | 220.00 | 0.88000 | 0.91615 | 0.90000 |



|           |                  |                |        |         |         |         |         |
|-----------|------------------|----------------|--------|---------|---------|---------|---------|
| OWNER 502 | RANGE SINGLE 10  | 58263 4VOST02  | 220.00 | 0.89562 | 0.93030 | 1.15000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 30  | 50652 4ZELEZ81 | 330.00 | 0.89635 | 0.95416 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 31  | 50655 4SADOV81 | 330.00 | 0.89141 | 0.96977 | 1.10000 | 0.90000 |
| OWNER 509 | RANGE SINGLE 77  | 50949 4TRUBN91 | 500.00 | 0.88840 | 0.97962 | 1.05000 | 0.95000 |
| OWNER 502 | RANGE SINGLE 77  | 50580 4VLAD 21 | 220.00 | 0.86186 | 0.92964 | 1.15000 | 0.90000 |
| OWNER 502 | RANGE SINGLE 77  | 50595 4GAZ 22  | 220.00 | 0.87284 | 0.94473 | 1.15000 | 0.90000 |
| OWNER 509 | RANGE SINGLE 87  | 58370 4BUDEN9  | 500.00 | 0.94269 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 509 | RANGE SINGLE 87  | 58374 4BUDEN95 | 500.00 | 0.94269 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 502 | RANGE SINGLE 94  | 58217 4KRYMS2  | 220.00 | 0.89097 | 0.93692 | 1.15000 | 0.90000 |
| OWNER 502 | RANGE SINGLE 94  | 58219 4KIRIL2  | 220.00 | 0.86849 | 0.91615 | 1.15000 | 0.90000 |
| OWNER 502 | RANGE SINGLE 94  | 58263 4VOST02  | 220.00 | 0.88376 | 0.93030 | 1.15000 | 0.90000 |
| OWNER 509 | RANGE SINGLE 97  | 58370 4BUDEN9  | 500.00 | 0.94641 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 509 | RANGE SINGLE 97  | 58374 4BUDEN95 | 500.00 | 0.94641 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 509 | RANGE SINGLE 99  | 58370 4BUDEN9  | 500.00 | 0.94493 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 509 | RANGE SINGLE 99  | 58374 4BUDEN95 | 500.00 | 0.94493 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 509 | RANGE SINGLE 105 | 58370 4BUDEN9  | 500.00 | 0.94828 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 509 | RANGE SINGLE 105 | 58374 4BUDEN95 | 500.00 | 0.94828 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 502 | RANGE SINGLE 110 | 58219 4KIRIL2  | 220.00 | 0.88318 | 0.91615 | 1.15000 | 0.90000 |
| OWNER 502 | RANGE SINGLE 110 | 58263 4VOST02  | 220.00 | 0.89811 | 0.93030 | 1.15000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 116 | 58325 4MASHU8  | 330.00 | 0.89401 | 0.94943 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 116 | 58402 4PROHL8  | 330.00 | 0.87990 | 0.94693 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 116 | 58404 4BAKSA8  | 330.00 | 0.88459 | 0.94559 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 116 | 58430 4NALJC8  | 330.00 | 0.87863 | 0.94022 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 116 | 58505 4V-5008  | 330.00 | 0.88620 | 0.93076 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 116 | 58510 4V-2 8   | 330.00 | 0.89270 | 0.93531 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 116 | 58513 4MOZD08  | 330.00 | 0.87692 | 0.93414 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 122 | 58402 4PROHL8  | 330.00 | 0.88372 | 0.94693 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 122 | 58404 4BAKSA8  | 330.00 | 0.89335 | 0.94559 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 122 | 58430 4NALJC8  | 330.00 | 0.88748 | 0.94022 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 122 | 58505 4V-5008  | 330.00 | 0.78673 | 0.93076 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 122 | 58513 4MOZD08  | 330.00 | 0.83460 | 0.93414 | 1.10000 | 0.90000 |
| OWNER 509 | RANGE SINGLE 124 | 58370 4BUDEN9  | 500.00 | 0.94390 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 509 | RANGE SINGLE 124 | 58374 4BUDEN95 | 500.00 | 0.94390 | 0.97768 | 1.05000 | 0.95000 |
| OWNER 508 | RANGE SINGLE 124 | 58325 4MASHU8  | 330.00 | 0.89331 | 0.94943 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 124 | 58402 4PROHL8  | 330.00 | 0.87780 | 0.94693 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 124 | 58404 4BAKSA8  | 330.00 | 0.88375 | 0.94559 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 124 | 58430 4NALJC8  | 330.00 | 0.87777 | 0.94022 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 124 | 58505 4V-5008  | 330.00 | 0.80095 | 0.93076 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 124 | 58510 4V-2 8   | 330.00 | 0.80211 | 0.93531 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 124 | 58513 4MOZD08  | 330.00 | 0.83791 | 0.93414 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 126 | 58712 4DERBE8  | 330.00 | 0.89376 | 0.91871 | 1.10000 | 0.90000 |
| OWNER 508 | RANGE SINGLE 127 | 58712 4DERBE8  | 330.00 | 0.89381 | 0.91871 | 1.10000 | 0.90000 |


**BLACKSEA REGIONAL MODEL  
SUMMER MINIMUM LOAD 2010**

| <----- MONITORED BRANCH -----> |                  |                     |        | CONTINGENCY | RATING  | FLOW    | %       |
|--------------------------------|------------------|---------------------|--------|-------------|---------|---------|---------|
| MONITORED VOLTAGE REPORT:      |                  |                     |        |             |         |         |         |
| SYSTEM                         | CONTINGENCY      | <----- B U S -----> |        | V-CONT      | V-INIT  | V-MAX   | V-MIN   |
| OWNER 509                      | RANGE BASE CASE  | 50717 4ELEC 91      | 500.00 | 1.06560     | 1.06560 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 50758 4NVAES91      | 500.00 | 1.06051     | 1.06051 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 50801 4STOSK91      | 500.00 | 1.05285     | 1.05285 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 50813 4METAL91      | 500.00 | 1.05413     | 1.05413 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 50902 4BALAS91      | 500.00 | 1.06186     | 1.06186 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 50940 40TPNV91      | 500.00 | 1.05582     | 1.05582 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 58260 4CENTR9       | 500.00 | 1.05094     | 1.05094 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 58370 4BUDEN9       | 500.00 | 1.06250     | 1.06250 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE BASE CASE  | 58374 4BUDEN95      | 500.00 | 1.06257     | 1.06257 | 1.05000 | 0.95000 |
| OWNER 502                      | RANGE BASE CASE  | 50597 4LIMAN21      | 220.00 | 1.15040     | 1.15040 | 1.15000 | 0.90000 |
| OWNER 509                      | RANGE SINGLE 77  | 50934 4FROL091      | 500.00 | 1.07237     | 1.04644 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE SINGLE 78  | 50949 4TRUBN91      | 500.00 | 0.89869     | 0.96657 | 1.05000 | 0.95000 |
| OWNER 509                      | RANGE SINGLE 86  | 58194 4VDAES97      | 500.00 | 1.14198     | 1.01903 | 1.05000 | 0.95000 |
| OWNER 508                      | RANGE SINGLE 86  | 58332 4PRIKU8       | 330.00 | 1.12736     | 1.08515 | 1.10000 | 0.90000 |
| OWNER 508                      | RANGE SINGLE 86  | 58363 4BLAG08       | 330.00 | 1.10383     | 1.07737 | 1.10000 | 0.90000 |
| OWNER 508                      | RANGE SINGLE 86  | 58371 4BUDEN8       | 330.00 | 1.13283     | 1.08744 | 1.10000 | 0.90000 |
| OWNER 508                      | RANGE SINGLE 86  | 58373 4BUDEN82      | 330.00 | 1.13274     | 1.08738 | 1.10000 | 0.90000 |
| OWNER 509                      | RANGE SINGLE 110 | 58361 4STGRE91      | 500.00 | 1.05774     | 1.00628 | 1.05000 | 0.95000 |
| OWNER 508                      | RANGE SINGLE 131 | 58332 4PRIKU8       | 330.00 | 1.12256     | 1.08515 | 1.10000 | 0.90000 |
| OWNER 508                      | RANGE SINGLE 131 | 58363 4BLAG08       | 330.00 | 1.10476     | 1.07737 | 1.10000 | 0.90000 |
| OWNER 508                      | RANGE SINGLE 131 | 58371 4BUDEN8       | 330.00 | 1.12676     | 1.08744 | 1.10000 | 0.90000 |
| OWNER 508                      | RANGE SINGLE 131 | 58373 4BUDEN82      | 330.00 | 1.12683     | 1.08738 | 1.10000 | 0.90000 |
| OWNER 508                      | RANGE SINGLE 131 | 58773 4CHI298       | 330.00 | 1.24282     | 1.05061 | 1.10000 | 0.90000 |


**CONTINGENCY LEGEND:**

**LABEL                      EVENTS**

|           |   |                        |           |         |              |           |         |       |
|-----------|---|------------------------|-----------|---------|--------------|-----------|---------|-------|
| SINGLE 1  | : | OPEN LINE FROM BUS 506 | [XRU_UA01 | 750.00] | TO BUS 50678 | [4K AES02 | 750.00] | CKT 1 |
| SINGLE 2  | : | OPEN LINE FROM BUS 511 | [XRU_UA91 | 500.00] | TO BUS 58180 | [4SH-309  | 500.00] | CKT 1 |
| SINGLE 3  | : | OPEN LINE FROM BUS 512 | [XRU_UA92 | 500.00] | TO BUS 50758 | [4NVAES91 | 500.00] | CKT 0 |
| SINGLE 4  | : | OPEN LINE FROM BUS 513 | [XRU_UA81 | 330.00] | TO BUS 58146 | [4HCHGP8  | 330.00] | CKT 1 |
| SINGLE 5  | : | OPEN LINE FROM BUS 514 | [XRU_UA82 | 330.00] | TO BUS 50809 | [4VALUI81 | 330.00] | CKT 1 |
| SINGLE 6  | : | OPEN LINE FROM BUS 515 | [XRU_UA83 | 330.00] | TO BUS 50823 | [4SHEBE81 | 330.00] | CKT 1 |
| SINGLE 7  | : | OPEN LINE FROM BUS 516 | [XRU_UA84 | 330.00] | TO BUS 50663 | [4K AES81 | 330.00] | CKT 1 |
| SINGLE 8  | : | OPEN LINE FROM BUS 517 | [XRU_UA85 | 330.00] | TO BUS 50663 | [4K AES81 | 330.00] | CKT 1 |
| SINGLE 9  | : | OPEN LINE FROM BUS 518 | [XRU_UA86 | 330.00] | TO BUS 50811 | [4BELG081 | 330.00] | CKT 1 |
| SINGLE 10 | : | OPEN LINE FROM BUS 543 | [XGE_RU91 | 500.00] | TO BUS 58260 | [4CENTR9  | 500.00] | CKT 1 |



|           |   |                          |           |         |              |           |         |        |
|-----------|---|--------------------------|-----------|---------|--------------|-----------|---------|--------|
| SINGLE 11 | : | OPEN LINE FROM BUS 547   | [XAZ_RU81 | 330.00] | TO BUS 58712 | [4DERBE8  | 330.00] | CKT 1  |
| SINGLE 12 | : | OPEN LINE FROM BUS 553   | [XBY_RU01 | 750.00] | TO BUS 50540 | [4S AES01 | 750.00] | CKT 1  |
| SINGLE 13 | : | OPEN LINE FROM BUS 554   | [XBY_RU81 | 330.00] | TO BUS 50528 | [4ROSL381 | 330.00] | CKT 1  |
| SINGLE 14 | : | OPEN LINE FROM BUS 555   | [XBY_RU82 | 330.00] | TO BUS 50509 | [4TAL3381 | 330.00] | CKT 1  |
| SINGLE 15 | : | OPEN LINE FROM BUS 50509 | [4TAL3381 | 330.00] | TO BUS 50528 | [4ROSL381 | 330.00] | CKT 0  |
| SINGLE 16 | : | OPEN LINE FROM BUS 50513 | [4S AES91 | 500.00] | TO BUS 50530 | [4S AES81 | 330.00] | CKT 1  |
| SINGLE 17 | : | OPEN LINE FROM BUS 50513 | [4S AES91 | 500.00] | TO BUS 50530 | [4S AES81 | 330.00] | CKT 2  |
| SINGLE 18 | : | OPEN LINE FROM BUS 50513 | [4S AES91 | 500.00] | TO BUS 50540 | [4S AES01 | 750.00] | CKT 1  |
| SINGLE 19 | : | OPEN LINE FROM BUS 50513 | [4S AES91 | 500.00] | TO BUS 50540 | [4S AES01 | 750.00] | CKT 2  |
| SINGLE 20 | : | OPEN LINE FROM BUS 50513 | [4S AES91 | 500.00] | TO BUS 50963 | [4MIHAI91 | 500.00] | CKT 1  |
| SINGLE 21 | : | OPEN LINE FROM BUS 50513 | [4S AES91 | 500.00] | TO BUS 50963 | [4MIHAI91 | 500.00] | CKT 98 |
| SINGLE 22 | : | OPEN LINE FROM BUS 50528 | [4ROSL381 | 330.00] | TO BUS 50530 | [4S AES81 | 330.00] | CKT 1  |
| SINGLE 23 | : | OPEN LINE FROM BUS 50528 | [4ROSL381 | 330.00] | TO BUS 50530 | [4S AES81 | 330.00] | CKT 2  |
| SINGLE 24 | : | OPEN LINE FROM BUS 50540 | [4S AES01 | 750.00] | TO BUS 50554 | [4NBRAN01 | 750.00] | CKT 0  |
| SINGLE 25 | : | OPEN LINE FROM BUS 50554 | [4NBRAN01 | 750.00] | TO BUS 50555 | [4NBRAN91 | 500.00] | CKT 1  |
| SINGLE 26 | : | OPEN LINE FROM BUS 50554 | [4NBRAN01 | 750.00] | TO BUS 50555 | [4NBRAN91 | 500.00] | CKT 2  |
| SINGLE 27 | : | OPEN LINE FROM BUS 50554 | [4NBRAN01 | 750.00] | TO BUS 50675 | [4K AES01 | 750.00] | CKT 0  |
| SINGLE 28 | : | OPEN LINE FROM BUS 50555 | [4NBRAN91 | 500.00] | TO BUS 50717 | [4ELEC 91 | 500.00] | CKT 0  |
| SINGLE 29 | : | OPEN LINE FROM BUS 50652 | [4ZELEZ81 | 330.00] | TO BUS 50662 | [4UZNAJ81 | 330.00] | CKT 0  |
| SINGLE 30 | : | OPEN LINE FROM BUS 50652 | [4ZELEZ81 | 330.00] | TO BUS 50676 | [4K AES82 | 330.00] | CKT 0  |
| SINGLE 31 | : | OPEN LINE FROM BUS 50655 | [4SADOV81 | 330.00] | TO BUS 50662 | [4UZNAJ81 | 330.00] | CKT 0  |
| SINGLE 32 | : | OPEN LINE FROM BUS 50662 | [4UZNAJ81 | 330.00] | TO BUS 50669 | [4KURSK81 | 330.00] | CKT 0  |
| SINGLE 33 | : | OPEN LINE FROM BUS 50662 | [4UZNAJ81 | 330.00] | TO BUS 50676 | [4K AES82 | 330.00] | CKT 1  |
| SINGLE 34 | : | OPEN LINE FROM BUS 50662 | [4UZNAJ81 | 330.00] | TO BUS 50676 | [4K AES82 | 330.00] | CKT 2  |
| SINGLE 35 | : | OPEN LINE FROM BUS 50662 | [4UZNAJ81 | 330.00] | TO BUS 50811 | [4BELG081 | 330.00] | CKT 0  |
| SINGLE 36 | : | OPEN LINE FROM BUS 50663 | [4K AES81 | 330.00] | TO BUS 50676 | [4K AES82 | 330.00] | CKT 99 |
| SINGLE 37 | : | OPEN LINE FROM BUS 50663 | [4K AES81 | 330.00] | TO BUS 50678 | [4K AES02 | 750.00] | CKT 0  |
| SINGLE 38 | : | OPEN LINE FROM BUS 50669 | [4KURSK81 | 330.00] | TO BUS 50673 | [4SEIMS81 | 330.00] | CKT 0  |
| SINGLE 39 | : | OPEN LINE FROM BUS 50669 | [4KURSK81 | 330.00] | TO BUS 50676 | [4K AES82 | 330.00] | CKT 0  |
| SINGLE 40 | : | OPEN LINE FROM BUS 50675 | [4K AES01 | 750.00] | TO BUS 50676 | [4K AES82 | 330.00] | CKT 0  |
| SINGLE 41 | : | OPEN LINE FROM BUS 50675 | [4K AES01 | 750.00] | TO BUS 50678 | [4K AES02 | 750.00] | CKT 0  |
| SINGLE 42 | : | OPEN LINE FROM BUS 50678 | [4K AES02 | 750.00] | TO BUS 50816 | [4METAL01 | 750.00] | CKT 0  |
| SINGLE 43 | : | OPEN LINE FROM BUS 50703 | [4BORIN91 | 500.00] | TO BUS 50713 | [4LIPEC91 | 500.00] | CKT 0  |
| SINGLE 44 | : | OPEN LINE FROM BUS 50703 | [4BORIN91 | 500.00] | TO BUS 50717 | [4ELEC 91 | 500.00] | CKT 0  |
| SINGLE 45 | : | OPEN LINE FROM BUS 50703 | [4BORIN91 | 500.00] | TO BUS 50758 | [4NVAES91 | 500.00] | CKT 0  |
| SINGLE 46 | : | OPEN LINE FROM BUS 50713 | [4LIPEC91 | 500.00] | TO BUS 50860 | [4TAMBO91 | 500.00] | CKT 0  |
| SINGLE 47 | : | OPEN LINE FROM BUS 50713 | [4LIPEC91 | 500.00] | TO BUS 50902 | [4BALAS91 | 500.00] | CKT 0  |
| SINGLE 48 | : | OPEN LINE FROM BUS 50713 | [4LIPEC91 | 500.00] | TO BUS 50940 | [40TPNV91 | 500.00] | CKT 0  |
| SINGLE 49 | : | OPEN LINE FROM BUS 50713 | [4LIPEC91 | 500.00] | TO BUS 50962 | [4RGRES91 | 500.00] | CKT 1  |
| SINGLE 50 | : | OPEN LINE FROM BUS 50713 | [4LIPEC91 | 500.00] | TO BUS 50962 | [4RGRES91 | 500.00] | CKT 2  |
| SINGLE 51 | : | OPEN LINE FROM BUS 50758 | [4NVAES91 | 500.00] | TO BUS 50801 | [4STOSK91 | 500.00] | CKT 0  |
| SINGLE 52 | : | OPEN LINE FROM BUS 50758 | [4NVAES91 | 500.00] | TO BUS 50940 | [40TPNV91 | 500.00] | CKT 0  |
| SINGLE 53 | : | OPEN LINE FROM BUS 50760 | [4LISKI81 | 330.00] | TO BUS 50809 | [4VALUI81 | 330.00] | CKT 0  |
| SINGLE 54 | : | OPEN LINE FROM BUS 50801 | [4STOSK91 | 500.00] | TO BUS 50803 | [4STOSK81 | 330.00] | CKT 1  |
| SINGLE 55 | : | OPEN LINE FROM BUS 50801 | [4STOSK91 | 500.00] | TO BUS 50803 | [4STOSK81 | 330.00] | CKT 2  |
| SINGLE 56 | : | OPEN LINE FROM BUS 50801 | [4STOSK91 | 500.00] | TO BUS 50813 | [4METAL91 | 500.00] | CKT 0  |
| SINGLE 57 | : | OPEN LINE FROM BUS 50803 | [4STOSK81 | 330.00] | TO BUS 50806 | [4GUBKI81 | 330.00] | CKT 0  |
| SINGLE 58 | : | OPEN LINE FROM BUS 50803 | [4STOSK81 | 330.00] | TO BUS 50828 | [40EMK 81 | 330.00] | CKT 1  |
| SINGLE 59 | : | OPEN LINE FROM BUS 50803 | [4STOSK81 | 330.00] | TO BUS 50828 | [40EMK 81 | 330.00] | CKT 2  |
| SINGLE 60 | : | OPEN LINE FROM BUS 50806 | [4GUBKI81 | 330.00] | TO BUS 50807 | [4LEBED81 | 330.00] | CKT 0  |
| SINGLE 61 | : | OPEN LINE FROM BUS 50807 | [4LEBED81 | 330.00] | TO BUS 50811 | [4BELG081 | 330.00] | CKT 0  |
| SINGLE 62 | : | OPEN LINE FROM BUS 50807 | [4LEBED81 | 330.00] | TO BUS 50814 | [4METAL81 | 330.00] | CKT 0  |
| SINGLE 63 | : | OPEN LINE FROM BUS 50809 | [4VALUI81 | 330.00] | TO BUS 50814 | [4METAL81 | 330.00] | CKT 0  |
| SINGLE 64 | : | OPEN LINE FROM BUS 50811 | [4BELG081 | 330.00] | TO BUS 50823 | [4SHEBE81 | 330.00] | CKT 0  |
| SINGLE 65 | : | OPEN LINE FROM BUS 50813 | [4METAL91 | 500.00] | TO BUS 50816 | [4METAL01 | 750.00] | CKT 0  |
| SINGLE 66 | : | OPEN LINE FROM BUS 50814 | [4METAL81 | 330.00] | TO BUS 50816 | [4METAL01 | 750.00] | CKT 1  |
| SINGLE 67 | : | OPEN LINE FROM BUS 50814 | [4METAL81 | 330.00] | TO BUS 50816 | [4METAL01 | 750.00] | CKT 2  |
| SINGLE 68 | : | OPEN LINE FROM BUS 50814 | [4METAL81 | 330.00] | TO BUS 50828 | [40EMK 81 | 330.00] | CKT 1  |
| SINGLE 69 | : | OPEN LINE FROM BUS 50814 | [4METAL81 | 330.00] | TO BUS 50828 | [40EMK 81 | 330.00] | CKT 2  |
| SINGLE 70 | : | OPEN LINE FROM BUS 50860 | [4TAMBO91 | 500.00] | TO BUS 50962 | [4RGRES91 | 500.00] | CKT 0  |
| SINGLE 71 | : | OPEN LINE FROM BUS 50902 | [4BALAS91 | 500.00] | TO BUS 50913 | [4VOLGA91 | 500.00] | CKT 0  |
| SINGLE 72 | : | OPEN LINE FROM BUS 50902 | [4BALAS91 | 500.00] | TO BUS 50934 | [4FROL091 | 500.00] | CKT 0  |
| SINGLE 73 | : | OPEN LINE FROM BUS 50902 | [4BALAS91 | 500.00] | TO BUS 50940 | [40TPNV91 | 500.00] | CKT 0  |
| SINGLE 74 | : | OPEN LINE FROM BUS 50913 | [4VOLGA91 | 500.00] | TO BUS 50920 | [4VGGES91 | 500.00] | CKT 0  |
| SINGLE 75 | : | OPEN LINE FROM BUS 50913 | [4VOLGA91 | 500.00] | TO BUS 50932 | [4UZNAJ91 | 500.00] | CKT 0  |
| SINGLE 76 | : | OPEN LINE FROM BUS 50920 | [4VGGES91 | 500.00] | TO BUS 50934 | [4FROL091 | 500.00] | CKT 0  |
| SINGLE 77 | : | OPEN LINE FROM BUS 50932 | [4UZNAJ91 | 500.00] | TO BUS 50949 | [4TRUBN91 | 500.00] | CKT 0  |
| SINGLE 78 | : | OPEN LINE FROM BUS 50932 | [4UZNAJ91 | 500.00] | TO BUS 58190 | [4VDAES9  | 500.00] | CKT 0  |
| SINGLE 79 | : | OPEN LINE FROM BUS 50932 | [4UZNAJ91 | 500.00] | TO BUS 58192 | [4VDAES9J | 500.00] | CKT 0  |
| SINGLE 80 | : | OPEN LINE FROM BUS 50962 | [4RGRES91 | 500.00] | TO BUS 50963 | [4MIHAI91 | 500.00] | CKT 1  |
| SINGLE 81 | : | OPEN LINE FROM BUS 50962 | [4RGRES91 | 500.00] | TO BUS 50963 | [4MIHAI91 | 500.00] | CKT 2  |
| SINGLE 82 | : | OPEN LINE FROM BUS 58146 | [4HCHGP8  | 330.00] | TO BUS 58254 | [4TIHOR8  | 330.00] | CKT 0  |
| SINGLE 83 | : | OPEN LINE FROM BUS 58180 | [4SH-309  | 500.00] | TO BUS 58190 | [4VDAES9  | 500.00] | CKT 0  |
| SINGLE 84 | : | OPEN LINE FROM BUS 58190 | [4VDAES9  | 500.00] | TO BUS 58192 | [4VDAES9J | 500.00] | CKT 0  |
| SINGLE 85 | : | OPEN LINE FROM BUS 58190 | [4VDAES9  | 500.00] | TO BUS 58193 | [4VDAES95 | 500.00] | CKT 0  |
| SINGLE 87 | : | OPEN LINE FROM BUS 58193 | [4VDAES95 | 500.00] | TO BUS 58273 | [4TIHOR95 | 500.00] | CKT 0  |
| SINGLE 89 | : | OPEN LINE FROM BUS 58233 | [4ARMAV8  | 330.00] | TO BUS 58253 | [4KROP08  | 330.00] | CKT 0  |
| SINGLE 90 | : | OPEN LINE FROM BUS 58233 | [4ARMAV8  | 330.00] | TO BUS 58310 | [4NEVGR8  | 330.00] | CKT 0  |
| SINGLE 91 | : | OPEN LINE FROM BUS 58233 | [4ARMAV8  | 330.00] | TO BUS 58344 | [4STGRE8  | 330.00] | CKT 1  |
| SINGLE 92 | : | OPEN LINE FROM BUS 58233 | [4ARMAV8  | 330.00] | TO BUS 58344 | [4STGRE8  | 330.00] | CKT 2  |
| SINGLE 93 | : | OPEN LINE FROM BUS 58253 | [4KROP08  | 330.00] | TO BUS 58254 | [4TIHOR8  | 330.00] | CKT 0  |
| SINGLE 94 | : | OPEN LINE FROM BUS 58260 | [4CENTR9  | 500.00] | TO BUS 58361 | [4STGRE91 | 500.00] | CKT 0  |
| SINGLE 95 | : | OPEN LINE FROM BUS 58270 | [4TIHOR9  | 500.00] | TO BUS 58273 | [4TIHOR95 | 500.00] | CKT 0  |
| SINGLE 96 | : | OPEN LINE FROM BUS 58270 | [4TIHOR9  | 500.00] | TO BUS 58362 | [4STGRE92 | 500.00] | CKT 0  |
| SINGLE 97 | : | OPEN LINE FROM BUS 58303 | [4STAVR8  | 330.00] | TO BUS 58344 | [4STGRE8  | 330.00] | CKT 0  |
| SINGLE 98 | : | OPEN LINE FROM BUS 58303 | [4STAVR8  | 330.00] | TO BUS 58349 | [4GEC-48  | 330.00] | CKT 0  |
| SINGLE 99 | : | OPEN LINE FROM BUS 58303 | [4STAVR8  | 330.00] | TO BUS 58363 | [4BLAG08  | 330.00] | CKT 0  |



|            |   |                          |           |         |              |           |         |       |
|------------|---|--------------------------|-----------|---------|--------------|-----------|---------|-------|
| SINGLE 101 | : | OPEN LINE FROM BUS 58310 | [4NEVGR8  | 330.00] | TO BUS 58349 | [4GEC-48  | 330.00] | CKT 0 |
| SINGLE 104 | : | OPEN LINE FROM BUS 58325 | [4MASHU8  | 330.00] | TO BUS 58402 | [4PROHL8  | 330.00] | CKT 0 |
| SINGLE 105 | : | OPEN LINE FROM BUS 58332 | [4PRIKU8  | 330.00] | TO BUS 58363 | [4BLAG08  | 330.00] | CKT 0 |
| SINGLE 106 | : | OPEN LINE FROM BUS 58332 | [4PRIKU8  | 330.00] | TO BUS 58371 | [4BUDEN8  | 330.00] | CKT 0 |
| SINGLE 107 | : | OPEN LINE FROM BUS 58344 | [4STGRE8  | 330.00] | TO BUS 58360 | [4STGRE90 | 500.00] | CKT 3 |
| SINGLE 108 | : | OPEN LINE FROM BUS 58344 | [4STGRE8  | 330.00] | TO BUS 58360 | [4STGRE90 | 500.00] | CKT 4 |
| SINGLE 110 | : | OPEN LINE FROM BUS 58360 | [4STGRE90 | 500.00] | TO BUS 58361 | [4STGRE91 | 500.00] | CKT 0 |
| SINGLE 111 | : | OPEN LINE FROM BUS 58360 | [4STGRE90 | 500.00] | TO BUS 58362 | [4STGRE92 | 500.00] | CKT 0 |
| SINGLE 112 | : | OPEN LINE FROM BUS 58370 | [4BUDEN9  | 500.00] | TO BUS 58371 | [4BUDEN8  | 330.00] | CKT 1 |
| SINGLE 113 | : | OPEN LINE FROM BUS 58370 | [4BUDEN9  | 500.00] | TO BUS 58371 | [4BUDEN8  | 330.00] | CKT 2 |
| SINGLE 116 | : | OPEN LINE FROM BUS 58371 | [4BUDEN8  | 330.00] | TO BUS 58402 | [4PROHL8  | 330.00] | CKT 0 |
| SINGLE 118 | : | OPEN LINE FROM BUS 58402 | [4PROHL8  | 330.00] | TO BUS 58404 | [4BAKSA8  | 330.00] | CKT 0 |
| SINGLE 120 | : | OPEN LINE FROM BUS 58404 | [4BAKSA8  | 330.00] | TO BUS 58430 | [4NALJC8  | 330.00] | CKT 0 |
| SINGLE 122 | : | OPEN LINE FROM BUS 58505 | [4V-5008  | 330.00] | TO BUS 58510 | [4V-2 8   | 330.00] | CKT 0 |
| SINGLE 124 | : | OPEN LINE FROM BUS 58510 | [4V-2 8   | 330.00] | TO BUS 58714 | [4CHIRJ8  | 330.00] | CKT 0 |
| SINGLE 125 | : | OPEN LINE FROM BUS 58703 | [4CHIRG8  | 330.00] | TO BUS 58704 | [4CHGES8  | 330.00] | CKT 0 |
| SINGLE 126 | : | OPEN LINE FROM BUS 58703 | [4CHIRG8  | 330.00] | TO BUS 58714 | [4CHIRJ8  | 330.00] | CKT 0 |
| SINGLE 127 | : | OPEN LINE FROM BUS 58704 | [4CHGES8  | 330.00] | TO BUS 58714 | [4CHIRJ8  | 330.00] | CKT 0 |
| SINGLE 128 | : | OPEN LINE FROM BUS 58710 | [4MAHAC8  | 330.00] | TO BUS 58712 | [4DERBE8  | 330.00] | CKT 0 |

## 4.6.6. Turkey

### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

| <----- MONITORED BRANCH -----> |        |                |          | CONTINGENCY | RATING | FLOW   | %     |
|--------------------------------|--------|----------------|----------|-------------|--------|--------|-------|
| 60612 THOPA 3                  | 150.00 | 61103*THOPA 2  | 220.00 1 | BASE CASE   | 150.0  | 154.4  | 102.9 |
| 60665 TELBIS11                 | 400.00 | 61060*G-4ELBIS | 21.000 1 | GENMAX      | 345.0  | 481.3  | 139.5 |
| 60665 TELBIS11                 | 400.00 | 61060*G-4ELBIS | 21.000 2 | GENMAX      | 345.0  | 481.3  | 139.5 |
| 60665 TELBIS11                 | 400.00 | 61060*G-4ELBIS | 21.000 3 | GENMAX      | 345.0  | 481.3  | 139.5 |
| 60665 TELBIS11                 | 400.00 | 61060*G-4ELBIS | 21.000 4 | GENMAX      | 345.0  | 481.3  | 139.5 |
| 60063 TS.MUR3                  | 150.00 | 60081*TBAGCI3A | 150.00 1 | SINGLE 11   | 177.2  | 180.7  | 100.5 |
| 60088 TADAPA12                 | 400.00 | 60091*TGEBZE11 | 400.00 1 | SINGLE 19   | 1046.8 | 1022.9 | 102.1 |
| 60063 TS.MUR3                  | 150.00 | 60081*TBAGCI3A | 150.00 1 | SINGLE 20   | 177.2  | 180.2  | 100.1 |
| 60088 TADAPA12                 | 400.00 | 60091*TGEBZE11 | 400.00 1 | SINGLE 24   | 1046.8 | 1210.0 | 121.1 |
| 60091*TGEBZE11                 | 400.00 | 60143 TDUMYG1  | 400.00 1 | SINGLE 24   | 1057.2 | 1035.5 | 102.6 |
| 60201*TB0ZUY3                  | 150.00 | 60212 TSEYIT3  | 150.00 1 | SINGLE 30   | 177.2  | 190.7  | 105.3 |
| 60088 TADAPA12                 | 400.00 | 60091*TGEBZE11 | 400.00 1 | SINGLE 36   | 1046.8 | 1085.9 | 108.3 |
| 60097*TAKCAK3                  | 150.00 | 60575 TEREGL32 | 150.00 1 | SINGLE 40   | 128.6  | 172.7  | 129.8 |
| 60088 TADAPA12                 | 400.00 | 60091*TGEBZE11 | 400.00 1 | SINGLE 42   | 1046.8 | 1128.9 | 113.4 |
| 60232*TBORN03                  | 150.00 | 60259 TUNIVE3  | 150.00 1 | SINGLE 57   | 177.2  | 185.2  | 102.7 |
| 60612 THOPA 3                  | 150.00 | 61103*THOPA 2  | 220.00 1 | SINGLE 134  | 150.0  | 173.5  | 115.7 |
| 60612 THOPA 3                  | 150.00 | 61103*THOPA 2  | 220.00 2 | SINGLE 134  | 180.0  | 183.3  | 101.8 |
| 60634*TAGRI 3                  | 150.00 | 60647 THORAS3  | 150.00 1 | SINGLE 135  | 128.6  | 133.2  | 135.3 |
| 60642*TERZUR31                 | 150.00 | 60643 TERZUR32 | 150.00 2 | SINGLE 135  | 128.6  | 174.2  | 139.7 |
| 60747 TADILC3                  | 150.00 | 60758*TERCIS3  | 150.00 1 | SINGLE 135  | 128.6  | 118.5  | 116.2 |
| 60634 TAGRI 3                  | 150.00 | 60758*TERCIS3  | 150.00 1 | SINGLE 137  | 128.6  | 118.9  | 102.2 |
| 60784*TBATMA32                 | 150.00 | 60801 TBATMA3M | 150.00 1 | SINGLE 160  | 240.6  | 255.4  | 107.5 |

#### MONITORED VOLTAGE REPORT:

| SYSTEM | CONTINGENCY      | <----- B U S -----> |                 | V-CONT  | V-INIT  | V-MAX   | V-MIN   |
|--------|------------------|---------------------|-----------------|---------|---------|---------|---------|
| '6-400 | RANGE SINGLE 8   | 60032               | TBABAE12 400.00 | 1.05506 | 1.03270 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 82  | 60394               | THATAY1 400.00  | 0.94600 | 0.99096 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 135 | 60656               | TAKYAC11 400.00 | 0.71809 | 0.96498 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 135 | 60797               | TVAN 1 400.00   | 0.71910 | 0.95036 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 135 | 60798               | TCIZRE1 400.00  | 0.94472 | 0.98443 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 135 | 60799               | TPS3 1 400.00   | 0.94817 | 0.98931 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 137 | 60797               | TVAN 1 400.00   | 0.77371 | 0.95036 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 143 | 60722               | TURFA 1 400.00  | 0.91658 | 0.98131 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 143 | 60729               | TKIZIL1 400.00  | 0.92868 | 0.97248 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 143 | 60783               | TBATMA1 400.00  | 0.94011 | 0.97125 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 160 | 60729               | TKIZIL1 400.00  | 0.93557 | 0.97248 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 160 | 60745               | TDIYAR1 400.00  | 0.91917 | 0.97291 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 160 | 60783               | TBATMA1 400.00  | 0.92854 | 0.97125 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 168 | 60798               | TCIZRE1 400.00  | 0.92462 | 0.98443 | 1.05000 | 0.95000 |


### BLACKSEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

| <----- MONITORED BRANCH -----> |        |                 |          | CONTINGENCY | RATING | FLOW  | %     |
|--------------------------------|--------|-----------------|----------|-------------|--------|-------|-------|
| 60292 TDALAM3                  | 150.00 | 69755*G-DALMSK1 | 6.3000 1 | BASE CASE   | 12.0   | 12.9  | 107.1 |
| 60097*TAKCAK3                  | 150.00 | 60575 TEREGL32  | 150.00 1 | SINGLE 40   | 128.6  | 157.7 | 118.8 |
| 60665 TELBIS11                 | 400.00 | 69544*G-4ELBIS1 | 21.000 1 | SINGLE 65   | 345.0  | 429.3 | 124.4 |

#### MONITORED VOLTAGE REPORT:

| SYSTEM | CONTINGENCY      | <----- B U S -----> |                 | V-CONT  | V-INIT  | V-MAX   | V-MIN   |
|--------|------------------|---------------------|-----------------|---------|---------|---------|---------|
| '6-400 | RANGE SINGLE 8   | 60032               | TBABAE12 400.00 | 1.06477 | 1.02296 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 73  | 60322               | TVARSA1 400.00  | 0.94841 | 0.97415 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 125 | 60530               | TKONYA1 400.00  | 0.93919 | 0.96443 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 169 | 60798               | TCIZRE1 400.00  | 1.06116 | 1.00273 | 1.05000 | 0.95000 |
| '6-400 | RANGE SINGLE 169 | 60799               | TPS3 1 400.00   | 1.06283 | 1.01176 | 1.05000 | 0.95000 |







CONTINGENCY LEGEND:

LABEL EVENTS

|           |                                      |         |                        |         |       |
|-----------|--------------------------------------|---------|------------------------|---------|-------|
| INT-197   | : OPEN LINE FROM BUS 197 [XMI_BA11   | 400.00] | TO BUS 12471 [VMI3 11  | 400.00] | CKT 1 |
|           | : OPEN LINE FROM BUS 197 [XMI_BA11   | 400.00] | TO BUS 60032 [TBABAE12 | 400.00] | CKT 1 |
| INT-198   | : OPEN LINE FROM BUS 198 [XMI_HA11   | 400.00] | TO BUS 12471 [VMI3 11  | 400.00] | CKT 1 |
|           | : OPEN LINE FROM BUS 198 [XMI_HA11   | 400.00] | TO BUS 60002 [THAMIT1  | 400.00] | CKT 1 |
| INT-215   | : OPEN LINE FROM BUS 215 [XFI_BA11   | 400.00] | TO BUS 60000 [TBABAE11 | 400.00] | CKT 1 |
|           | : OPEN LINE FROM BUS 215 [XFI_BA11   | 400.00] | TO BUS 80258 [GKEXRU1  | 400.00] | CKT 1 |
| INT-542   | : OPEN LINE FROM BUS 542 [XGE_TR21   | 220.00] | TO BUS 20017 [6BATUM2  | 220.00] | CKT 1 |
|           | : OPEN LINE FROM BUS 542 [XGE_TR21   | 220.00] | TO BUS 61103 [THOPA 2  | 220.00] | CKT 1 |
| GENMAX    | : OPEN LINE FROM BUS 60979 [60979    | 21.000] | TO BUS 60384 [TISKEN1  | 400.00] | CKT 1 |
|           | : OPEN LINE FROM BUS 60979 [60979    | 21.000] | TO BUS 60384 [TISKEN1  | 400.00] | CKT 2 |
| SINGLE 1  | : OPEN LINE FROM BUS 215 [XFI_BA11   | 400.00] | TO BUS 60000 [TBABAE11 | 400.00] | CKT 1 |
| SINGLE 2  | : OPEN LINE FROM BUS 60000 [TBABAE11 | 400.00] | TO BUS 60001 [TUNIMR1  | 400.00] | CKT 1 |
| SINGLE 3  | : OPEN LINE FROM BUS 60000 [TBABAE11 | 400.00] | TO BUS 60002 [THAMIT1  | 400.00] | CKT 1 |
| SINGLE 4  | : OPEN LINE FROM BUS 60001 [TUNIMR1  | 400.00] | TO BUS 60031 [TKAPTA1  | 400.00] | CKT 1 |
| SINGLE 5  | : OPEN LINE FROM BUS 60001 [TUNIMR1  | 400.00] | TO BUS 60038 [TIKITE1  | 400.00] | CKT 1 |
| SINGLE 6  | : OPEN LINE FROM BUS 60001 [TUNIMR1  | 400.00] | TO BUS 60039 [THABIP1  | 400.00] | CKT 1 |
| SINGLE 7  | : OPEN LINE FROM BUS 60002 [THAMIT1  | 400.00] | TO BUS 60031 [TKAPTA1  | 400.00] | CKT 1 |
| SINGLE 8  | : OPEN LINE FROM BUS 60002 [THAMIT1  | 400.00] | TO BUS 60032 [TBABAE12 | 400.00] | CKT 1 |
| SINGLE 9  | : OPEN LINE FROM BUS 60002 [THAMIT1  | 400.00] | TO BUS 60037 [TALIBE1  | 400.00] | CKT 1 |
| SINGLE 10 | : OPEN LINE FROM BUS 60036 [TAMBAR1  | 400.00] | TO BUS 60038 [TIKITE1  | 400.00] | CKT 1 |
| SINGLE 11 | : OPEN LINE FROM BUS 60037 [TALIBE1  | 400.00] | TO BUS 60079 [TYILDI1  | 400.00] | CKT 1 |
| SINGLE 12 | : OPEN LINE FROM BUS 60037 [TALIBE1  | 400.00] | TO BUS 60082 [TATISA1  | 400.00] | CKT 1 |
| SINGLE 13 | : OPEN LINE FROM BUS 60037 [TALIBE1  | 400.00] | TO BUS 60094 [TUMRAN1  | 400.00] | CKT 1 |
| SINGLE 14 | : OPEN LINE FROM BUS 60037 [TALIBE1  | 400.00] | TO BUS 60131 [TBEYK01  | 400.00] | CKT 1 |
| SINGLE 15 | : OPEN LINE FROM BUS 60038 [TIKITE1  | 400.00] | TO BUS 60039 [THABIP1  | 400.00] | CKT 1 |
| SINGLE 16 | : OPEN LINE FROM BUS 60038 [TIKITE1  | 400.00] | TO BUS 60041 [TDAVUT1  | 400.00] | CKT 1 |
| SINGLE 17 | : OPEN LINE FROM BUS 60038 [TIKITE1  | 400.00] | TO BUS 60082 [TATISA1  | 400.00] | CKT 1 |
| SINGLE 18 | : OPEN LINE FROM BUS 60039 [THABIP1  | 400.00] | TO BUS 60085 [TZEKER1  | 400.00] | CKT 1 |
| SINGLE 19 | : OPEN LINE FROM BUS 60039 [THABIP1  | 400.00] | TO BUS 60129 [TADAPA11 | 400.00] | CKT 1 |
| SINGLE 20 | : OPEN LINE FROM BUS 60041 [TDAVUT1  | 400.00] | TO BUS 60079 [TYILDI1  | 400.00] | CKT 1 |
| SINGLE 21 | : OPEN LINE FROM BUS 60085 [TZEKER1  | 400.00] | TO BUS 60093 [TPASAK1  | 400.00] | CKT 1 |
| SINGLE 22 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60090 [TAKYAC1  | 400.00] | CKT 1 |
| SINGLE 23 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60091 [TGEBZE11 | 400.00] | CKT 1 |
| SINGLE 24 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60091 [TGEBZE11 | 400.00] | CKT 2 |
| SINGLE 25 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60092 [TOSMAN1  | 400.00] | CKT 1 |
| SINGLE 26 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60143 [TDUMYG1  | 400.00] | CKT 1 |
| SINGLE 27 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60148 [TGEBZE12 | 400.00] | CKT 1 |
| SINGLE 28 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60166 [TBURSA12 | 400.00] | CKT 1 |
| SINGLE 29 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60400 [TCAYIR1  | 400.00] | CKT 1 |
| SINGLE 30 | : OPEN LINE FROM BUS 60088 [TADAPA12 | 400.00] | TO BUS 60401 [TGOKCE1  | 400.00] | CKT 1 |
| SINGLE 31 | : OPEN LINE FROM BUS 60089 [TAKYAC13 | 400.00] | TO BUS 60090 [TAKYAC1  | 400.00] | CKT 1 |
| SINGLE 32 | : OPEN LINE FROM BUS 60089 [TAKYAC13 | 400.00] | TO BUS 60404 [TTEMEL1  | 400.00] | CKT 1 |
| SINGLE 33 | : OPEN LINE FROM BUS 60091 [TGEBZE11 | 400.00] | TO BUS 60093 [TPASAK1  | 400.00] | CKT 1 |
| SINGLE 34 | : OPEN LINE FROM BUS 60091 [TGEBZE11 | 400.00] | TO BUS 60094 [TUMRAN1  | 400.00] | CKT 1 |
| SINGLE 35 | : OPEN LINE FROM BUS 60091 [TGEBZE11 | 400.00] | TO BUS 60094 [TUMRAN1  | 400.00] | CKT 2 |
| SINGLE 36 | : OPEN LINE FROM BUS 60091 [TGEBZE11 | 400.00] | TO BUS 60143 [TDUMYG1  | 400.00] | CKT 1 |
| SINGLE 37 | : OPEN LINE FROM BUS 60092 [TOSMAN1  | 400.00] | TO BUS 60129 [TADAPA11 | 400.00] | CKT 1 |
| SINGLE 38 | : OPEN LINE FROM BUS 60092 [TOSMAN1  | 400.00] | TO BUS 60403 [TSINCA1  | 400.00] | CKT 1 |
| SINGLE 39 | : OPEN LINE FROM BUS 60092 [TOSMAN1  | 400.00] | TO BUS 60449 [TCANKI1  | 400.00] | CKT 1 |
| SINGLE 40 | : OPEN LINE FROM BUS 60092 [TOSMAN1  | 400.00] | TO BUS 60563 [TEREGL1  | 400.00] | CKT 1 |
| SINGLE 41 | : OPEN LINE FROM BUS 60093 [TPASAK1  | 400.00] | TO BUS 60131 [TBEYK01  | 400.00] | CKT 1 |
| SINGLE 42 | : OPEN LINE FROM BUS 60093 [TPASAK1  | 400.00] | TO BUS 60148 [TGEBZE12 | 400.00] | CKT 1 |
| SINGLE 43 | : OPEN LINE FROM BUS 60129 [TADAPA11 | 400.00] | TO BUS 60148 [TGEBZE12 | 400.00] | CKT 1 |
| SINGLE 44 | : OPEN LINE FROM BUS 60143 [TDUMYG1  | 400.00] | TO BUS 60166 [TBURSA12 | 400.00] | CKT 1 |
| SINGLE 45 | : OPEN LINE FROM BUS 60148 [TGEBZE12 | 400.00] | TO BUS 60404 [TTEMEL1  | 400.00] | CKT 1 |
| SINGLE 46 | : OPEN LINE FROM BUS 60149 [TBURSA11 | 400.00] | TO BUS 60166 [TBURSA12 | 400.00] | CKT 1 |
| SINGLE 47 | : OPEN LINE FROM BUS 60149 [TBURSA11 | 400.00] | TO BUS 60177 [TBALTK1  | 400.00] | CKT 1 |
| SINGLE 48 | : OPEN LINE FROM BUS 60149 [TBURSA11 | 400.00] | TO BUS 60196 [TTUNCB1  | 400.00] | CKT 1 |
| SINGLE 49 | : OPEN LINE FROM BUS 60166 [TBURSA12 | 400.00] | TO BUS 60194 [TKARAB1  | 400.00] | CKT 1 |
| SINGLE 50 | : OPEN LINE FROM BUS 60177 [TBALTK1  | 400.00] | TO BUS 60266 [TSOMA 1  | 400.00] | CKT 1 |
| SINGLE 51 | : OPEN LINE FROM BUS 60194 [TKARAB1  | 400.00] | TO BUS 60266 [TSOMA 1  | 400.00] | CKT 1 |
| SINGLE 52 | : OPEN LINE FROM BUS 60195 [TSEYIT1  | 400.00] | TO BUS 60196 [TTUNCB1  | 400.00] | CKT 1 |
| SINGLE 53 | : OPEN LINE FROM BUS 60195 [TSEYIT1  | 400.00] | TO BUS 60224 [TISIKL1  | 400.00] | CKT 1 |
| SINGLE 54 | : OPEN LINE FROM BUS 60195 [TSEYIT1  | 400.00] | TO BUS 60401 [TGOKCE1  | 400.00] | CKT 1 |
| SINGLE 55 | : OPEN LINE FROM BUS 60195 [TSEYIT1  | 400.00] | TO BUS 60558 [TAFYON1  | 400.00] | CKT 1 |
| SINGLE 56 | : OPEN LINE FROM BUS 60223 [TALIAG1  | 400.00] | TO BUS 60224 [TISIKL1  | 400.00] | CKT 1 |
| SINGLE 57 | : OPEN LINE FROM BUS 60223 [TALIAG1  | 400.00] | TO BUS 60225 [TUZUND1  | 400.00] | CKT 1 |
| SINGLE 58 | : OPEN LINE FROM BUS 60223 [TALIAG1  | 400.00] | TO BUS 60260 [TALIAD1  | 400.00] | CKT 1 |
| SINGLE 59 | : OPEN LINE FROM BUS 60223 [TALIAG1  | 400.00] | TO BUS 60260 [TALIAD1  | 400.00] | CKT 2 |
| SINGLE 60 | : OPEN LINE FROM BUS 60223 [TALIAG1  | 400.00] | TO BUS 60266 [TSOMA 1  | 400.00] | CKT 1 |
| SINGLE 61 | : OPEN LINE FROM BUS 60223 [TALIAG1  | 400.00] | TO BUS 60281 [TMANIS1  | 400.00] | CKT 1 |
| SINGLE 62 | : OPEN LINE FROM BUS 60224 [TISIKL1  | 400.00] | TO BUS 60281 [TMANIS1  | 400.00] | CKT 1 |
| SINGLE 63 | : OPEN LINE FROM BUS 60224 [TISIKL1  | 400.00] | TO BUS 60283 [TYATAG1  | 400.00] | CKT 1 |
| SINGLE 64 | : OPEN LINE FROM BUS 60224 [TISIKL1  | 400.00] | TO BUS 60283 [TYATAG1  | 400.00] | CKT 2 |
| SINGLE 65 | : OPEN LINE FROM BUS 60225 [TUZUND1  | 400.00] | TO BUS 60261 [TRES 1   | 400.00] | CKT 1 |
| SINGLE 66 | : OPEN LINE FROM BUS 60225 [TUZUND1  | 400.00] | TO BUS 60318 [TGERME1  | 400.00] | CKT 1 |
| SINGLE 67 | : OPEN LINE FROM BUS 60282 [TKEMER1  | 400.00] | TO BUS 60283 [TYATAG1  | 400.00] | CKT 1 |
| SINGLE 68 | : OPEN LINE FROM BUS 60282 [TKEMER1  | 400.00] | TO BUS 60284 [TYENIK1  | 400.00] | CKT 1 |
| SINGLE 69 | : OPEN LINE FROM BUS 60283 [TYATAG1  | 400.00] | TO BUS 60284 [TYENIK1  | 400.00] | CKT 1 |
| SINGLE 70 | : OPEN LINE FROM BUS 60283 [TYATAG1  | 400.00] | TO BUS 60313 [TDENIZ1  | 400.00] | CKT 1 |
| SINGLE 71 | : OPEN LINE FROM BUS 60284 [TYENIK1  | 400.00] | TO BUS 60318 [TGERME1  | 400.00] | CKT 1 |
| SINGLE 72 | : OPEN LINE FROM BUS 60313 [TDENIZ1  | 400.00] | TO BUS 60322 [TVARSA1  | 400.00] | CKT 1 |
| SINGLE 73 | : OPEN LINE FROM BUS 60321 [TOYMAP1  | 400.00] | TO BUS 60322 [TVARSA1  | 400.00] | CKT 1 |
| SINGLE 74 | : OPEN LINE FROM BUS 60321 [TOYMAP1  | 400.00] | TO BUS 60322 [TVARSA1  | 400.00] | CKT 2 |



|            |   |                          |           |         |              |           |         |       |
|------------|---|--------------------------|-----------|---------|--------------|-----------|---------|-------|
| SINGLE 75  | : | OPEN LINE FROM BUS 60321 | [TOYMAP1  | 400.00] | TO BUS 60515 | [TSEYDI1  | 400.00] | CKT 1 |
| SINGLE 76  | : | OPEN LINE FROM BUS 60339 | [TERMEN1  | 400.00] | TO BUS 60395 | [TMERSI1  | 400.00] | CKT 1 |
| SINGLE 77  | : | OPEN LINE FROM BUS 60339 | [TERMEN1  | 400.00] | TO BUS 60515 | [TSEYDI1  | 400.00] | CKT 1 |
| SINGLE 78  | : | OPEN LINE FROM BUS 60342 | [TADANA1  | 400.00] | TO BUS 60343 | [TERZIN1  | 400.00] | CKT 1 |
| SINGLE 79  | : | OPEN LINE FROM BUS 60342 | [TADANA1  | 400.00] | TO BUS 60384 | [TISKEN1  | 400.00] | CKT 1 |
| SINGLE 80  | : | OPEN LINE FROM BUS 60342 | [TADANA1  | 400.00] | TO BUS 60514 | [TCASEY1  | 400.00] | CKT 1 |
| SINGLE 81  | : | OPEN LINE FROM BUS 60343 | [TERZIN1  | 400.00] | TO BUS 60384 | [TISKEN1  | 400.00] | CKT 1 |
| SINGLE 82  | : | OPEN LINE FROM BUS 60343 | [TERZIN1  | 400.00] | TO BUS 60394 | [THATAY1  | 400.00] | CKT 1 |
| SINGLE 83  | : | OPEN LINE FROM BUS 60343 | [TERZIN1  | 400.00] | TO BUS 60663 | [TANDIR1  | 400.00] | CKT 1 |
| SINGLE 84  | : | OPEN LINE FROM BUS 60343 | [TERZIN1  | 400.00] | TO BUS 60671 | [TG.ANT1  | 400.00] | CKT 1 |
| SINGLE 85  | : | OPEN LINE FROM BUS 60384 | [TISKEN1  | 400.00] | TO BUS 60395 | [TMERSI1  | 400.00] | CKT 1 |
| SINGLE 86  | : | OPEN LINE FROM BUS 60400 | [TCAYIR1  | 400.00] | TO BUS 60403 | [TSINCA1  | 400.00] | CKT 1 |
| SINGLE 87  | : | OPEN LINE FROM BUS 60401 | [TGOKCE1  | 400.00] | TO BUS 60402 | [TGOLBA1  | 400.00] | CKT 1 |
| SINGLE 88  | : | OPEN LINE FROM BUS 60402 | [TGOLBA1  | 400.00] | TO BUS 60403 | [TSINCA1  | 400.00] | CKT 1 |
| SINGLE 89  | : | OPEN LINE FROM BUS 60402 | [TGOLBA1  | 400.00] | TO BUS 60484 | [TCAKAY11 | 400.00] | CKT 1 |
| SINGLE 90  | : | OPEN LINE FROM BUS 60402 | [TGOLBA1  | 400.00] | TO BUS 60485 | [TCAKAY12 | 400.00] | CKT 1 |
| SINGLE 91  | : | OPEN LINE FROM BUS 60403 | [TSINCA1  | 400.00] | TO BUS 60404 | [TTEMEL1  | 400.00] | CKT 1 |
| SINGLE 92  | : | OPEN LINE FROM BUS 60403 | [TSINCA1  | 400.00] | TO BUS 60415 | [TBAGLU1  | 400.00] | CKT 1 |
| SINGLE 93  | : | OPEN LINE FROM BUS 60403 | [TSINCA1  | 400.00] | TO BUS 60481 | [TCAAVA12 | 400.00] | CKT 1 |
| SINGLE 94  | : | OPEN LINE FROM BUS 60403 | [TSINCA1  | 400.00] | TO BUS 60482 | [TCAAVA13 | 400.00] | CKT 1 |
| SINGLE 95  | : | OPEN LINE FROM BUS 60404 | [TTEMEL1  | 400.00] | TO BUS 60475 | [TAGACC12 | 400.00] | CKT 1 |
| SINGLE 96  | : | OPEN LINE FROM BUS 60404 | [TTEMEL1  | 400.00] | TO BUS 60477 | [TAGACC14 | 400.00] | CKT 1 |
| SINGLE 97  | : | OPEN LINE FROM BUS 60415 | [TBAGLU1  | 400.00] | TO BUS 60447 | [TCAAYA12 | 400.00] | CKT 1 |
| SINGLE 98  | : | OPEN LINE FROM BUS 60446 | [TCAAYA11 | 400.00] | TO BUS 60449 | [TCANKI1  | 400.00] | CKT 1 |
| SINGLE 99  | : | OPEN LINE FROM BUS 60446 | [TCAAYA11 | 400.00] | TO BUS 60450 | [TKAYAB1  | 400.00] | CKT 1 |
| SINGLE 100 | : | OPEN LINE FROM BUS 60447 | [TCAAYA12 | 400.00] | TO BUS 60450 | [TKAYAB1  | 400.00] | CKT 1 |
| SINGLE 101 | : | OPEN LINE FROM BUS 60448 | [TCAAYA13 | 400.00] | TO BUS 60450 | [TKAYAB1  | 400.00] | CKT 1 |
| SINGLE 102 | : | OPEN LINE FROM BUS 60448 | [TCAAYA13 | 400.00] | TO BUS 60675 | [TSIVAS1  | 400.00] | CKT 1 |
| SINGLE 103 | : | OPEN LINE FROM BUS 60450 | [TKAYAB1  | 400.00] | TO BUS 60561 | [TALTIN1  | 400.00] | CKT 1 |
| SINGLE 104 | : | OPEN LINE FROM BUS 60450 | [TKAYAB1  | 400.00] | TO BUS 60562 | [TCARSA1  | 400.00] | CKT 1 |
| SINGLE 105 | : | OPEN LINE FROM BUS 60474 | [TAGACC11 | 400.00] | TO BUS 60475 | [TAGACC12 | 400.00] | CKT 1 |
| SINGLE 106 | : | OPEN LINE FROM BUS 60474 | [TAGACC11 | 400.00] | TO BUS 60487 | [TYESIL1  | 400.00] | CKT 1 |
| SINGLE 107 | : | OPEN LINE FROM BUS 60476 | [TAGACC13 | 400.00] | TO BUS 60477 | [TAGACC14 | 400.00] | CKT 1 |
| SINGLE 108 | : | OPEN LINE FROM BUS 60476 | [TAGACC13 | 400.00] | TO BUS 60487 | [TYESIL1  | 400.00] | CKT 1 |
| SINGLE 109 | : | OPEN LINE FROM BUS 60478 | [TAVANO11 | 400.00] | TO BUS 60480 | [TCAAVA11 | 400.00] | CKT 1 |
| SINGLE 110 | : | OPEN LINE FROM BUS 60478 | [TAVANO11 | 400.00] | TO BUS 60481 | [TCAAVA12 | 400.00] | CKT 1 |
| SINGLE 111 | : | OPEN LINE FROM BUS 60479 | [TAVANO12 | 400.00] | TO BUS 60482 | [TCAAVA13 | 400.00] | CKT 1 |
| SINGLE 112 | : | OPEN LINE FROM BUS 60479 | [TAVANO12 | 400.00] | TO BUS 60483 | [TCAAVA14 | 400.00] | CKT 1 |
| SINGLE 113 | : | OPEN LINE FROM BUS 60480 | [TCAAVA11 | 400.00] | TO BUS 60665 | [TELBIS11 | 400.00] | CKT 1 |
| SINGLE 114 | : | OPEN LINE FROM BUS 60483 | [TCAAVA14 | 400.00] | TO BUS 60666 | [TELBIS12 | 400.00] | CKT 1 |
| SINGLE 115 | : | OPEN LINE FROM BUS 60484 | [TCAKAY11 | 400.00] | TO BUS 60486 | [TKAYSE1  | 400.00] | CKT 1 |
| SINGLE 116 | : | OPEN LINE FROM BUS 60485 | [TCAKAY12 | 400.00] | TO BUS 60486 | [TKAYSE1  | 400.00] | CKT 1 |
| SINGLE 117 | : | OPEN LINE FROM BUS 60486 | [TKAYSE1  | 400.00] | TO BUS 60665 | [TELBIS11 | 400.00] | CKT 1 |
| SINGLE 118 | : | OPEN LINE FROM BUS 60486 | [TKAYSE1  | 400.00] | TO BUS 60674 | [TKEBAN1  | 400.00] | CKT 1 |
| SINGLE 119 | : | OPEN LINE FROM BUS 60486 | [TKAYSE1  | 400.00] | TO BUS 60674 | [TKEBAN1  | 400.00] | CKT 2 |
| SINGLE 120 | : | OPEN LINE FROM BUS 60487 | [TYESIL1  | 400.00] | TO BUS 60513 | [TTUFAN1  | 400.00] | CKT 1 |
| SINGLE 121 | : | OPEN LINE FROM BUS 60487 | [TYESIL1  | 400.00] | TO BUS 60530 | [TKONYA1  | 400.00] | CKT 1 |
| SINGLE 122 | : | OPEN LINE FROM BUS 60487 | [TYESIL1  | 400.00] | TO BUS 60668 | [TGOKCA12 | 400.00] | CKT 1 |
| SINGLE 123 | : | OPEN LINE FROM BUS 60487 | [TYESIL1  | 400.00] | TO BUS 60670 | [TGOKCA14 | 400.00] | CKT 1 |
| SINGLE 124 | : | OPEN LINE FROM BUS 60513 | [TTUFAN1  | 400.00] | TO BUS 60666 | [TELBIS12 | 400.00] | CKT 1 |
| SINGLE 125 | : | OPEN LINE FROM BUS 60514 | [TCASEY1  | 400.00] | TO BUS 60515 | [TSEYDI1  | 400.00] | CKT 1 |
| SINGLE 126 | : | OPEN LINE FROM BUS 60515 | [TSEYDI1  | 400.00] | TO BUS 60530 | [TKONYA1  | 400.00] | CKT 1 |
| SINGLE 127 | : | OPEN LINE FROM BUS 60515 | [TSEYDI1  | 400.00] | TO BUS 60558 | [TAFYON1  | 400.00] | CKT 1 |
| SINGLE 128 | : | OPEN LINE FROM BUS 60561 | [TALTIN1  | 400.00] | TO BUS 60562 | [TCARSA1  | 400.00] | CKT 1 |
| SINGLE 129 | : | OPEN LINE FROM BUS 60562 | [TCARSA1  | 400.00] | TO BUS 60564 | [TH.UGU1  | 400.00] | CKT 1 |
| SINGLE 130 | : | OPEN LINE FROM BUS 60562 | [TCARSA1  | 400.00] | TO BUS 60564 | [TH.UGU1  | 400.00] | CKT 2 |
| SINGLE 131 | : | OPEN LINE FROM BUS 60562 | [TCARSA1  | 400.00] | TO BUS 60603 | [TTIREB1  | 400.00] | CKT 1 |
| SINGLE 132 | : | OPEN LINE FROM BUS 60603 | [TTIREB1  | 400.00] | TO BUS 60624 | [TBORCK1  | 400.00] | CKT 1 |
| SINGLE 133 | : | OPEN LINE FROM BUS 60624 | [TBORCK1  | 400.00] | TO BUS 60625 | [TDERIN1  | 400.00] | CKT 1 |
| SINGLE 134 | : | OPEN LINE FROM BUS 60625 | [TDERIN1  | 400.00] | TO BUS 60633 | [TERZUR1  | 400.00] | CKT 1 |
| SINGLE 135 | : | OPEN LINE FROM BUS 60633 | [TERZUR1  | 400.00] | TO BUS 60656 | [TAKYAC11 | 400.00] | CKT 1 |
| SINGLE 136 | : | OPEN LINE FROM BUS 60633 | [TERZUR1  | 400.00] | TO BUS 60746 | [TOZLUC1  | 400.00] | CKT 1 |
| SINGLE 137 | : | OPEN LINE FROM BUS 60656 | [TAKYAC11 | 400.00] | TO BUS 60797 | [TVAN 1   | 400.00] | CKT 1 |
| SINGLE 138 | : | OPEN LINE FROM BUS 60663 | [TANDIR1  | 400.00] | TO BUS 60666 | [TELBIS12 | 400.00] | CKT 1 |
| SINGLE 139 | : | OPEN LINE FROM BUS 60664 | [TATATU1  | 400.00] | TO BUS 60666 | [TELBIS12 | 400.00] | CKT 1 |
| SINGLE 140 | : | OPEN LINE FROM BUS 60664 | [TATATU1  | 400.00] | TO BUS 60667 | [TGOKCA11 | 400.00] | CKT 1 |
| SINGLE 141 | : | OPEN LINE FROM BUS 60664 | [TATATU1  | 400.00] | TO BUS 60669 | [TGOKCA13 | 400.00] | CKT 1 |
| SINGLE 142 | : | OPEN LINE FROM BUS 60664 | [TATATU1  | 400.00] | TO BUS 60671 | [TG.ANT1  | 400.00] | CKT 1 |
| SINGLE 143 | : | OPEN LINE FROM BUS 60664 | [TATATU1  | 400.00] | TO BUS 60722 | [TURFA 1  | 400.00] | CKT 1 |
| SINGLE 144 | : | OPEN LINE FROM BUS 60664 | [TATATU1  | 400.00] | TO BUS 60728 | [TBIREC1  | 400.00] | CKT 1 |
| SINGLE 145 | : | OPEN LINE FROM BUS 60664 | [TATATU1  | 400.00] | TO BUS 60737 | [THILVA1  | 400.00] | CKT 1 |
| SINGLE 146 | : | OPEN LINE FROM BUS 60665 | [TELBIS11 | 400.00] | TO BUS 60666 | [TELBIS12 | 400.00] | CKT 1 |
| SINGLE 147 | : | OPEN LINE FROM BUS 60665 | [TELBIS11 | 400.00] | TO BUS 60674 | [TKEBAN1  | 400.00] | CKT 1 |
| SINGLE 148 | : | OPEN LINE FROM BUS 60666 | [TELBIS12 | 400.00] | TO BUS 60733 | [TELBIS21 | 400.00] | CKT 1 |
| SINGLE 149 | : | OPEN LINE FROM BUS 60666 | [TELBIS12 | 400.00] | TO BUS 60733 | [TELBIS21 | 400.00] | CKT 2 |
| SINGLE 150 | : | OPEN LINE FROM BUS 60666 | [TELBIS12 | 400.00] | TO BUS 60733 | [TELBIS21 | 400.00] | CKT 3 |
| SINGLE 151 | : | OPEN LINE FROM BUS 60666 | [TELBIS12 | 400.00] | TO BUS 60733 | [TELBIS21 | 400.00] | CKT 4 |
| SINGLE 152 | : | OPEN LINE FROM BUS 60667 | [TGOKCA11 | 400.00] | TO BUS 60668 | [TGOKCA12 | 400.00] | CKT 1 |
| SINGLE 153 | : | OPEN LINE FROM BUS 60669 | [TGOKCA13 | 400.00] | TO BUS 60670 | [TGOKCA14 | 400.00] | CKT 1 |
| SINGLE 154 | : | OPEN LINE FROM BUS 60671 | [TG.ANT1  | 400.00] | TO BUS 60728 | [TBIREC1  | 400.00] | CKT 1 |
| SINGLE 155 | : | OPEN LINE FROM BUS 60672 | [TKANGA1  | 400.00] | TO BUS 60674 | [TKEBAN1  | 400.00] | CKT 1 |
| SINGLE 156 | : | OPEN LINE FROM BUS 60672 | [TKANGA1  | 400.00] | TO BUS 60675 | [TSIVAS1  | 400.00] | CKT 1 |
| SINGLE 157 | : | OPEN LINE FROM BUS 60673 | [TKARAK1  | 400.00] | TO BUS 60674 | [TKEBAN1  | 400.00] | CKT 1 |
| SINGLE 158 | : | OPEN LINE FROM BUS 60673 | [TKARAK1  | 400.00] | TO BUS 60674 | [TKEBAN1  | 400.00] | CKT 2 |
| SINGLE 159 | : | OPEN LINE FROM BUS 60673 | [TKARAK1  | 400.00] | TO BUS 60737 | [THILVA1  | 400.00] | CKT 1 |
| SINGLE 160 | : | OPEN LINE FROM BUS 60673 | [TKARAK1  | 400.00] | TO BUS 60745 | [TDIYAR1  | 400.00] | CKT 1 |
| SINGLE 161 | : | OPEN LINE FROM BUS 60674 | [TKEBAN1  | 400.00] | TO BUS 60732 | [TKEBAN1H | 400.00] | CKT 1 |



|            |   |                          |          |         |              |           |         |       |
|------------|---|--------------------------|----------|---------|--------------|-----------|---------|-------|
| SINGLE 162 | : | OPEN LINE FROM BUS 60674 | [TKEBAN1 | 400.00] | TO BUS 60732 | [TKEBAN1H | 400.00] | CKT 2 |
| SINGLE 163 | : | OPEN LINE FROM BUS 60674 | [TKEBAN1 | 400.00] | TO BUS 60732 | [TKEBAN1H | 400.00] | CKT 3 |
| SINGLE 164 | : | OPEN LINE FROM BUS 60674 | [TKEBAN1 | 400.00] | TO BUS 60746 | [TOZLUC1  | 400.00] | CKT 1 |
| SINGLE 165 | : | OPEN LINE FROM BUS 60722 | [TURFA 1 | 400.00] | TO BUS 60729 | [TKIZIL1  | 400.00] | CKT 1 |
| SINGLE 166 | : | OPEN LINE FROM BUS 60729 | [TKIZIL1 | 400.00] | TO BUS 60783 | [TBATMA1  | 400.00] | CKT 1 |
| SINGLE 167 | : | OPEN LINE FROM BUS 60745 | [TDIYAR1 | 400.00] | TO BUS 60783 | [TBATMA1  | 400.00] | CKT 1 |
| SINGLE 168 | : | OPEN LINE FROM BUS 60798 | [TCIZRE1 | 400.00] | TO BUS 60799 | [TPS3 1   | 400.00] | CKT 1 |

#### 4.6.7. Ukraine

##### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0  
PERCENT OF RATING SET A  
ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: D:\miksa\0\BlackSea\0report\UA\ua.acc  
DISTRIBUTION FACTOR FILE: D:\miksa\0\BlackSea\0report\UA\UA.dfx  
SUBSYSTEM DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\UA\UA.sub  
MONITORED ELEMENT FILE: D:\miksa\0\BlackSea\0report\UA\UA.mon  
CONTINGENCY DESCRIPTION FILE: D:\miksa\0\BlackSea\0report\UA\ukraine.con


| <----- MONITORED BRANCH -----> |        |                |          | CONTINGENCY | RATING | FLOW   | %     |
|--------------------------------|--------|----------------|----------|-------------|--------|--------|-------|
| 70520*UJUAZS81                 | 330.00 | 70521 UJUAZS31 | 150.00 0 | BASE CASE   | 250.0  | 283.0  | 113.2 |
| 70380*UZAPAR01                 | 750.00 | 70381 UZAP7S81 | 330.00 2 | 45-S        | 1000.0 | 1216.1 | 121.6 |
| 70308 UDNEPR81                 | 330.00 | 70356*UDNEPR01 | 750.00 2 | 46-S        | 1000.0 | 1112.6 | 111.3 |
| 70520*UJUAZS81                 | 330.00 | 70521 UJUAZS31 | 150.00 0 | 57-S        | 250.0  | 320.2  | 128.1 |
| 70520*UJUAZS81                 | 330.00 | 70521 UJUAZS31 | 150.00 0 | 58-S        | 250.0  | 351.8  | 140.7 |

##### MONITORED VOLTAGE REPORT:

| SYSTEM    | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |
|-----------|-----------------|---------------------|--------|---------|---------|---------|
| OWNER 703 | RANGE BASE CASE | 70256 UKRJUK31      | 150.00 | 1.07623 | 1.07623 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70269 ULOZ1531      | 150.00 | 0.93842 | 0.93842 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70311 UDGEC131      | 150.00 | 1.05940 | 1.05940 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70320 UDDZ_132      | 150.00 | 1.05132 | 1.05132 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70324 UDD_TE31      | 150.00 | 1.05646 | 1.05646 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70329 UKRGE31       | 150.00 | 1.08000 | 1.08000 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70345 UPOBUZ31      | 150.00 | 1.05474 | 1.05474 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70347 UPROME31      | 150.00 | 1.06000 | 1.06000 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70355 UMELIT31      | 150.00 | 1.05490 | 1.05490 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70521 UJUAZS31      | 150.00 | 1.05538 | 1.05538 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70524 UCENTR31      | 150.00 | 0.94800 | 0.94800 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70533 UNTR0I31      | 150.00 | 0.94948 | 0.94948 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70535 USNIGI31      | 150.00 | 0.94441 | 0.94441 | 1.05000 |
| OWNER 700 | RANGE 8-S       | 70242 USEVUK01      | 750.00 | 0.89461 | 0.99421 | 1.05000 |
| OWNER 700 | RANGE 33-S      | 70703 UCAEC_01      | 750.00 | 0.85305 | 0.97259 | 1.05000 |
| OWNER 700 | RANGE 34-S      | 70599 UJUAZS01      | 750.00 | 0.91018 | 0.95903 | 1.05000 |
| OWNER 700 | RANGE 37-S      | 70006 UJDONB01      | 750.00 | 0.91670 | 0.95680 | 1.05000 |
| OWNER 703 | RANGE 44-S      | 70315 UNIKOP32      | 150.00 | 1.07409 | 1.04075 | 1.05000 |
| OWNER 703 | RANGE 44-S      | 70337 UFERR031      | 150.00 | 1.05222 | 1.01516 | 1.05000 |
| OWNER 703 | RANGE 44-S      | 70387 UNIKOP31      | 150.00 | 1.07409 | 1.04075 | 1.05000 |
| OWNER 708 | RANGE 56-S      | 70530 UKOTOV81      | 330.00 | 0.87228 | 0.98442 | 1.10000 |
| OWNER 703 | RANGE 57-S      | 70503 UTRIHA31      | 150.00 | 0.94959 | 0.97986 | 1.05000 |
| OWNER 703 | RANGE 57-S      | 70516 UHNPZ_31      | 150.00 | 0.93607 | 0.95684 | 1.05000 |
| OWNER 703 | RANGE 57-S      | 70524 UCENTR31      | 150.00 | 0.92046 | 0.94800 | 1.05000 |
| OWNER 703 | RANGE 57-S      | 70535 USNIGI31      | 150.00 | 0.91633 | 0.94441 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70392 UBERDN31      | 150.00 | 0.93019 | 0.97327 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70503 UTRIHA31      | 150.00 | 0.90447 | 0.97986 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70516 UHNPZ_31      | 150.00 | 0.89436 | 0.95684 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70524 UCENTR31      | 150.00 | 0.87269 | 0.94800 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70526 UNIKOL31      | 150.00 | 0.90637 | 0.98028 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70533 UNTR0I31      | 150.00 | 0.90270 | 0.94948 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70535 USNIGI31      | 150.00 | 0.86700 | 0.94441 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70536 UNIKOS31      | 150.00 | 0.91001 | 0.96554 | 1.05000 |
| OWNER 703 | RANGE 58-S      | 70550 UHERS031      | 150.00 | 0.92129 | 0.98131 | 1.05000 |
| OWNER 708 | RANGE 58-S      | 70419 USIMFE81      | 330.00 | 0.84925 | 0.91509 | 1.10000 |
| OWNER 708 | RANGE 58-S      | 70423 UKBURU81      | 330.00 | 0.86346 | 0.93184 | 1.10000 |
| OWNER 708 | RANGE 58-S      | 70525 UNIKOL81      | 330.00 | 0.87795 | 0.94363 | 1.10000 |
| OWNER 703 | RANGE 62-S      | 70269 ULOZ1531      | 150.00 | 0.91139 | 0.93842 | 1.05000 |
| OWNER 703 | RANGE 62-S      | 70348 UPRIZ031      | 150.00 | 0.92969 | 0.96403 | 1.05000 |
| OWNER 703 | RANGE 62-S      | 70369 UPVAVL031     | 150.00 | 0.93826 | 0.97488 | 1.05000 |

##### BLACKSEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

| <----- MONITORED BRANCH -----> |        |                |          | CONTINGENCY | RATING | FLOW   | %     |
|--------------------------------|--------|----------------|----------|-------------|--------|--------|-------|
| 70313*UZAEC_01                 | 750.00 | 70338 UZAEC_81 | 330.00 0 | 37-S        | 1000.0 | 1035.7 | 103.6 |



|                |        |                |        |   |      |        |        |       |
|----------------|--------|----------------|--------|---|------|--------|--------|-------|
| 70380*UZAPAR01 | 750.00 | 70381 UZAP7S81 | 330.00 | 2 | 45-S | 1000.0 | 1164.0 | 116.4 |
| 70308 UDNEPR81 | 330.00 | 70356*UDNEPR01 | 750.00 | 2 | 46-S | 1000.0 | 1070.5 | 107.0 |


#### MONITORED VOLTAGE REPORT:

| SYSTEM    | CONTINGENCY     | <----- B U S -----> | V-CONT | V-INIT  | V-MAX   | V-MIN   |
|-----------|-----------------|---------------------|--------|---------|---------|---------|
| OWNER 703 | RANGE BASE CASE | 70236 UKRMTCT31     | 150.00 | 1.05232 | 1.05232 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70345 UPOBUZ31      | 150.00 | 1.05879 | 1.05879 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70355 UMLIT31       | 150.00 | 1.06787 | 1.06787 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70521 UJUAZS31      | 150.00 | 1.06198 | 1.06198 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70532 UPERV131      | 150.00 | 1.05150 | 1.05150 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70740 UUMANJ31      | 150.00 | 1.06329 | 1.06329 | 1.05000 |
| OWNER 703 | RANGE BASE CASE | 70763 UTALJN31      | 150.00 | 1.06284 | 1.06284 | 1.05000 |
| OWNER 702 | RANGE BASE CASE | 70502 UTRIHA21      | 220.00 | 1.11645 | 1.11645 | 1.10000 |
| OWNER 702 | RANGE 9-S       | 70016 UVELIK21      | 220.00 | 1.13006 | 1.07420 | 1.10000 |
| OWNER 700 | RANGE 33-S      | 70703 UCAEC_01      | 750.00 | 0.91396 | 0.99868 | 1.05000 |
| OWNER 700 | RANGE 38-S      | 70380 UZAPAR01      | 750.00 | 0.91552 | 0.93893 | 1.05000 |

#### CONTINGENCY LEGEND:

| LABEL | EVENTS                                                                                |
|-------|---------------------------------------------------------------------------------------|
| 1-S   | : OPEN BRANCH FROM BUS 78 [XSA_MU11 400.00] TO BUS 70919 [UMUKAC11 400.00] CKT 1      |
| 2-S   | : OPEN BRANCH FROM BUS 84 [XRO_MU11 400.00] TO BUS 70919 [UMUKAC11 400.00] CKT 1      |
| 3-S   | : OPEN BRANCH FROM BUS 154 [XKI_MU21 220.00] TO BUS 70917 [UMUKAC21 220.00] CKT 1     |
| 4-S   | : OPEN BRANCH FROM BUS 155 [XTI_MU21 220.00] TO BUS 70917 [UMUKAC21 220.00] CKT 1     |
| 5-S   | : OPEN BRANCH FROM BUS 196 [XAL_ZA01 750.00] TO BUS 70995 [UZUKR702 750.00] CKT 1     |
| 6-S   | : OPEN BRANCH FROM BUS 501 [XPL_UA01 750.00] TO BUS 70808 [UHAEC_01 750.00] CKT 1     |
| 7-S   | : OPEN BRANCH FROM BUS 504 [XVK_MU11 400.00] TO BUS 70919 [UMUKAC11 400.00] CKT 1     |
| 8-S   | : OPEN BRANCH FROM BUS 506 [XRU_UA01 750.00] TO BUS 70242 [USEVUK01 750.00] CKT 1     |
| 9-S   | : OPEN BRANCH FROM BUS 508 [XRU_UA22 220.00] TO BUS 70102 [ULUTEC22 220.00] CKT 1     |
| 10-S  | : OPEN BRANCH FROM BUS 510 [XRU_UA24 220.00] TO BUS 70127 [UAMVR021 220.00] CKT 1     |
| 11-S  | : OPEN BRANCH FROM BUS 511 [XRU_UA91 500.00] TO BUS 70178 [UPOBED91 500.00] CKT 1     |
| 12-S  | : OPEN BRANCH FROM BUS 512 [XRU_UA92 500.00] TO BUS 70185 [UDONBA91 500.00] CKT 1     |
| 13-S  | : OPEN BRANCH FROM BUS 513 [XRU_UA81 330.00] TO BUS 70125 [UJOZNA81 330.00] CKT 1     |
| 14-S  | : OPEN BRANCH FROM BUS 514 [XRU_UA82 330.00] TO BUS 70201 [UZMTZS81 330.00] CKT 1     |
| 15-S  | : OPEN BRANCH FROM BUS 515 [XRU_UA83 330.00] TO BUS 70211 [ULOSEV81 330.00] CKT 1     |
| 16-S  | : OPEN BRANCH FROM BUS 516 [XRU_UA84 330.00] TO BUS 70245 [USOSTK81 330.00] CKT 1     |
| 17-S  | : OPEN BRANCH FROM BUS 517 [XRU_UA85 330.00] TO BUS 70247 [USUMIS81 330.00] CKT 1     |
| 18-S  | : OPEN BRANCH FROM BUS 518 [XRU_UA86 330.00] TO BUS 70299 [UOTPL081 330.00] CKT 1     |
| 19-S  | : OPEN BRANCH FROM BUS 519 [XMD_UA81 330.00] TO BUS 70805 [UDSGEC81 330.00] CKT 1     |
| 20-S  | : OPEN BRANCH FROM BUS 520 [XMD_UA82 330.00] TO BUS 70508 [UUSAT081 330.00] CKT 1     |
| 21-S  | : OPEN BRANCH FROM BUS 521 [XMD_UA83 330.00] TO BUS 70512 [UNODES81 330.00] CKT 1     |
| 22-S  | : OPEN BRANCH FROM BUS 522 [XMD_UA84 330.00] TO BUS 70530 [UKOTOV81 330.00] CKT 1     |
| 23-S  | : OPEN BRANCH FROM BUS 523 [XMD_UA85 330.00] TO BUS 70530 [UKOTOV81 330.00] CKT 2     |
| 24-S  | : OPEN BRANCH FROM BUS 524 [XMD_UA86 330.00] TO BUS 70530 [UKOTOV81 330.00] CKT 1     |
| 25-S  | : OPEN BRANCH FROM BUS 525 [XMD_UA87 330.00] TO BUS 70545 [UARCIZ81 330.00] CKT 1     |
| 26-S  | : OPEN BRANCH FROM BUS 539 [XUA_BY81 330.00] TO BUS 70727 [UCAEC_81 330.00] CKT 1     |
| 27-S  | : OPEN BRANCH FROM BUS 540 [XUA_BY82 330.00] TO BUS 70733 [UCERNI81 330.00] CKT 1     |
| 28-S  | : OPEN BRANCH FROM BUS 70985 [URAEAC_01 750.00] TO BUS 70945 [UZUKR701 750.00] CKT 0  |
| 29-S  | : OPEN BRANCH FROM BUS 70945 [UZUKR701 750.00] TO BUS 70808 [UHAEC_01 750.00] CKT 0   |
| 30-S  | : OPEN BRANCH FROM BUS 70945 [UZUKR701 750.00] TO BUS 70827 [UVN_7501 750.00] CKT 0   |
| 31-S  | : OPEN BRANCH FROM BUS 70772 [UKIEV01 750.00] TO BUS 70808 [UHAEC_01 750.00] CKT 0    |
| 32-S  | : OPEN BRANCH FROM BUS 70772 [UKIEV01 750.00] TO BUS 70827 [UVN_7501 750.00] CKT 0    |
| 33-S  | : OPEN BRANCH FROM BUS 70772 [UKIEV01 750.00] TO BUS 70703 [UCAEC_01 750.00] CKT 0    |
| 34-S  | : OPEN BRANCH FROM BUS 70827 [UVN_7501 750.00] TO BUS 70599 [UJUAZS01 750.00] CKT 0   |
| 35-S  | : OPEN BRANCH FROM BUS 70599 [UJUAZS01 750.00] TO BUS 70356 [UDNEPR01 750.00] CKT 0   |
| 36-S  | : OPEN BRANCH FROM BUS 70356 [UDNEPR01 750.00] TO BUS 70380 [UZAPAR01 750.00] CKT 0   |
| 37-S  | : OPEN BRANCH FROM BUS 70313 [UZAEC_01 750.00] TO BUS 70006 [UJDONB01 750.00] CKT 0   |
| 38-S  | : OPEN BRANCH FROM BUS 70380 [UZAPAR01 750.00] TO BUS 70186 [UDONBA01 750.00] CKT 0   |
| 39-S  | : OPEN BRANCH FROM BUS 70006 [UJDONB01 750.00] TO BUS 70186 [UDONBA01 750.00] CKT 0   |
| 40-S  | : OPEN BRANCH FROM BUS 70006 [UJDONB01 750.00] TO BUS 70007 [UJDONB81 330.00] CKT 1   |
| 41-S  | : OPEN BRANCH FROM BUS 70186 [UDONBA01 750.00] TO BUS 70181 [UDONBA81 330.00] CKT 1   |
| 42-S  | : OPEN BRANCH FROM BUS 70186 [UDONBA01 750.00] TO BUS 70185 [UDONBA91 500.00] CKT 1   |
| 43-S  | : OPEN BRANCH FROM BUS 70242 [USEVUK01 750.00] TO BUS 70241 [USEVUK81 330.00] CKT 0   |
| 44-S  | : OPEN BRANCH FROM BUS 70313 [UZAEC_01 750.00] TO BUS 70338 [UZAEC_81 330.00] CKT 0   |
| 45-S  | : OPEN BRANCH FROM BUS 70380 [UZAPAR01 750.00] TO BUS 70381 [UZAP7S81 330.00] CKT 1   |
| 46-S  | : OPEN BRANCH FROM BUS 70356 [UDNEPR01 750.00] TO BUS 70308 [UDNEPR81 330.00] CKT 1   |
| 47-S  | : OPEN BRANCH FROM BUS 70599 [UJUAZS01 750.00] TO BUS 70520 [UJUAZS81 330.00] CKT 0   |
| 48-S  | : OPEN BRANCH FROM BUS 70703 [UCAEC_01 750.00] TO BUS 70727 [UCAEC_81 330.00] CKT 1   |
| 49-S  | : OPEN BRANCH FROM BUS 70772 [UKIEV01 750.00] TO BUS 70773 [UKIEV81 330.00] CKT 0     |
| 50-S  | : OPEN BRANCH FROM BUS 70827 [UVN_7501 750.00] TO BUS 70826 [UVN_7581 330.00] CKT 0   |
| 51-S  | : OPEN BRANCH FROM BUS 70808 [UHAEC_01 750.00] TO BUS 70809 [UHAEC_81 330.00] CKT 0   |
| 52-S  | : OPEN BRANCH FROM BUS 70945 [UZUKR701 750.00] TO BUS 70941 [UZAPUK81 330.00] CKT 1   |
| 53-S  | : OPEN BRANCH FROM BUS 70985 [URAEAC_01 750.00] TO BUS 70902 [URAEAC_81 330.00] CKT 0 |
| 54-S  | : OPEN BRANCH FROM BUS 70508 [UUSAT081 330.00] TO BUS 70523 [UADZAL81 330.00] CKT 1   |
| 55-S  | : OPEN BRANCH FROM BUS 70508 [UUSAT081 330.00] TO BUS 70523 [UADZAL81 330.00] CKT 2   |
| 56-S  | : OPEN BRANCH FROM BUS 70822 [ULDTEC81 330.00] TO BUS 70530 [UKOTOV81 330.00] CKT 0   |
| 57-S  | : OPEN BRANCH FROM BUS 70520 [UJUAZS81 330.00] TO BUS 70523 [UADZAL81 330.00] CKT 0   |
| 58-S  | : OPEN BRANCH FROM BUS 70520 [UJUAZS81 330.00] TO BUS 70501 [UTRIHA81 330.00] CKT 0   |
| 59-S  | : OPEN BRANCH FROM BUS 70851 [UDNGAE81 330.00] TO BUS 70822 [ULDTEC81 330.00] CKT 0   |
| 60-S  | : OPEN BRANCH FROM BUS 70818 [UBAR3_81 330.00] TO BUS 70851 [UDNGAE81 330.00] CKT 0   |
| 61-S  | : OPEN BRANCH FROM BUS 70381 [UZAP7S81 330.00] TO BUS 70140 [UKUTEC81 330.00] CKT 0   |
| 62-S  | : OPEN BRANCH FROM BUS 70316 [UPDTEC81 330.00] TO BUS 70306 [UPAVL081 330.00] CKT 0   |
| 63-S  | : OPEN BRANCH FROM BUS 70306 [UPAVL081 330.00] TO BUS 70144 [UKRARM81 330.00] CKT 0   |
| 64-S  | : OPEN BRANCH FROM BUS 70144 [UKRARM81 330.00] TO BUS 70151 [UCENTR81 330.00] CKT 0   |
| 65-S  | : OPEN BRANCH FROM BUS 70328 [UKRGEC81 330.00] TO BUS 70218 [UKREME81 330.00] CKT 0   |
| 66-S  | : OPEN BRANCH FROM BUS 70218 [UKREME81 330.00] TO BUS 70308 [UDNEPR81 330.00] CKT 0   |
| 67-S  | : OPEN BRANCH FROM BUS 70701 [UNEZIN81 330.00] TO BUS 70214 [UKANAT81 330.00] CKT 0   |
| 68-S  | : OPEN BRANCH FROM BUS 70185 [UDONBA91 500.00] TO BUS 70178 [UPOBED91 500.00] CKT 0   |





|      |   |                                      |         |                        |         |       |
|------|---|--------------------------------------|---------|------------------------|---------|-------|
| 69-S | : | OPEN BRANCH FROM BUS 70170 [UHARCI81 | 330.00] | TO BUS 70125 [UJOZNA81 | 330.00] | CKT 0 |
| 70-S | : | OPEN BRANCH FROM BUS 70934 [UBUTEC11 | 400.00] | TO BUS 70919 [UMUKAC11 | 400.00] | CKT 0 |

#### 4.6.8. Armenia

##### BLACKSEA REGIONAL MODEL WINTER MAXIMUM LOAD 2010

ACCC OVERLOAD REPORT: MONITORED BRANCHES AND INTERFACES LOADED ABOVE 100.0 % OF RATING SET A  
CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT DIFFERS FROM ITS BASE CASE LOADING BY 10.0  
MVA (MW FOR INTERFACES)

CONTINGENCY CASE LOADING NOT CHECKED UNLESS IT EXCEEDS ITS BASE CASE LOADING BY 5.0

PERCENT OF RATING SET A

ACCC VOLTAGE REPORT: VOLTAGE BAND CHECK IN CONTINGENCY CASES SKIPPED FOR ANY BUS WITHIN 0.02000 OF ITS BASE CASE  
VOLTAGE MAGNITUDE

AC CONTINGENCY RESULTS FILE: E:\0\BSR\0report\AM\AM.acc  
DISTRIBUTION FACTOR FILE: E:\0\BSR\0report\AM\AM.dfx  
SUBSYSTEM DESCRIPTION FILE: E:\0\BSR\0report\AM\AM.sub  
MONITORED ELEMENT FILE: E:\0\BSR\0report\AM\AM.mon  
CONTINGENCY DESCRIPTION FILE: E:\0\BSR\0report\AM\AM.con

<----- MONITORED BRANCH -----> CONTINGENCY RATING FLOW %

MONITORED VOLTAGE REPORT:  
SYSTEM

CONTINGENCY <----- B U S -----> V-CONT V-INIT V-MAX V-MIN

##### BLACKSEA REGIONAL MODEL SUMMER MINIMUM LOAD 2010

<----- MONITORED BRANCH -----> CONTINGENCY RATING FLOW %


MONITORED VOLTAGE REPORT:  
SYSTEM

CONTINGENCY <----- B U S -----> V-CONT V-INIT V-MAX V-MIN

##### CONTINGENCY LEGEND:

LABEL EVENTS

|           |   |                                    |         |                        |         |       |
|-----------|---|------------------------------------|---------|------------------------|---------|-------|
| SINGLE 1  | : | OPEN LINE FROM BUS 541 [XAM_GE21   | 220.00] | TO BUS 82011 [8ALVRD2  | 220.00] | CKT 1 |
| SINGLE 2  | : | OPEN LINE FROM BUS 609 [XAM_GE11   | 400.00] | TO BUS 84099 [8HRAZD1  | 400.00] | CKT 1 |
| SINGLE 3  | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 82003 [8HRZ_H2  | 220.00] | CKT 1 |
| SINGLE 4  | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 82003 [8HRZ_H2  | 220.00] | CKT 2 |
| SINGLE 5  | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 82007 [8VANDZ2  | 220.00] | CKT 1 |
| SINGLE 6  | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 82007 [8VANDZ2  | 220.00] | CKT 2 |
| SINGLE 7  | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 82022 [8ZOVUN2  | 220.00] | CKT 1 |
| SINGLE 8  | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 82029 [8MARSH2  | 220.00] | CKT 1 |
| SINGLE 9  | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 82040 [8GAVAR2  | 220.00] | CKT 1 |
| SINGLE 10 | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 84099 [8HRAZD1  | 400.00] | CKT 1 |
| SINGLE 11 | : | OPEN LINE FROM BUS 82001 [8HRAZD2  | 220.00] | TO BUS 84099 [8HRAZD1  | 400.00] | CKT 2 |
| SINGLE 12 | : | OPEN LINE FROM BUS 82003 [8HRZ_H2  | 220.00] | TO BUS 82021 [8SHAUM2  | 220.00] | CKT 1 |
| SINGLE 13 | : | OPEN LINE FROM BUS 82007 [8VANDZ2  | 220.00] | TO BUS 82011 [8ALVRD2  | 220.00] | CKT 1 |
| SINGLE 14 | : | OPEN LINE FROM BUS 82007 [8VANDZ2  | 220.00] | TO BUS 82013 [8GYUMR2  | 220.00] | CKT 1 |
| SINGLE 15 | : | OPEN LINE FROM BUS 82013 [8GYUMR2  | 220.00] | TO BUS 82015 [8ASHNK2  | 220.00] | CKT 1 |
| SINGLE 16 | : | OPEN LINE FROM BUS 82015 [8ASHNK2  | 220.00] | TO BUS 82018 [8AMNPP2  | 220.00] | CKT 1 |
| SINGLE 17 | : | OPEN LINE FROM BUS 82015 [8ASHNK2  | 220.00] | TO BUS 82018 [8AMNPP2  | 220.00] | CKT 2 |
| SINGLE 18 | : | OPEN LINE FROM BUS 82018 [8AMNPP2  | 220.00] | TO BUS 82021 [8SHAUM2  | 220.00] | CKT 1 |
| SINGLE 19 | : | OPEN LINE FROM BUS 82018 [8AMNPP2  | 220.00] | TO BUS 82029 [8MARSH2  | 220.00] | CKT 1 |
| SINGLE 20 | : | OPEN LINE FROM BUS 82018 [8AMNPP2  | 220.00] | TO BUS 82032 [8ARART2  | 220.00] | CKT 1 |
| SINGLE 21 | : | OPEN LINE FROM BUS 82021 [8SHAUM2  | 220.00] | TO BUS 82022 [8ZOVUN2  | 220.00] | CKT 1 |
| SINGLE 22 | : | OPEN LINE FROM BUS 82021 [8SHAUM2  | 220.00] | TO BUS 82045 [8HAGHT2  | 220.00] | CKT 1 |
| SINGLE 23 | : | OPEN LINE FROM BUS 82032 [8ARART2  | 220.00] | TO BUS 82033 [8YEHEGN2 | 220.00] | CKT 1 |
| SINGLE 24 | : | OPEN LINE FROM BUS 82032 [8ARART2  | 220.00] | TO BUS 82045 [8HAGHT2  | 220.00] | CKT 1 |
| SINGLE 25 | : | OPEN LINE FROM BUS 82033 [8YEHEGN2 | 220.00] | TO BUS 82034 [8SPAND2  | 220.00] | CKT 1 |
| SINGLE 26 | : | OPEN LINE FROM BUS 82033 [8YEHEGN2 | 220.00] | TO BUS 82035 [8SHAMB2  | 220.00] | CKT 1 |
| SINGLE 27 | : | OPEN LINE FROM BUS 82033 [8YEHEGN2 | 220.00] | TO BUS 82039 [8LICHK2  | 220.00] | CKT 1 |
| SINGLE 28 | : | OPEN LINE FROM BUS 82034 [8SPAND2  | 220.00] | TO BUS 82036 [8SHINU2  | 220.00] | CKT 1 |
| SINGLE 29 | : | OPEN LINE FROM BUS 82035 [8SHAMB2  | 220.00] | TO BUS 82036 [8SHINU2  | 220.00] | CKT 1 |
| SINGLE 30 | : | OPEN LINE FROM BUS 82036 [8SHINU2  | 220.00] | TO BUS 82038 [8AGARK2  | 220.00] | CKT 1 |
| SINGLE 31 | : | OPEN LINE FROM BUS 82036 [8SHINU2  | 220.00] | TO BUS 82038 [8AGARK2  | 220.00] | CKT 2 |
| SINGLE 32 | : | OPEN LINE FROM BUS 82039 [8LICHK2  | 220.00] | TO BUS 82040 [8GAVAR2  | 220.00] | CKT 1 |



## 4.7. Border capacities

Table 4.1 - Indicative NTC values Winter 2010

| <b>Indicative values for Net Transfer Capacities ( NTC ) in Black Sea regio<br/>WINTER 2010<br/>(Non binding values)</b> |          |              |                   |
|--------------------------------------------------------------------------------------------------------------------------|----------|--------------|-------------------|
| FROM                                                                                                                     | TO       | MW           | VALUE PROVIDED BY |
| Bulgaria                                                                                                                 | Romania  | <b>1300</b>  | Bulgaria/Romania  |
|                                                                                                                          | Turkey   | <b>650</b>   | Bulgaria/Turkey   |
| Georgia                                                                                                                  | Russia   | <b>400</b>   | Georgia/Russia    |
|                                                                                                                          | Turkey   | <b>200</b>   | Georgia/Turkey    |
| Moldova                                                                                                                  | Romania  | <b>1950</b>  | Moldova/Romania   |
|                                                                                                                          | Ukraine  | <b>1150</b>  | Moldova/Ukraine   |
| Romania                                                                                                                  | Bulgaria | <b>1450</b>  | Bulgaria/Romania  |
|                                                                                                                          | Moldova  | <b>550</b>   | Moldova/Romania   |
|                                                                                                                          | Ukraine  | <b>2500+</b> | Romania/Ukraine   |
| Russia                                                                                                                   | Georgia  | <b>400</b>   | Georgia/Russia    |
|                                                                                                                          | Ukraine  | <b>3000</b>  | Russia/Ukraine    |
| Turkey                                                                                                                   | Bulgaria | <b>900</b>   | Bulgaria/Turkey   |
|                                                                                                                          | Georgia  | <b>200</b>   | Georgia/Turkey    |
| Ukraine                                                                                                                  | Moldova  | <b>1000</b>  | Moldova/Ukraine   |
|                                                                                                                          | Russia   | <b>3000</b>  | Russia/Ukraine    |
|                                                                                                                          | Romania  | <b>1750</b>  | Romania/Ukraine   |

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».





Table 4.2 – Indicative NTC values Summer 2010

| <b>Indicative values for Net Transfer Capacities ( NTC ) in Black Sea regio<br/>SUMMER 2010<br/>(Non binding values)</b> |          |              |                   |
|--------------------------------------------------------------------------------------------------------------------------|----------|--------------|-------------------|
| FROM                                                                                                                     | TO       | MW           | VALUE PROVIDED BY |
| Bulgaria                                                                                                                 | Romania  | <b>1900</b>  | Bulgaria/Romania  |
|                                                                                                                          | Turkey   | <b>600</b>   | Bulgaria/Turkey   |
| Georgia                                                                                                                  | Russia   | <b>850</b>   | Georgia/Russia    |
|                                                                                                                          | Turkey   | <b>200</b>   | Georgia/Turkey    |
| Moldova                                                                                                                  | Romania  | <b>700</b>   | Moldova/Romania   |
|                                                                                                                          | Ukraine  | <b>1600</b>  | Moldova/Ukraine   |
| Romania                                                                                                                  | Bulgaria | <b>1550</b>  | Bulgaria/Romania  |
|                                                                                                                          | Moldova  | <b>650</b>   | Moldova/Romania   |
|                                                                                                                          | Ukraine  | <b>2500+</b> | Romania/Ukraine   |
| Russia                                                                                                                   | Georgia  | <b>650</b>   | Georgia/Russia    |
|                                                                                                                          | Ukraine  | <b>3000</b>  | Ukraine/Russia    |
| Turkey                                                                                                                   | Bulgaria | <b>1500</b>  | Bulgaria/Turkey   |
|                                                                                                                          | Georgia  | <b>200</b>   | Georgia/Turkey    |
| Ukraine                                                                                                                  | Moldova  | <b>1750</b>  | Moldova/Ukraine   |
|                                                                                                                          | Russia   | <b>3000</b>  | Ukraine/Russia    |
|                                                                                                                          | Romania  | <b>1750</b>  | Romania/Ukraine   |

These indicative values have been computed by extrapolation from standard situations, in order to evaluate the transfer capacity through a single interface at the same time. Thus these figures should be considered separately and are not cumulative. When the evaluation of a transfer limit requires to use a set of assumption which are too far from usual or foreseeable situation (leading to high inaccuracies), the NTC figure has been replaced by « no realistic limit ».



#### 4.7.1. BULGARIA



Figure 4.35 – Bulgaria – NTC border capacities (values for 2005)





Figure 4.36 – Bulgaria – NTC border capacities 2010

Table 4.3 – Bulgaria – Winter 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies                | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|------------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                            | 5 | 6                  | 7                    | 8                      |
| BG-RO    | 1500   | INT  | OHL 400 kV RTANTA1-VAEC_41                  | INT  | OHL 400 kV RTANTA1-VAEC_41   | 1 | 1310MVA            | 1350.7MVA            | 101.5%                 |
| RO-BG    | 1650   |      | PRODUCTION LIMIT REACHED                    |      |                              |   |                    |                      |                        |
| BG-TR    | 850    | BG   | TR 400/220kV VMI3 2-VMI3 12                 | BG   | OHL 400 kV VMI3 11-VMI 1     | 1 | 800MVA             | 795.2MVA             | 99.5%                  |
| TR-BG    | 1000   | TR   | OHL 400 kV TADAPA12-TGEBZE11                | TR   | OHL 400 kV TADAPA12-TGEBZE11 | 2 | 1430MVA            | 1303MVA              | 96.0%                  |

Table 4.4 – Bulgaria – Summer 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies                | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|------------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                            | 5 | 6                  | 7                    | 8                      |
| BG-RO    | 2100   | INT  | OHL 400 kV RTANTA1-VAEC_41                  | INT  | OHL 400 kV RTANTA1-VAEC_41   | 1 | 1310MVA            | 1289MVA              | 97.5%                  |
| RO-BG    | 1750   |      | PRODUCTION LIMIT REACHED                    |      |                              |   |                    |                      |                        |
| BG-TR    | 800    | BG   | TR 400/220kV VMI3 2-VMI3 12                 | BG   | OHL 400 kV VMI3 11-VMI 1     | 1 | 800 MVA            | 821.9 MVA            | 102.7%                 |
| TR-BG    | 2000   | TR   | OHL 400 kV TADAPA12-TGEBZE11                | TR   | OHL 400 kV TADAPA12-TGEBZE11 | 2 | 1046.8MVA          | 977 MVA              | 93.3%                  |



#### 4.7.2. GEORGIA




Figure 4.37 – Georgia – Network capacities 2005



Figure 4.38 – Georgia – Network capacities 2010

Georgian and Russian Power Systems are connected through 500 KV lines is “Kavkasioni” by which the inflow amount

For 2010 summer is:


A) 1000 MW from Georgia to Russia , when the generated power by Enguri H.P.P is 1200 MW with voltage normal ranges .

B) 700 MW from Russia to Georgia, when Enguri H.P.P is out of service and in thermal plant 1 unit is operable with 120 MW.

For winter 2010 is :

A) 405 MW from Georgia to Russia, when the generated power by Enguri H.P.P is 1200 MW with normal voltages.

B) 610 MW from Russia to Georgia with normal voltages.



### 4.7.3. MOLDOVA

No Net Transfer Capacities for Moldova have been published up to now. The capability of Moldovan network at present is highly dependant on operation of neighboring Ukrainian network.





Figure 4.39 – Moldova – Network capacities 2010

Table 4.5 – Moldova – Winter 2010 results


| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies             | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|---------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                         | 5 | 6                  | 7                    | 8                      |
| MD-RO    | 1300   |      | MODEL INSTABILITY                           | MD   | OHL 330kV 5BALTS8-5STRAS8 | 1 | 788.8MVA           |                      |                        |
| RO-MD    | 800    |      | PRODUCTION LIMIT REACHED                    | INT  | OHL 400kV 5VULKA1-RISACC1 | 1 | 1212.4MVA          |                      |                        |
| MD-UA    | 1300   |      | MODEL INSTABILITY                           | MD   | OHL 330kV 5BALTS8-5STRAS8 | 1 | 788.8MVA           |                      |                        |
| UA-MD    | 800    |      | PRODUCTION LIMIT REACHED                    | INT  | OHL 400kV 5VULKA1-RISACC1 | 1 | 1212.4MVA          |                      |                        |

Table 4.6 – Moldova – Summer 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies               | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|-----------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                           | 5 | 6                  | 7                    | 8                      |
| MD-RO    | 800    | INT  | OHL 400kV RROSIO1-UMUKAC11 1                | INT  | OHL 400kV 5BALTS1-RSUCEA1 1 | 1 | 692.8MVA           |                      |                        |
| RO-MD    | 750    | RO   | OHL 220kV RLOTRU2-RSIBIU2 1                 | RO   | OHL 220kV RLOTRU2-RSIBIU2   | 2 | 333.4MVA           |                      |                        |
| MD-UA    | 1250   | INT  | OHL 400kV RROSIO1-UMUKAC11 1                | INT  | OHL 750kV MAISA 0-UZUKR702  | 1 | 2598.1MVA          |                      |                        |
| UA-MD    | 750    |      | PRODUCTION LIMIT REACHED                    |      |                             |   |                    |                      |                        |



#### 4.7.4. ROMANIA



Source: Indicative values for Net Transfer Capacities ( NTC ) in Europe

Figure 4.40 – Romania – Network capacities 2005





Figure 4.41 – Romania – Network capacities 2010

Table 4.7 – Romania – Winter 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies               | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|-----------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                           | 5 | 6                  | 7                    | 8                      |
| RO-MD    | 1400   | MD   | TR 330/110 5BALTS1                          | INT  | OHL 400kV 5BALTS1-RSUCEA1 1 | 1 | 210MVA             | 487                  | 231.9%                 |
| MD-RO    | 200    | MD   | PRODUCTION LIMIT REACHED                    |      |                             |   |                    |                      |                        |
| RO-UA    | 2000   |      | PRODUCTION LIMIT REACHED                    |      |                             |   |                    |                      |                        |
| UA-RO    | 500    | INT  | OHL 400kV RROSIO1-UMUKAC11 1                | INT  | OHL 750kV MAISA 0-UZUKR702  | 1 | 693MVA             | 695                  | 100.3%                 |
| RO-BG    | 1200   | INT  | OHL 400 kV RTANTA1-VAEC_41                  | INT  | OHL 400 kV RTANTA1-VAEC_41  | 1 | 1211MVA            | 1232.8               | 101.8%                 |
| BG-RO    | 1500   |      | PRODUCTION LIMIT REACHED                    |      |                             |   |                    |                      |                        |

Table 4.8 – Romania – Summer 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies               | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|-----------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                           | 5 | 6                  | 7                    | 8                      |
| RO-MD    | 1050   | MD   | TR 330/110 5BALTS1                          | INT  | OHL 400kV 5BALTS1-RSUCEA1 1 | 1 | 210MVA             | 537.6                | 256.0%                 |
| MD-RO    | 200    | INT  | OHL 330kV UUSATO81-5MREPP8 1                | INT  | OHL 400kV 5BALTS1-RSUCEA1 1 | 1 | 120MVA             | 122.16               | 101.8%                 |
| RO-UA    | 2000   |      | PRODUCTION LIMIT REACHED                    |      |                             |   |                    |                      |                        |
| UA-RO    | 450    | INT  | OHL 400kV RROSIO1-UMUKAC11 1                | INT  | OHL 750kV MAISA 0-UZUKR702  | 1 | 693MVA             | 700                  | 101.0%                 |
| RO-BG    | 1350   | INT  | OHL 400 kV RTANTA1-VAEC_41                  | INT  | OHL 400 kV RTANTA1-VAEC_41  | 1 | 1211MVA            | 1215.844             | 100.4%                 |
| BG-RO    | 2100   |      | PRODUCTION LIMIT REACHED                    |      |                             |   |                    |                      |                        |



#### 4.7.5. RUSSIA




Figure 4.42 – Russia – Network capacities 2005





Figure 4.43 – Russia – Network capacities 2010





#### 4.7.6. TURKEY




Figure 4.44 – Turkey – Network capacities 2005





Figure 4.45 – Turkey – Network capacities 2010

Table 4.9 – Turkey – winter 2010 results


| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies                | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|------------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                            | 5 | 6                  | 7                    | 8                      |
| TR-BG    | 1100   | TR   | OHL 400 kV TADAPA12-TGEBZE11                | TR   | OHL 400 kV TADAPA12-TGEBZE11 | 2 | 1430.7MVA          | 1302.5MVA            | 95.9%                  |
|          |        |      | TR 400/150 kV THAMIT1                       |      | OHL 400 kV TBABAE11-TUNIMR1  | 1 | 250MVA             | 286.5MVA             | 114.6%                 |
| BG-TR    | 850    | BG   | TR 400/220 kV VMI3 2 1                      | BG   | OHL 400 kV VMI3 11-VMI 1     | 1 | 800 MVA            | 795.2 MVA            | 99.5%                  |
| TR-GE    | 200    | TR   | TR 220/150 kV THOPA 3 1                     | TR   | OHL 500 kV 6HENGU9-6ZESTA9   | 1 | 150.0MVA           | 170.2MVA             | 113.5%                 |
|          |        | TR   | TR 220/150 kV THOPA 3 2                     |      |                              |   | 180.0MVA           | 179.8MVA             | 99.9%                  |
|          |        | INT  | OHL 220kV THOPA 2-6BATUM2 1                 |      |                              |   | 371.1MVA           | 349.3MVA             | 96.9%                  |
|          |        | GE   | OHL 220kV 6VARDI2 - 6ZUGDI2 1               |      |                              |   | 318.2MVA           | 382.2MVA             | 118.9%                 |
|          |        | INT  | OHL 220kV THOPA 2-6BATUM2 1                 | TR   | OHL 400 kV TDERIN1-TERZUR1   | 1 | 371.1MVA           | 356.1MVA             | 97.3%                  |
|          |        | TR   | TR 220/150 kV THOPA 3 1                     |      |                              |   | 150.0MVA           | 172.9MVA             | 115.3%                 |
|          |        | TR   | TR 220/150 kV THOPA 3 2                     |      |                              |   | 180.0MVA           | 182.6MVA             | 101.5%                 |
|          |        | TR   | TR 400/150 kV TBORCK1 1                     |      |                              |   | 250.0MVA           | 243.4MVA             | 97.4%                  |
| GE-TR    | 200    | TR   | TR 400/150 kV TBORCK1 2                     | GE   | OHL 500 kV 6HENGU9-6ZESTA9   |   | 250.0MVA           | 243.4MVA             | 97.4%                  |
|          |        | GE   | OHL 220 kV 6VARDI2 - 6ZUGDI2                |      |                              | 1 | 318.2 MVA          | 455.0 MVA            | 145.0%                 |
|          |        | GE   | TR 500/220 kV 6HENGU9 1                     |      |                              |   | 500 MVA            | 773.7 MVA            | 154.7%                 |

Table 4.10 – Turkey – Summer 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies                | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|------------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                            | 5 | 6                  | 7                    | 8                      |
| TR-BG    | 1700   | TR   | OHL 400 kV TADAPA12-TGEBZE11                | TR   | OHL 400 kV TADAPA12-TGEBZE11 | 2 | 1046.8MVA          | 976.8                | 95.3%                  |
| BG-TR    | 800    | BG   | TR 400/220 kV VMI3 2 1                      | BG   | OHL 400 kV VMI3 11-VMI 1     | 1 | 800 MVA            | 821.9                | 102.7%                 |
| TR-GE    | 200    | TR   | TR 220/150 kV THOPA 3 1                     | TR   | OHL 400 kV TTIREB1-TBORCK1   | 1 | 150.0MVA           | 165.6MVA             | 110.4%                 |
|          |        | TR   | TR 220/150 kV THOPA 3 2                     |      |                              |   | 180.0MVA           | 174.9MVA             | 97.2%                  |
|          |        | TR   | OHL 150 kV TMURAT3-TBORCK3                  |      |                              |   | 240.6MVA           | 370.2MVA             | 154.2%                 |
| GE-TR    | 200    | GE   | TR 500/220 kV 6HENGU9 1                     | INT  | OHL 500kV 4CENTR9-6HENGU9    | 1 | 500MVA             | 483.8MVA             | 96.8%                  |
|          |        | TR   | TR 220/150 kV THOPA 3 1                     |      |                              |   | 150.0MVA           | 177.7MVA             | 118.5%                 |



|  |  |     |                               |  |  |  |          |          |        |
|--|--|-----|-------------------------------|--|--|--|----------|----------|--------|
|  |  | TR  | TR 220/150 kV THOPA 3 2       |  |  |  | 180.0MVA | 187.7MVA | 104.3% |
|  |  | INT | OHL 220kV THOPA 2-6BATUM2 1   |  |  |  | 371.1MVA | 360.8MVA | 103.3% |
|  |  | GE  | OHL 220kV 6VARDI2 - 6TKVAR2 1 |  |  |  | 371.0MVA | 375.2MVA | 104.7% |
|  |  | GE  | OHL 220kV 6TKVAR2-6SOUKH2 1   |  |  |  | 371.0MVA | 365.0MVA | 101.9% |



#### 4.7.7. UKRAINE



Figure 4.46 - Ukraine – Network capacities for 2005




Figure 4.47 – Ukraine – Network capacities 2010

Table 4.11 – Ukraine – winter 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/ out of limits voltages | Area | contingencies              | # | limit<br>/ Unom | Flow<br>/ Voltage | rate<br>/ volt.dev. |
|----------|--------|------|------------------------------------------|------|----------------------------|---|-----------------|-------------------|---------------------|
| UA-MD    | 500    | RO   | OHL 220kV RBUC.S2B-RFUNDE22 1            |      |                            |   | 304.8MVA        | 398.4             | 130.7%              |
| MD-UA    | 1850   |      | PRODUCTION LIMIT REACHED                 |      |                            |   |                 |                   |                     |
| UA-RO    | 350    | INT  | OHL 400kV RROSIO1-UMUKAC11 1             | INT  | OHL 750kV MAISA 0-UZUKR702 | 1 | 692MVA          | 728               | 105.2%              |
| RO-UA    | 3000   |      | PRODUCTION LIMIT REACHED                 |      |                            |   |                 |                   |                     |





Table 4.12 – Ukraine – Summer 2010 results

| SCENARIO | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies              | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|----------|--------|------|---------------------------------------------|------|----------------------------|---|--------------------|----------------------|------------------------|
|          |        | 1    | 2                                           | 3    | 4                          | 5 | 6                  | 7                    | 8                      |
| UA-MD    | 2000   | RO   | OHL 220kV RFUNDE22-RBUC.S2B 1               |      |                            |   | 304.8MVA           | 348.4                | 114.3%                 |
|          |        | RO   | OHL 220kV RFUNDE21-RBUC.S2B 1               |      |                            |   | 304.8MVA           | 342                  | 112.2%                 |
| MD-UA    | 2000   |      | PRODUCTION LIMIT REACHED                    |      |                            |   |                    |                      |                        |
| UA-RO    | 300    | INT  | OHL 400kV RROSIO1-UMUKAC11 1                | INT  | OHL 750kV MAISA 0-UZUKR702 | 1 | 692                | 717                  | 103.6%                 |
| RO-UA    | 3000   |      | PRODUCTION LIMIT REACHED                    |      |                            |   |                    |                      |                        |

#### 4.7.8. ARMENIA

There are no NTC values for Armenia, since it operates only in radial operation with neighboring countries, and transfers are limited by the capacities of existing interconnection lines.



#### 4.8. Import/Export Scenarios



Figure 4.48 – Import/Export – Network capacities Winter 2010

Table 4.13 – Import/Export - Winter 2010 results

| SCENARIO  | AMOUNT | Area | overloadings<br>/ out of limits voltages | Area | contingencies                | # | limit<br>/ Unom | Flow<br>/ Voltage | rate<br>/ volt.dev. |
|-----------|--------|------|------------------------------------------|------|------------------------------|---|-----------------|-------------------|---------------------|
|           |        | 1    | 2                                        | 3    | 4                            | 5 | 6               | 7                 | 8                   |
| RO-TR     | 1300   | INT  | OHL 400 kV RTANTA1-VAEC_41               | INT  | OHL 400 kV RTANTA1-VAEC_41   | 1 | 1211MVA         | 1236.2            | 102.0%              |
| TR-RO     | 1450   | TR   | OHL 400kV TADAPA12-TGEBZE11 1            | TR   | OHL 400kV TADAPA12-TGEBZE11  | 2 | 1430.7MVA       | 1456.5            | 101.8%              |
| UA+RU-CE  | 3450   | INT  | OHL 750kV ZRZE7101-UHAEC_01 1            | INT  | OHL 400kV RROSIO1-UMUKAC11   | 1 | 2507.1MVA       |                   |                     |
| UA+RU-SEE | 1500   | RO   | TR 400/220kV RROSIO1 1                   | RO   | OHL 400kV RROSIO1-RGADAL1    | 1 | 400MVA          |                   |                     |
| TR-UCTE   | 1200   | TR   | OHL 400 kV TADAPA12-TGEBZE11             | TR   | OHL 400 kV TADAPA12-TGEBZE11 | 2 | 1430.7MVA       | 1314.4MVA         | 96.9%               |
|           |        |      | TR 400/150 kV THAMIT1                    |      | OHL 400 kV TBABAE11-TUNIMR1  | 1 | 250.0MVA        | 320.2MVA          | 128.1%              |
| UCTE-TR   | 1000   | TR   | TR 400/150 kV THAMIT1 1                  | TR   | OHL 400 kV GFILIP1-VMIZ 11   | 1 | 250.0MVA        | 259.4MVA          | 103.8%              |
|           |        | TR   | OHL 400 kV TBABAE12-TGEBZE11             | TR   | OHL 400 kV TBABAE12-TGEBZE11 | 1 | 250.0MVA        | 348.5MVA          | 139.4%              |
|           |        | RO   | OHL 110kV RCTA N5-RCTA B5                | RO   | OHL 400 kV TBABAE12-VMIZ 11  | 1 | 149.6MVA        | 165.4MVA          | 111.1%              |
|           |        | BG   | TR 220/110 kV VPLEVE21 1                 | BG   | OHL 400 kV VCAREV1-VMIZIA1   | 1 | 200.0MVA        | 194.9MVA          | 97.5%               |





Figure 4.49 – Import/Export – Network capacities Summer 2010

Table 4.14 – Import/Export - Summer 2010 results

| SCENARIO  | AMOUNT | Area | overloadings<br>/<br>out of limits voltages | Area | contingencies                | # | limit<br>/<br>Unom | Flow<br>/<br>Voltage | rate<br>/<br>volt.dev. |
|-----------|--------|------|---------------------------------------------|------|------------------------------|---|--------------------|----------------------|------------------------|
|           |        | 1    | 2                                           | 3    | 4                            | 5 | 6                  | 7                    | 8                      |
| RO-TR     | 1450   | TR   | OHL 400kV THAMIT1-TBABAE12                  | INT  | OHL 400kV THAMIT1-VMI3 11    | 1 | 1057.2MVA          | 1082.6               | 102.4%                 |
| TR-RO     | 1300   |      | PRODUCTION LIMIT REACHED                    |      |                              |   |                    |                      |                        |
| UA+RU-CE  | 3400   | INT  | OHL 750kV ZRZE7101-UHAEC_01 1               | INT  | OHL 400kV QVKAP_1-UMUKAC11   | 1 | 692.8MVA           |                      |                        |
| UA+RU-SEE | 2000   | INT  | OHL 400kV 5BALTS1-RSUCEA1 1                 | INT  | OHL 750kV MAISA 0-UZUKR702   | 1 | 1212.4MVA          |                      |                        |
| TR-UCTE   | 1800   | TR   | OHL 400 kV TADAPA12-TGEBZE11                | TR   | OHL 400 kV TADAPA12-TGEBZE11 | 2 | 1046.8MVA          | 998.1MVA             | 97.5%                  |
| UCTE-TR   | 1100   | TR   | OHL 400 kV TADAPA12-TGEBZE12                | TR   | OHL 400 kV TPASAK1-TGEBZE12  | 1 | 1589.3MVA          | 1480.0MVA            | 95.2%                  |
|           |        | BG   | TR 400/220 kV VMI3 2 1                      | BG   | OHL 400 kV VMI3 11-VMI 1     | 1 | 800MVA             | 810.8MVA             | 101.3%                 |



---

## **5. NEW PLANNED LINES AND SUBSTATIONS**






Table 5.1 – Black Sea region - Planned network reinforcements

| TYPE     | SUBSTATION1 |                    | SUBSTATION2 |                   | VOLTAGE LEVEL | Number Of Circuits /units | CAPACITY |                  | MATERIAL OR TRANSFORMER TYPE | CROSS mm2 | LENGTH |        |          | DATE OF COMMISSION | STATUS            |
|----------|-------------|--------------------|-------------|-------------------|---------------|---------------------------|----------|------------------|------------------------------|-----------|--------|--------|----------|--------------------|-------------------|
|          |             |                    |             |                   | kV/kV         |                           | A or MVA | limited A or MVA |                              |           | BR1 km | BR2 km | TOTAL km |                    |                   |
| 1        | 2           | 3                  | 2           | 3                 | 4             | 5                         | 6        | 7                | 8                            | 9         | 10     | 11     | 12       | 13                 | 14                |
| BULGARIA |             |                    |             |                   |               |                           |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | BG          | C.Mogila           | MK          | Stip              | 400           | 1                         | 1890     | -                | ACSR                         | 2X500     | 80     | 70     | 150      | 2008               | construction      |
| OHL      | BG          | M.East             | GR          | Nea Santa         | 400           | 1                         | 1890     | -                | ACSR                         | 2X500     | -      | -      | -        | -                  | Feasibility study |
| OHL      | BG          | Zlatitsa           | BG          | Plovdiv           | 400           | 1                         | 1890     | -                | ACSR                         | 2X500     | -      | -      | 140      | 2007               |                   |
| GEORGIA  |             |                    |             |                   |               |                           |          |                  |                              |           |        |        |          |                    |                   |
| SS       | GE          | Qsani              |             |                   | 500/400       | 1                         | 3X267    |                  | LTC                          |           |        |        |          | 2009               | Feasibility study |
| OHL      | GE          | Qsani              | AM          | TPP Hrazdan       | 400           | 1                         | 1100     | 1400             | ACSR                         | 2x300     | 80     | 90     | 170      | 2009               | Feasibility study |
| OHL      | GE          | Mukharani          | AZ          | AZ TPP            | 330           | 1                         |          |                  |                              |           |        |        | 283      |                    |                   |
| SS       | GE          | Akhhaltske         |             |                   | 500/400       | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| BB       | GE          | Akhhaltske         |             |                   | 400           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | GE          | Akhhaltske         |             | Marneuli          | 500           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | GE          | Marneuli           |             | Gardabani         | 500           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | GE          | Akhhaltske         |             | Menji             | 500           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | GE          | Menji              |             | Kudoni            | 500           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | GE          | Akhhaltske         |             | Zestaponi         | 500           | 1                         |          |                  |                              |           |        |        | 71       |                    |                   |
| OHL      | GE          | Akhhaltske         | TR          | Borcka            | 400           | 1                         |          |                  |                              |           |        |        | 130      |                    |                   |
| OHL      | GE          | Gardabani          | AR          | Atarbeksan        | 330           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | GE          | Enguri             | RU          | Centralna(Sochi)  | 500           | 1                         |          |                  |                              |           |        |        | 450      |                    |                   |
| MOLDOVA  |             |                    |             |                   |               |                           |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | MD          | Balti              | RO          | Suceava           | 400           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| SS       | MD          | Chisinau           |             |                   | 400/330       | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | MD          | Chisinau           | RO          | Iasi              | 400           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | MD          | Balti              | UA          | Dnestrovskia HPP  | 330           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | MD          | Balti              | MD          | Straseni          | 330           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | MD          | Straseni           | MD          | Chisinau          | 330           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | MD          | Balti              | MD          | Ribnita           | 330           | 1                         |          |                  |                              |           |        |        |          |                    |                   |
| SS       | MD          | Balti              |             |                   | 400/330       | 1                         |          |                  | IPC                          |           |        |        |          |                    |                   |
| SS       | MD          | Moldovskaya        |             |                   | 400/330       | 1                         |          |                  | IPC                          |           |        |        |          |                    |                   |
| ROMANIA  |             |                    |             |                   |               |                           |          |                  |                              |           |        |        |          |                    |                   |
| SS       | RO          | Portile de Fier II |             |                   | 220/110       | 2                         | 2*200    |                  | 2 windings                   |           |        |        |          | 2008               |                   |
| OHL      | RO          | Portile de Fier II | RO          | Cetate            | 220           | 1                         | 875      |                  | Ol-Al                        | 450       |        |        | 80       | 2008               |                   |
| OHL      | RO          | Portile de Fier II | RO          | Portile de Fier I | 220           | 1                         | 875      |                  | Ol-Al                        | 450       |        |        | 71       | 2008               |                   |
| CSS      | RO          | Nadab              |             | -                 | 400           |                           |          |                  |                              |           |        |        |          |                    |                   |
| OHL      | RO          | Oradea             | RO          | Nadab             | 400           | 1                         | 1997     |                  | Ol-Al                        | 3*300     |        |        | 75       |                    |                   |
| OHL      | RO          | Arad               | RO          | Nadab             | 400           | 1                         | 1997     |                  | Ol-Al                        | 3*300     |        |        | 35       |                    |                   |
| OHL      | RO          | Nadab              | HU          | Bekescsaba Border | 400           | 1                         | 1750     |                  | Ol-Al                        | 3*300     |        |        | 23       | 2008               |                   |
| OHL      | HU          | Bekescsaba Border  | HU          | Bekescsaba        | 400           | 1                         | 1750     |                  | Ol-Al                        | 2*500     |        |        | 37       | 2010               |                   |
| SS       | RO          | Suceava            |             |                   | 400/110       | 2                         | 250      |                  | 2 windings                   |           |        |        |          | 2010               |                   |
| OHL      | RO          | Suceava            | MD          | Balti             | 400           | 1                         | 1750     |                  | Ol-Al                        | 3*300     |        |        | 95       | 2014               |                   |






|        |    |                   |    |               |         |   |         |  |            |       |     |     |      |           |              |
|--------|----|-------------------|----|---------------|---------|---|---------|--|------------|-------|-----|-----|------|-----------|--------------|
| SS     | RO | Bacau             |    |               | 400/220 | 1 | 400     |  | 2 windings |       |     |     |      | 2014      |              |
| SS     | RO | Roman             |    |               | 400/220 | 1 | 400     |  | 2 windings |       |     |     |      | 2014      |              |
| OHL    | RO | Suceava           | RO | Roman         | 400     | 1 | 1700    |  | Ol-Al      | 3*300 |     |     | 100  | 2014      |              |
| OHL    | RO | Roman             | RO | Bacau         | 400     | 1 | 1700    |  | Ol-Al      | 3*300 |     |     | 58.8 | 2014      |              |
| OHL    | RO | Bacau             | RO | Gutinas       | 400     | 1 | 1700    |  | Ol-Al      | 3*300 |     |     | 55.3 | 2014      |              |
| SS     | RO | Iasi              |    |               | 400/220 |   |         |  |            |       |     |     |      | 2010      |              |
| OHL    | RO | Iasi              | MD | Chisinau      | 400     | 1 |         |  |            |       |     |     |      | 2010      |              |
| SS     | RO | Resita            |    |               | 400/220 | 1 | 400     |  | 2 windings |       |     |     |      | 2014      |              |
| SS     | RO | Resita            |    |               | 400/110 | 1 | 250     |  | 2 windings |       |     |     |      | 2014      |              |
| OHL    | RO | Portile de Fier I | RO | Resita        | 400     | 1 | 1997    |  | Ol-Al      | 3*300 |     |     | 117  | 2014      |              |
| SS     | RO | Timisoara         |    |               | 400/220 | 1 | 400     |  | 2 windings |       |     |     |      | 2014      |              |
| OHL    | RO | Timisoara         | RO | Resita        | 400     | 1 | 1997    |  | Ol-Al      | 3*300 |     |     | 73   | 2014      |              |
| OHL    | RO | Timisoara         | RO | Arad          | 400     | 1 | 1997    |  | Ol-Al      | 3*300 |     |     | 55   | 2014      |              |
| OHL    | RO | Timisoara         | CS | Vrsac         | 400     | 1 | 1750    |  | Ol-Al      | 3*300 |     |     | 100  | 2014      |              |
| DC     | RO | Constanta         |    |               | 400     |   | 600     |  |            |       |     |     |      | ?         |              |
| SK     | RO | Constanta         | TR | Pasakoy       | 400     | 1 | 600     |  |            |       | 200 | 200 | 400  | ?         |              |
| OHL    | RO | Constanta         | RO | Medgidia      | 400     | 1 | 1800    |  | Ol-Al      | 3*300 |     |     | 21   | 2010-2014 |              |
| RUSSIA |    |                   |    |               |         |   |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Sotchi            | GE | Enguri        | 500     | 1 |         |  |            |       |     |     | 450  |           |              |
| SS     | RU | Rostov            |    |               | 500     | 2 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Rostov            |    | Sahti 30      | 500     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Rostov            |    | Frolovskaya   | 500     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Rostov            |    | R 20          | 220     | 1 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Krimskaya II      |    |               | 500     | 2 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Krimskaya II      |    | Tihoreck      | 500     | 1 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Senaya            |    | Senaya        | 220     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Krimskaya II      |    | Senaya        | 220     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Krimskaya II      |    | Slavyansk     | 220     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Slavyansk         |    | Senaya        | 220     | 1 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Nevinomysk        |    |               | 500     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Nevinomysk        |    | Volgodonskaya | 500     | 1 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Mozdok            |    |               | 500     | 2 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Nevinomysk        |    | Mozdok        | 500     | 1 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Alagir            |    |               | 330     | 2 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Nalcik            |    | Alagir        | 330     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | V2                |    | Alagir        | 330     | 1 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Kizljär           |    |               | 330     | 2 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Grozniy           |    |               | 330     | 2 |         |  |            |       |     |     |      |           |              |
| SS     | RU | Artem             |    |               | 330     | 2 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Mozdok            |    | Artem         | 330     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | HP Irganskaya     |    | Artem         | 330     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Derbent           |    | Artem         | 330     | 1 |         |  |            |       |     |     |      |           |              |
| OHL    | RU | Derbent           | AZ | Apsheeron     | 330     | 1 |         |  |            |       |     |     |      |           |              |
| TURKEY |    |                   |    |               |         |   |         |  |            |       |     |     |      |           |              |
| SS     | TR | Afyon             | -  | -             | 400/150 |   | 250     |  |            |       |     |     |      | 2006      | construction |
| SS     | TR | Agri              | -  | -             | 400/150 |   | 250+150 |  |            |       |     |     |      | 2006      | construction |



|         |    |                    |    |                |         |   |          |   |      |          |     |     |     |      |                   |
|---------|----|--------------------|----|----------------|---------|---|----------|---|------|----------|-----|-----|-----|------|-------------------|
| OHL     | TR | Aliğa              |    | Manisa         | 400     | 1 |          |   | ACSR | 3Bx1272  |     |     |     | 2006 | completed         |
| SS      | TR | Baglum             | -  | -              | 400/150 |   | 2x250    |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Beykoz GIS         | -  | -              | 400/33  |   | 2x125    |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Davutpaşa GIS      | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Davutpaşa GIS      | -  | -              | 400/33  |   | 125      |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Erzurum            | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | 2006 | construction      |
| OHL     | TR | Erzurum            |    | Horasan        | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | construction      |
| SS      | TR | Germencik          | -  | -              | 400/150 |   | 2x250    |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Hilvan             | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Hilvan             | -  | -              | 400/33  |   | 125      |   |      |          |     |     |     | 2006 | construction      |
| OHL     | TR | Horasan            |    | Agri           | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | construction      |
| OHL     | TR | HPP Borçka-Deriner |    | HPP Yusufeli   | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | construction      |
| OHL     | TR | HPP Oymapinar      |    | Varsak         | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | construction      |
| OHL     | TR | HPP Yusufeli       |    | Erzurum        | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | construction      |
| SS      | TR | İkiteli            | -  | -              | 400/33  |   | 2x125    |   |      |          |     |     |     | 2005 | completed         |
| K       | TR | İkitelli           |    | Davutpasa      | 400     | 1 |          |   |      | 2000 mm2 |     |     |     | 2006 | completed         |
| OHL     | TR | Isiklar            |    | Manisa         | 400     | 1 |          |   | ACSR | 3Bx1272  |     |     |     | 2006 | completed         |
| OHL     | TR | Iyidere            |    | HPP Borçka     | 400     | 1 |          |   | ACSR | 3Bx1272  |     |     |     | 2006 | completed         |
| OHL     | TR | Karabiga-Çan       |    | TPP Soma       | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | construction      |
| OHL     | TR | Karakya-Ataturk    |    | Hilvan         | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | completed         |
| SS      | TR | Manisa             | -  | -              | 400/150 |   | 2x250    |   |      |          |     |     |     | 2006 | construction      |
| OHL     | TR | Tirebolu           |    | Iyidere        | 400     | 1 |          |   | ACSR | 3Bx1272  |     |     |     | 2006 | completed         |
| SS      | TR | TPP Iskenderun     | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | 2006 | construction      |
| OHL     | TR | TPP Unimar         |    | Babaeski       | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | construction      |
| OHL     | TR | Yeniköy-Uzundere   |    | Aydin          | 400     | 2 |          |   | ACSR | 3Bx954   |     |     |     | 2006 | completed         |
| K       | TR | Yildiztepe         |    | Davutpasa      | 400     | 2 |          |   |      | 2000 mm2 |     |     |     | 2006 | construction      |
| SS      | TR | Zekeriya GIS       | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Zekeriya GIS       | -  | -              | 400/33  |   | 125      |   |      |          |     |     |     | 2006 | construction      |
| SS      | TR | Hatay              | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | 2007 | construction      |
| SS      | TR | Hatay              | -  | -              | 400/33  |   | 125      |   |      |          |     |     |     | 2007 | construction      |
| OHL     | TR | Hatay              |    | Erzin          | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2007 | construction      |
| SS      | TR | Mersin             | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | 2007 | construction      |
| SS      | TR | Mersin             | -  | -              | 400/33  |   | 125      |   |      |          |     |     |     | 2007 | construction      |
| OHL     | TR | Mersin             |    | TPP Iskenderun | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2007 | construction      |
| OHL     | TR | Seydişehir         |    | HPP Oymapinar  | 400     | 1 |          |   | ACSR | 3Bx954   |     |     |     | 2007 | construction      |
| SS      | TR | Umraniye           | -  | -              | 400/150 |   | 2x250    |   |      |          |     |     |     | 2007 | construction      |
| SS      | TR | Borçka             | -  | -              | 400/150 |   | 250      |   |      |          |     |     |     | ?    |                   |
| OHL     | TR | Borcka             | GE | Akhalske       | 400     | 1 |          |   |      |          |     |     | 130 |      |                   |
| OHL     | TR | Babaeski           | GR | N.Santa        | 400     | 1 |          |   | ACSR | 3Bx954   | 64  |     |     | 2010 | F.study           |
| DC      | TR | Pasakoy            |    |                | 400     |   | 600 MW   |   |      |          |     |     |     |      | Idea              |
| SK      | TR | Pasakoy            | RO | Constanta      | 400     | 1 | 600 MW   |   |      |          | 200 | 200 | 400 |      | Idea              |
| UKRAINE |    |                    |    |                |         |   |          |   |      |          |     |     |     |      |                   |
| OHL     | UA | Pivdenoukrainskaya | RO | Isaccea        | 750     | 1 | 4000 A   | - | ACSR | 400*5    | 406 | 3   | 409 | 2015 | Feasibility study |
| SS      | UA | Kyivska            |    |                | 750/330 | 1 | 1000 MVA | - | PST  | -        | -   | -   | -   | 2008 | Construction      |
| OHL     | UA | Rivnenska NPP      | UA | Kyivska        | 750     | 1 | 4000 A   | - | ACSR | 400*5    | 370 | 0   | 370 | 2008 | Construction      |
| OHL     | UA | Zahidnoukrainska   | UA | Bogorodchani   | 330     | 1 | 1670 A   | - | ACSR | 400*2    | 111 | 0   | 111 | 2010 | Construction      |




|         |    |                    |    |                      |         |    |         |         |      |           |     |     |     |      |                   |
|---------|----|--------------------|----|----------------------|---------|----|---------|---------|------|-----------|-----|-----|-----|------|-------------------|
| OHL     | UA | Dnistrovska PSHPP  | UA | Bar                  | 330     | 1  | 1670 A  | -       | ACSR | 400*2     | 95  | 0   | 95  | 2007 | Construction      |
| OHL     | UA | Novoodeska         | UA | Artsyzy              | 330     | 1  | 1670 A  | -       | ACSR | 400*2     | 140 | 0   | 140 | 2007 | Feasibility study |
| OHL     | UA | Adgalyk            | UA | Usatovo              | 330     | 1  | 1670 A  | -       | ACSR | 400*2     | 124 | 0   | 124 | 2007 | Feasibility study |
| OHL     | UA | Zarya              | UA | Mirna                | 330     | 1  | 1380 A  | -       | ACSR | 300*2     | 14  | 0   | 14  | 2008 | Construction      |
| OHL     | UA | Simferopol         | UA | Sevastopol           | 330     | 1  | 1670 A  | -       | ACSR | 400*2     | 70  | 0   | 70  | 2007 | Feasibility study |
| OHL     | UA | Dgankoj            | UA | Melitopol-Simferopol | 330     | 1  | 1380 A  | -       | ACSR | 400*2     | 16  | 0   | 16  | 2006 | Construction      |
| OHL     | UA | Pivnichnoukrainska | UA | Kyivska              | 750     | 1  | 4000 A  | -       | ACSR | 400*5     | 292 | 0   | 292 | 2015 | Feasibility study |
| OHL     | UA | Zaporizka NPP      | UA | Kahovska             | 750     | 1  | 4000 A  | -       | ACSR | 400*5     | 190 | 0   | 190 | 2015 | Feasibility study |
| OHL     | UA | Lutsk Pivnichna    | UA | Ternopil             | 330     | 1  | 1670 A  | -       | ACSR | 400*2     | 180 | 0   | 180 | 2010 | Feasibility study |
| OHL     | UA | K.Podolska         | UA | Ternopil             | 330     | 1  | 1670 A  | -       | ACSR | 400*2     | 150 | 0   | 150 | 2012 | Feasibility study |
| OHL     | UA | HPP Dnistrovksa    | MD | Balti                | 330     | 1  | 1670 A  | -       | ACSR | 400*2     | 120 | 0   | 120 | 2012 | Idea              |
| ARMENIA |    |                    |    |                      |         |    |         |         |      |           |     |     |     |      |                   |
| SS      | AM | Hrazdan TPP        |    |                      | 400/220 | 10 | 2x5x200 | 2x5x220 |      |           |     |     |     | 2009 | Feasibility study |
| OHL     | AM | Hrazdan TPP        | IR | Tavrız               | 400     | 2  | 2x1800  | 2x1900  | ACSR | 2x(2x500) | 332 | 100 | 432 | 2010 | Feasibility study |
| OHL     | AM | Hrazdan TPP        | GE | Ksani                | 400     | 1  | 1100    | 1400    | ACSR | 2x300     | 90  | 80  | 170 | 2009 | Feasibility study |

- 1 Type of project (OHL - overhead line, K - cable, SK - submarine cable, SS - substation, BB - back to back system...)
- 2 Country (ISO code)
- 3 Substation name
- 4 Installed voltage (for lines nominal voltage, for transformers ratio in voltages)
- 5 number of circuits/units
- 6 Conventional transmission capacity of elements for OHL in Amps, for transformers in MVA
- 7 Conventional transmission capacity limited by transformers or substations
- 8 Type of conductor or transformer (ACSR - Aluminum Cross-section Steel Reinforced, or code of conductor, PS - phase shift transformer...)
- 9 Cross-section (number of ropes in bundle x cross-section/cross-section of reinforcement rope)
- 10 Length till border of first state
- 11 Length till border of second state
- 12 Total length
- 13 Date of commissioning (estimate)
- 14 Status of project (Idea, Feasibility study, Construction, Damaged, out of service, Decommissioned...)


Table 5.2 – Black Sea region - Planned new generation units

| TYPE | SUBSTATION1 |                | VOLTAGE LEVEL |     | CAPACITY |        | DATE OF COMMISSIONING | STATUS       |
|------|-------------|----------------|---------------|-----|----------|--------|-----------------------|--------------|
|      |             |                | kV            | kV  | MW       | MVA    | year                  |              |
| 1    | 2           | 3              | 4             | 5   | 6        | 7      | 8                     | 9            |
| NPP  | BG          | Belene         | 24            | 400 | 2x1000   | 2x1111 | 2012                  | construction |
| CCHP | MD          | Balti          | 15.75         | 400 | 3x150    | 3x176  | 2010                  |              |
| CCHP | MD          | Vulkanesti     | 15.75         | 400 | 3x150    | 3x176  | 2010                  |              |
| NPP  | RO          | Cernavoda      | 24            | 400 | 2x700    | 740    | 2010- 2014            | construction |
| HPP  | RU          | Zaramagskaya   |               | 330 |          |        | 2010                  |              |
| HPP  | RU          | Cherkeskaya II |               | 330 |          |        | 2010                  |              |
| NPP  | RU          | Volgodonskaya  | 20            | 500 | 1000     | 1111   | 2010                  |              |
| HPP  | TR          | Ermenek        |               | 400 | 320      |        | -2010                 |              |
| HPP  | TR          | Kargı          |               | 400 | 214      |        | -2010                 |              |
| HPP  | TR          | Borçka         |               | 400 | 300      |        | -2010                 |              |



|       |    |                      |       |     |             |     |       |                    |
|-------|----|----------------------|-------|-----|-------------|-----|-------|--------------------|
| HPP   | TR | Deriner              |       | 400 | 670         |     | -2010 |                    |
| PSHPP | UA | Dnistrovskia         | 15.75 | 330 | 324/416     | 360 | 2008  | Construction       |
| CCHP  | UA | Kyivska 6            | 20    | 330 | 250         | 353 | 2008  | Construction       |
| PSHPP | UA | Tashlykska           | 15.75 | 330 | 2x146/2x211 | 307 | 2006  | Construction       |
| PSHPP | UA | Tashlykska           | 15.75 | 330 | 2x146/2x211 | 307 | 2008  | Construction       |
| CCHP  | AM | Yerevan TPP new unit | 18    | 110 | 208         | 240 | 2009  | Tendering          |
| TPP   | AM | Hrazdan TPP unit 5   | 15.75 | 220 | 440         | 510 | 2009  | Partly Constructed |

- 1 Type of plant (HPP - Hydropower plant, TPP - Thermal power plant, PSHPP - Pump Storage Hydro Power Plant, CCHP - Combined Cycle Heating Plant...)
- 2 Country
- 3 Substation name
- 4 Generator voltage level
- 5 Network voltage level
- 6 Installed active power
- 7 Installed apparent power
- 8 Date of commissioning (estimate)
- 9 Status of the project (Idea, Feasibility study, Construction...)



## 6. FINDINGS

Findings based on past experience and calculations performed, what are critical points of interconnected network, limitations in regional network and how new elements that are modeled influence these limitations

Connection between Turkey and Georgia is at present only one 220kV line Hopa(TR)-Batumi(GE), and this is most limiting factor for transfer capacity between these two countries. Building of the new 400 kV line Borcka (TR)- Akhaltske (GE) will significantly increase transfer capacity between these two countries, to at least 600 MW in both directions.

It is also essential to strengthen internal 500 kV network in Georgia, with two new lines connecting Achalciche (GE) substation with existing stations Zestafoni and Gardabani. To increase further secure operation of the system is also necessary to build line Enguri-Achalchice as back up to old line Enguri-Zestafoni. Together with building the second line between Centralna (RU)-Enguri(GE), this will significantly increase overall network capacities in the region.

1. In case of a synchronous operation of the whole area a natural load flow loop is triggered. The direction is Russia → Ukraine → Romania → Bulgaria → Turkey → Georgia → Russia and it can involve up to 300 MW creating big problems for the weak interconnection between Georgia and Turkey. {to be checked for Armenia}
2. Connection between Turkey and Georgia (only one 220 kV s.c. OHL) is presently the most limiting factor for transfer capacity in the analyzed area. Building of a new interconnection 400 kV s.c. OHL (Borcka – Akhaltsikhe) operating in asynchronous mode (back-to-back station of 650 MW) will significantly increase the safety in operation of Georgian Power System and the total transfer capacity in both directions.
3. According to the calculations the NTC between the countries are presented in the following Table:

Table 1 – Indicative values for the bilateral transmission capacity – Winter Peak Load

| No | FROM     | TO       | $\Delta E_{max}$ [MW] | BCE [MW] | TRM [MW] | NTC [MW] |
|----|----------|----------|-----------------------|----------|----------|----------|
| 1  | Bulgaria | Romania  | 1500                  | 0        | 200      | 1300     |
| 2  | Bulgaria | Turkey   | 850                   | 0        | 200      | 650      |
| 3  | Georgia  | Russia   | 650                   | -200     | 50       | 400      |
| 4  | Georgia  | Turkey   | 250                   | 0        | 50       | 200      |
| 5  | Moldova  | Romania  | 1300                  | 750      | 100      | 1950     |
| 6  | Moldova  | Ukraine  | 1850                  | -450     | 250      | 1150     |
| 7  | Romania  | Bulgaria | 1650                  | 0        | 200      | 1450     |
| 8  | Romania  | Moldova  | 1400                  | -750     | 100      | 550      |
| 9  | Romania  | Ukraine  | above 2500            | 0        | 150      | 2500     |
| 10 | Russia   | Georgia  | 250                   | 200      | 50       | 400      |
| 11 | Russia   | Ukraine  | 3150                  | 200      | 350      | 3000     |
| 12 | Turkey   | Bulgaria | 1100                  | 0        | 200      | 900      |
| 13 | Turkey   | Georgia  | 450                   | 0        | 50       | 400      |
| 14 | Ukraine  | Moldova  | 800                   | 450      | 250      | 1000     |
| 15 | Ukraine  | Russia   | 3550                  | -200     | 350      | 3000     |
| 16 | Ukraine  | Romania  | 1900                  | 0        | 150      | 1750     |




Table 2 – Indicative values for the bilateral transmission capacity – Summer Light Load


| No | FROM     | TO       | $\Delta E_{max}$ [MW] | BCE [MW] | TRM [MW] | NTC [MW] |
|----|----------|----------|-----------------------|----------|----------|----------|
| 1  | Bulgaria | Romania  | 2100                  | 0        | 200      | 1900     |
| 2  | Bulgaria | Turkey   | 800                   | 0        | 200      | 600      |
| 3  | Georgia  | Russia   | 900                   | 0        | 50       | 850      |
| 4  | Georgia  | Turkey   | 50                    | 200      | 50       | 200      |
| 5  | Moldova  | Romania  | 450                   | 350      | 100      | 700      |
| 6  | Moldova  | Ukraine  | 2200                  | -350     | 250      | 1600     |
| 7  | Romania  | Bulgaria | 1750                  | 0        | 200      | 1550     |
| 8  | Romania  | Moldova  | 1100                  | -350     | 100      | 650      |
| 9  | Romania  | Ukraine  | above 2500            | 0        | 150      | 2500     |
| 10 | Russia   | Georgia  | 700                   | 0        | 50       | 650      |
| 11 | Russia   | Ukraine  | 3150                  | 200      | 350      | 3000     |
| 12 | Turkey   | Bulgaria | 1700                  | 0        | 200      | 1500     |
| 13 | Turkey   | Georgia  | 450                   | -200     | 50       | 200      |
| 14 | Ukraine  | Moldova  | 1650                  | 350      | 250      | 1750     |
| 15 | Ukraine  | Russia   | 3550                  | -200     | 350      | 3000     |
| 16 | Ukraine  | Romania  | 1900                  | 0        | 150      | 1750     |

4. If we consider the structure forecasted for 2010 the results from the previous tables shows a very strongly meshed power grid between some of the countries in the area, thus:
  - Between Ukraine and Russia – over 3000 MW in both winter and summer regimes.
  - Between Romania and Ukraine – over 2500 MW in both winter and summer regimes
5. Also, for the same time horizon (2010) and power grid structure we can identify some “weak points” :
  - Between Georgia and Turkey – only 200 MW in both winter and summer regimes
  - Between Turkey and Bulgaria – only 600 MW in the winter regime
  - Between Romania and Moldova - ~600 MW in both winter and summer regimes
  - Between Russia and Georgia – 600 ÷ 700 MW

Taking into account the geographical conditions and the other interconnection of Turkey with Greece in the same area, it is understandable the low capacity between Turkey and Bulgaria but for the rest of the weak points identified in this project new investments are to be recommended.
6. According to the companies proposals the new projects were classified in three categories:
  - construction;
  - Feasibility study
  - Ideas/proposals.


The projects in construction or in a very close stage to the construction starting were classified in the first category and included in the model with the status “ON”.

Elements classified as Feasibility study are projects for which technical evaluation is in progress or it is finished. Now they are in stage of finding adequate ways to financial fund they realization.




The rest of the new projects were classified in the category Idea/proposal and most of them are included in the model with the status “OFF”. These projects will be analyzed in the future whether they are feasible or not.

| TYPE     | SUBSTATION1 |                    | SUBSTATION2 |                   | VOLTAGE<br>LEVEL<br>kV/kV | CAPACITY<br>A or MVA | DATE<br>OF<br>COMM | STATUS            |
|----------|-------------|--------------------|-------------|-------------------|---------------------------|----------------------|--------------------|-------------------|
| BULGARIA |             |                    |             |                   |                           |                      |                    |                   |
| OHL      | BG          | C.Mogila           | MK          | Stip              | 400                       | 1890                 | 2008               | construction      |
| OHL      | BG          | M.East             | GR          | Nea Santa         | 400                       | 1890                 | -                  | Feasibility study |
| OHL      | BG          | Zlatitsa           | BG          | Plovdiv           | 400                       | 1890                 | 2007               | Feasibility study |
| GEORGIA  |             |                    |             |                   |                           |                      |                    |                   |
| SS       | GE          | Qsani              |             |                   | 500/400                   | 3X267                | 2009               | Feasibility study |
| OHL      | GE          | Qsani              | AM          | TPP Hrazdan       | 400                       | 1100                 | 2009               | Feasibility study |
| OHL      | GE          | Mukharani          | AZ          | AZ TPP            | 330                       |                      |                    | existing          |
| SS       | GE          | Akhaltske          |             |                   | 500/400                   |                      |                    | Feasibility study |
| BB       | GE          | Akhaltske          |             |                   | 400                       |                      |                    | Feasibility study |
| OHL      | GE          | Akhaltske          |             | Marneuli          | 500                       |                      |                    | Feasibility study |
| OHL      | GE          | Marneuli           |             | Gardabani         | 500                       |                      |                    | Feasibility study |
| OHL      | GE          | Akhaltske          |             | Menji             | 500                       |                      |                    | Feasibility study |
| OHL      | GE          | Menji              |             | Kudoni            | 500                       |                      |                    | Feasibility study |
| OHL      | GE          | Akhaltske          |             | Zestaponi         | 500                       |                      |                    | Feasibility study |
| OHL      | GE          | Akhaltske          | TR          | Borcka            | 400                       |                      |                    | Feasibility study |
| OHL      | GE          | Enguri             | RU          | Centralna(Sochi)  | 500                       |                      |                    | Idea              |
| MOLDOVA  |             |                    |             |                   |                           |                      |                    |                   |
| OHL      | MD          | Balti              | RO          | Suceava           | 400                       |                      |                    | Idea              |
| SS       | MD          | Chisinau           |             |                   | 400/330                   |                      |                    | Idea              |
| OHL      | MD          | Chisinau           | RO          | Iasi              | 400                       |                      |                    | Idea              |
| OHL      | MD          | Balti              | UA          | Dnestrovskya HPP  | 330                       |                      |                    | Idea              |
| OHL      | MD          | Balti              | MD          | Straseni          | 330                       |                      |                    | Idea              |
| OHL      | MD          | Straseni           | MD          | Chisinau          | 330                       |                      |                    | Idea              |
| OHL      | MD          | Balti              | MD          | Ribnita           | 330                       |                      |                    | Idea              |
| SS       | MD          | Balti              |             |                   | 400/330                   |                      |                    | Idea              |
| SS       | MD          | Moldovskaya        |             |                   | 400/330                   |                      |                    | Idea              |
| ROMANIA  |             |                    |             |                   |                           |                      |                    |                   |
| SS       | RO          | Portile de Fier II |             |                   | 220/110                   | 2*200                | 2008               | Feasibility study |
| OHL      | RO          | Portile de Fier II | RO          | Cetate            | 220                       | 875                  | 2008               | Feasibility study |
| OHL      | RO          | Portile de Fier II | RO          | Portile de Fier I | 220                       | 875                  | 2008               | Feasibility study |
| CSS      | RO          | Nadab              |             | -                 | 400                       |                      |                    | Feasibility study |
| OHL      | RO          | Oradea             | RO          | Nadab             | 400                       | 1997                 |                    | Feasibility study |
| OHL      | RO          | Arad               | RO          | Nadab             | 400                       | 1997                 |                    | Feasibility study |
| OHL      | RO          | Nadab              | HU          | Bekescsaba Border | 400                       | 1750                 | 2008               | Feasibility study |
| OHL      | HU          | Bekescsaba Border  | HU          | Bekescsaba        | 400                       | 1750                 | 2010               | Feasibility study |
| SS       | RO          | Suceava            |             |                   | 400/110                   | 250                  | 2010               | Feasibility study |
| OHL      | RO          | Suceava            | MD          | Balti             | 400                       | 1750                 | 2014               | Feasibility study |
| SS       | RO          | Bacau              |             |                   | 400/220                   | 400                  | 2014               | Feasibility study |
| SS       | RO          | Roman              |             |                   | 400/220                   | 400                  | 2014               | Feasibility study |
| OHL      | RO          | Suceava            | RO          | Roman             | 400                       | 1700                 | 2014               | Feasibility study |
| OHL      | RO          | Roman              | RO          | Bacau             | 400                       | 1700                 | 2014               | Feasibility study |
| OHL      | RO          | Bacau              | RO          | Gutinas           | 400                       | 1700                 | 2014               | Feasibility study |
| SS       | RO          | Iasi               |             |                   | 400/220                   |                      | 2010               | Feasibility study |
| OHL      | RO          | Iasi               | MD          | Chisinau          | 400                       |                      | 2010               | Feasibility study |
| SS       | RO          | Resita             |             |                   | 400/220                   | 400                  | 2014               | Feasibility study |
| SS       | RO          | Resita             |             |                   | 400/110                   | 250                  | 2014               | Feasibility study |
| OHL      | RO          | Portile de Fier I  | RO          | Resita            | 400                       | 1997                 | 2014               | Feasibility study |
| SS       | RO          | Timisoara          |             |                   | 400/220                   | 400                  | 2014               | Feasibility study |
| OHL      | RO          | Timisoara          | RO          | Resita            | 400                       | 1997                 | 2014               | Feasibility study |
| OHL      | RO          | Timisoara          | RO          | Arad              | 400                       | 1997                 | 2014               | Feasibility study |
| OHL      | RO          | Timisoara          | CS          | Vrsac             | 400                       | 1750                 | 2014               | Feasibility study |
| DC       | RO          | Constanta          |             |                   | 400                       | 600                  | ?                  | Feasibility study |
| SK       | RO          | Constanta          | TR          | Pasakoy           | 400                       | 600                  | ?                  | Feasibility study |
| OHL      | RO          | Constanta          | RO          | Medgidia          | 400                       | 1800                 | 2014               | Feasibility study |
| RUSSIA   |             |                    |             |                   |                           |                      |                    |                   |
| OHL      | RU          | Sotchi             | GE          | Enguri            | 500                       |                      |                    | Idea              |
| SS       | RU          | Rostov             |             |                   | 500                       |                      |                    | Feasibility study |
| OHL      | RU          | Rostov             |             | Sahti 30          | 500                       |                      |                    | Feasibility study |
| OHL      | RU          | Rostov             |             | Frolovskaya       | 500                       |                      |                    | Feasibility study |
| OHL      | RU          | Rostov             |             | R 20              | 220                       |                      |                    | Feasibility study |
| SS       | RU          | Krimskaya II       |             |                   | 500                       |                      |                    | Feasibility study |
| OHL      | RU          | Krimskaya II       |             | Tihoreck          | 500                       |                      |                    | Feasibility study |
| SS       | RU          | Senaya             |             | Senaya            | 220                       |                      |                    | Feasibility study |




|         |    |                    |    |                      |         |          |      |                   |
|---------|----|--------------------|----|----------------------|---------|----------|------|-------------------|
| OHL     | RU | Krimskaya II       |    | Senaya               | 220     |          |      | Feasibility study |
| OHL     | RU | Krimskaya II       |    | Slavyansk            | 220     |          |      | Feasibility study |
| OHL     | RU | Slavyansk          |    | Senaya               | 220     |          |      | Feasibility study |
| SS      | RU | Nevinomysk         |    |                      | 500     |          |      | Feasibility study |
| OHL     | RU | Nevinomysk         |    | Volgodonskaya        | 500     |          |      | Feasibility study |
| SS      | RU | Mozdok             |    |                      | 500     |          |      | Feasibility study |
| OHL     | RU | Nevinomysk         |    | Mozdok               | 500     |          |      | Feasibility study |
| SS      | RU | Alagir             |    |                      | 330     |          |      | Feasibility study |
| OHL     | RU | Nalcik             |    | Alagir               | 330     |          |      | Feasibility study |
| OHL     | RU | V2                 |    | Alagir               | 330     |          |      | Feasibility study |
| SS      | RU | Kizljär            |    |                      | 330     |          |      | Feasibility study |
| SS      | RU | Grozniy            |    |                      | 330     |          |      | Feasibility study |
| SS      | RU | Artem              |    |                      | 330     |          |      | Feasibility study |
| OHL     | RU | Mozdok             |    | Artem                | 330     |          |      | Feasibility study |
| OHL     | RU | HP Irganskaya      |    | Artem                | 330     |          |      | Feasibility study |
| OHL     | RU | Derbent            |    | Artem                | 330     |          |      | Feasibility study |
| OHL     | RU | Derbent            | AZ | Apsheeron            | 330     |          |      | Feasibility study |
| TURKEY  |    |                    |    |                      |         |          |      |                   |
| SS      | TR | Afyon              | -  | -                    | 400/150 | 250      | 2006 | construction      |
| SS      | TR | Agri               | -  | -                    | 400/150 | 250+150  | 2006 | construction      |
| SS      | TR | Baglum             | -  | -                    | 400/150 | 2x250    | 2006 | construction      |
| SS      | TR | Beykoz GIS         | -  | -                    | 400/33  | 2x125    | 2006 | construction      |
| SS      | TR | Davutpaşa GIS      | -  | -                    | 400/150 | 250      | 2006 | construction      |
| SS      | TR | Davutpaşa GIS      | -  | -                    | 400/33  | 125      | 2006 | construction      |
| SS      | TR | Erzurum            | -  | -                    | 400/150 | 250      | 2006 | construction      |
| OHL     | TR | Erzurum            |    | Horasan              | 400     |          | 2006 | construction      |
| SS      | TR | Germencik          | -  | -                    | 400/150 | 2x250    | 2006 | construction      |
| SS      | TR | Hilvan             | -  | -                    | 400/150 | 250      | 2006 | construction      |
| SS      | TR | Hilvan             | -  | -                    | 400/33  | 125      | 2006 | construction      |
| OHL     | TR | Horasan            |    | Agri                 | 400     |          | 2006 | construction      |
| OHL     | TR | HPP Borçka-Deriner |    | HPP Yusufeli         | 400     |          | 2006 | construction      |
| OHL     | TR | HPP Oymapinar      |    | Varsak               | 400     |          | 2006 | construction      |
| OHL     | TR | HPP Yusufeli       |    | Erzurum              | 400     |          | 2006 | construction      |
| OHL     | TR | Karabiga-Çan       |    | TPP Soma             | 400     |          | 2006 | construction      |
| SS      | TR | Manisa             | -  | -                    | 400/150 | 2x250    | 2006 | construction      |
| SS      | TR | TPP Iskenderun     | -  | -                    | 400/150 | 250      | 2006 | construction      |
| OHL     | TR | TPP Unimar         |    | Babaeski             | 400     |          | 2006 | construction      |
| K       | TR | Yildiztepe         |    | Davutpasa            | 400     |          | 2006 | construction      |
| SS      | TR | Zekeriyaçay GIS    | -  | -                    | 400/150 | 250      | 2006 | construction      |
| SS      | TR | Zekeriyaçay GIS    | -  | -                    | 400/33  | 125      | 2006 | construction      |
| SS      | TR | Hatay              | -  | -                    | 400/150 | 250      | 2007 | construction      |
| SS      | TR | Hatay              | -  | -                    | 400/33  | 125      | 2007 | construction      |
| OHL     | TR | Hatay              |    | Erzin                | 400     |          | 2007 | construction      |
| SS      | TR | Mersin             | -  | -                    | 400/150 | 250      | 2007 | construction      |
| SS      | TR | Mersin             | -  | -                    | 400/33  | 125      | 2007 | construction      |
| OHL     | TR | Mersin             |    | TPP Iskenderun       | 400     |          | 2007 | construction      |
| OHL     | TR | Seydişehir         |    | HPP Oymapinar        | 400     |          | 2007 | construction      |
| SS      | TR | Umraniye           | -  | -                    | 400/150 | 2x250    | 2007 | construction      |
| SS      | TR | Borçka             | -  | -                    | 400/150 | 250      | 2010 | Feasibility study |
| OHL     | TR | Borçka             | GE | Akhaltse             | 400     |          |      | Feasibility study |
| OHL     | TR | Babaeski           | GR | N.Santa              | 400     |          | 2010 | F.study           |
| DC      | TR | Pasakoy            |    |                      | 400     | 600 MW   |      | Idea              |
| SK      | TR | Pasakoy            | RO | Constanta            | 400     | 600 MW   |      | Idea              |
| UKRAINE |    |                    |    |                      |         |          |      |                   |
| OHL     | UA | Pivdenoukrainskaya | RO | Isaccea              | 750     | 4000 A   | 2015 | Feasibility study |
| SS      | UA | Kyivska            |    |                      | 750/330 | 1000 MVA | 2008 | Construction      |
| OHL     | UA | Rivnenska NPP      | UA | Kyivska              | 750     | 4000 A   | 2008 | Construction      |
| OHL     | UA | Zahidnoukrainska   | UA | Bogorodchani         | 330     | 1670 A   | 2010 | Construction      |
| OHL     | UA | Dnistrovka PSHPP   | UA | Bar                  | 330     | 1670 A   | 2007 | Construction      |
| OHL     | UA | Novoodeska         | UA | Artsyz               | 330     | 1670 A   | 2007 | Feasibility study |
| OHL     | UA | Adgalyk            | UA | Usatovo              | 330     | 1670 A   | 2007 | Feasibility study |
| OHL     | UA | Zarya              | UA | Mirna                | 330     | 1380 A   | 2008 | Construction      |
| OHL     | UA | Simferopol         | UA | Sevastopol           | 330     | 1670 A   | 2007 | Feasibility study |
| OHL     | UA | Dgankoj            | UA | Melitopol-Simferopol | 330     | 1380 A   | 2006 | Construction      |
| OHL     | UA | Pivnichnoukrainska | UA | Kyivska              | 750     | 4000 A   | 2015 | Feasibility study |
| OHL     | UA | Zaporizka NPP      | UA | Kahovska             | 750     | 4000 A   | 2015 | Feasibility study |
| OHL     | UA | Lutsk Pivnichna    | UA | Ternopil             | 330     | 1670 A   | 2010 | Feasibility study |
| OHL     | UA | K.Podolska         | UA | Ternopil             | 330     | 1670 A   | 2012 | Feasibility study |
| OHL     | UA | HPP Dnistrovka     | MD | Balti                | 330     | 1670 A   | 2012 | Idea              |
| ARMENIA |    |                    |    |                      |         |          |      |                   |
| SS      | AM | Hrazdan TPP        |    |                      | 400/220 | 2x5x200  | 2009 | Feasibility study |





|     |    |             |    |        |     |        |      |                   |
|-----|----|-------------|----|--------|-----|--------|------|-------------------|
| OHL | AM | Hrazdan TPP | IR | Tavrız | 400 | 2x1800 | 2010 | Feasibility study |
| OHL | AM | Hrazdan TPP | GE | Ksani  | 400 | 1100   | 2009 | Feasibility study |

7. Network capacities analyses for market realistic scenarios of power exchanges showed that expected network topology enables secure exchange of following quantities from Black Sea region



Import/Export – Network capacities Winter 2010



Import/Export – Network capacities Summer 2010

